# SZS CONSULTING GROUP

#### **HOVLAND HALL**

**ADA ASSESSMENT & SURVEY** 



Sacramento Office 770 L Street, Suite 950 Sacramento, CA 95814 Tel: 916.669.8750 Fax: 888.211.7441

Silicon Valley Office 2225 E. Bayshore Road, Suite 200 Palo Alto CA 94303 Tel: 866.694.7637 www.szs-consulting.com

September 16, 2019



GABRIEL MERRELL
DIRECTOR, ACCESS AND AFFIRMATIVE ACTION
DEPUTY ADA COORDINATOR
OFFICE OF EQUAL OPPORTUNITY AND ACCESS
OREGON STATE UNIVERSITY
330 SNELL HALL
CORVALLIS, OR 97331

Re: ADA Accessibility Survey and Assessment – Hovland Hall

Dear Gabriel,

We are pleased to submit this report for Hovland Hall. This report is part of our project to provide a Campus Accessibility Survey and Assessment for Oregon State University. It is our hope that this report will assist OSU in improving access to people with disabilities to campus facilities.

SZS has been pleased to be a part of this effort to evaluate campus buildings using federal and state statutes and regulations, as well as universal design principles in order to create performance standards that will guide design, construction and maintenance on campus.

We look forward to discussing our findings with your team.

Regards,

Syroun Z. Sanossian, Principal

Syn Z. Somi

SZS Consulting Group LLC

#### **TABLE OF CONTENTS**

1.	EXECUII	VE SUMMARY OF FINDINGS	<b>p.</b> 1
	<b>a.</b>	Pedestrian Facilities and Exterior Spaces Analyzed	p. 2
	b.	Building Entrances	p. 3
2.	INTERIOR	R SPACES	
		Basement	p. 3
		First - Second Floor	p. 4
3.	BARRIE	R DATA RECORDS	
		Exterior Area Barriers	p. 6
		Interior Area Barriers	p. 10
		Cost Estimate	p. 292

#### 1. EXECUTIVE SUMMARY OF FINDINGS

The field investigation for the interior spaces began on June 24, 2019. The exterior site elements were assessed originally as part of the pedestrian facilities assessment in June-September 2011 and are included as an essential part of this report. Images of each physical element identified in this report were captured in HD digital photos while manual measurements were taken to establish as-built conditions to facilitate the process of cost estimating. Digital photographs are provided within the report for each barrier to access, to facilitate the review of the data collected. We have found that technical data can be difficult to interpret without a visual component; the photos provide a clear connection between the technical data and each barrier to access.

Hovland Hall is a historic structure and many barriers to access were identified in the building. That is quite typical, as barriers to access exist in virtually every building, whether new or existing.

No "perfect" building exists in the real world.

This ADA Assessment and Survey report is intended to not only identify barriers to access, but to provide solutions. The basis for this ADA Assessment and Survey process is the underlying desire on the part of OSU to improve access by relying on higher standards than the minimum requirements in state and federal building codes. SZS intends to provide the information in this report in a clear and easy to understand format. The information in this report is compiled for use by designated OSU staff and other interested persons, so the content is designed to be understood by professionals and laymen alike.

The findings presented are both narrative and technical in nature; barriers to access identified during the field investigation process are documented in two ways;

1. Narrative Analysis: The analysis of findings is contained in an executive summary in a narrative form that not only describes each type of barrier identified, but also provides a discussion that analyses the functionality of physical elements. We also provide the reasoning and research behind the identification of barriers that conflict with universal design principles. This analysis may be accompanied by digital photographs or diagrams, where applicable.

NOTE: Understanding building function and usage is essential when interpreting the findings held in this report. The narrative is intended to facilitate this process.

2. Barrier Data Records: Individual barriers to access are entered into the SZS database so that technical information on the barriers can be provided as barrier data records. These barrier data records include digital photographs of each barrier identified, code references that determine the barrier to access, as-built measurements, barrier severity ratings, budgetary cost estimates, recommended solutions for barrier removal and a priority for barrier removal. The information is formatted with two barriers on each report page.

In order to consolidate the report data, some of the more typical barriers found in multiple locations have been grouped within the barrier data records with a description of the locations in which they were found.

#### A. Pedestrian Facilities and Exterior Spaces Analyzed

This report provides information on campus pedestrian facilities that serve Hovland Hall. Many physical elements are part of the comprehensive whole that creates a pedestrian facility. The fundamental elements evaluated as to whether they provide accessible pedestrian facilities include the following:

- Sidewalks
- Walkways
- Ramps
- Curb Ramps
- Blended Transitions
- Signalized Intersections
- Stairways (94% of people with disabilities are not mobility impaired)
- Benches and other Seating Elements
- Picnic Facilities

The descriptions provided for physical elements in this report are intended to clearly describe the differences between each physical element, such as when a pedestrian route is a sidewalk, rather than a walkway. The descriptions are intended to explain how the elements interact to form a cohesive pedestrian facility. Other more specific information described within this section intends to provide guidance on determinations made in this report.

The key to providing accessible pedestrian facilities is in recognizing that different people with disabilities have different needs. Setting policies that speak to the entire group is essential, rather than focusing on one particular subset of the overall group. Universal design principles govern here – physical elements should be usable to everyone that visits campus without having to resort to any adaptation or specialized design.

In summary, an accessible route exists within a building, property boundary or interior space and is separate from the PROW. Pedestrian walkways are similar to sidewalks as paved surfaces improved for use by pedestrians, but walkways are not located along or adjacent to the curb line, gutter or roadway and walkways are generally not considered part of the PROW. The pedestrian facility is the combination of the PROW and the accessible route, which functions as a whole to provide pedestrian access to facility entrances.

As a public building that was constructed prior to the passage of the ADA, Hovland Hall should have at least one accessible entrance, which was identified at the south entrance. This entrance was provided with a walkway that led to the basement floor main entrance and a corridor. No elevator was provided to carry passengers to reach all floors.

Hovland Hall has no accessible route provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public

transportation stops to the accessible building or facility entrance they serve<sup>1</sup> as compared to the 2010 ADA Standard for Accessible Design. Details on barriers identified in that route are provided within the ADA Assessment and Survey of the pedestrian facilities (provided as a separate report) as well as in the following records. Please see the barrier data records for details.

#### **B.** Building Entrances

The building was located along SW Campus Way and SW 26th Street within campus. Offstreet parking was provided at the southeast side of the building across from an accessible grade level pedestrian entrance equipped with an automatic door opening device. This entrance was altered recently to provide an accessible sloped walkway from the adjacent parking lot, although no accessible route was provided between this accessible entrance and other buildings or the campus pedestrian path at large.

Stairways leading to exterior doors were located at the north, southeast and west side of the building. The north entrance was the main entrance to the building and an ISA directional sign was posted at this entrance indicating the location of and route to the south accessible entrance. Although these doors do not need to be fully accessible, the stairs lack contrasting colors and accessible handrails. ISA directional signage should be provided for each location where stairways are the only form of vertical access to help ensure that pedestrians seeking an accessible entrance are not forced to retrace their steps.

Hovland Hall provided services including the following Departments:

- Arts & Sciences Business Center
- Office of Human Resources
- Agricultural Science & Marine Science Business Center (Finance & Acct Office)
- Philosophy
- History of Science & Environmental Arts and Humanities
- **Applied Ethics**
- Fisheries and Wildlife

#### INTERIOR SPACES

#### **BASEMENT**

Hovland Hall is a three-story building including a basement floor. The building provided graduate student offices, faculty offices, conference rooms, and classrooms. An accessible entrance to the basement was located on this level south of the building and the entrance was equipped with an automatic door opening device. The basement housed a business center, a conference room, offices and multiple utility rooms. The only interior pedestrian connection between the west and east side of the building traveled through a corridor with

<sup>&</sup>lt;sup>1</sup> 2010 ADA Standards for Accessible Design, Section 206.2.1 Site Arrival Points

a steep ramp. Sloped floors were identified in the lobby vestibule, corridors, offices, and many other locations. No lobby information signage was provided in the building that stated locations of accessible features such as restrooms, drinking fountains and other features. As a performance standard, it is recommended that lobby identification signage be provided on each floor, in each central corridor to help ensure that people with disabilities are not forced to retrace their steps.

All entrances on the basement level were identified with steeply sloped door landings. The doors were also identified with non-accessible operating force, low door headroom, door maneuvering clearance, clear width, door hardware and view panels that were installed too high for people who are short or who use wheelchairs to access which can be problematic when entry doors do not provide the option to see if the swinging door is going to collide with a person within the corridor, space or stairway.

General issues included tactile signs that were mounted too high and the Braille on the signs was located too close to the raised tactile characters. Also, horns and strobes were not provided in many of the rooms and the conference room lacked assistive listening systems and accessible tables.

No elevator was identified in the building. Stairs provided the only connection to the upper floors and with no vertical access or accessible route in some corridors where steep ramps exist between stairway landings and vestibule doors. Stairway treads at the top and bottom of each set of stairs lacked contrasting colors for people who have vision impairments. Handrails were mounted too low and lacked accessible handrail extensions.

A single accommodation toilet room and a multi-accommodation women's restroom were provided on this floor. The single accommodation toilet room was identified with sloped

floors, dispensers that protruded into the circulation route and no wheelchair accessible lavatory or toilet. Accessible tactile signs were not provided. Door maneuvering clearance was not accessible for people who use a mobility device. A typical water closet is shown at right.

Many staff use only areas were identified in the building. These spaces include IT rooms, janitorial rooms, private faculty offices and associated spaces. Signage at the



door/doorway to these spaces was included in this report as it is located along the public circulation route of travel, but these interior spaces were not investigated as part of this assessment process. In general, institutions and organizations make staff-use-only areas accessible as needed through the reasonable accommodation iterative process between the employer and employee.

#### FIRST - SECOND FLOOR

The lobby entrance for the first floor was located at the north side of the building with entry by way of an exterior stairway. The only accessible entrance to the building was at the basement level. No lobby information sign was provided to indicate the location of accessible features such as restrooms, drinking fountains, etc. and electrical outlets, switches, and controls were not within accessible reach range. Floor slope was not level (less than 2.0%) in many locations. Multiple objects protruded into the circulation route and

corridors were narrow and did not provided adequate maneuvering clearance for people who use mobility devices. At many doors in narrow corridors, maneuvering space adequate to allow a person to maneuver to enter the building was not present and automatic door opening devices would compensate for the lack of maneuvering clearance.

A classroom was located on the first floor and another classroom was located on the second floor. Both classrooms lacked accessible doors, shared assistive listening systems. and accessible desks. Desks were arranged in a way that did not provide a 36" wide unobstructed circulation path, whiteboard writing surfaces were installed too high, telephones and pencil sharpeners created protruding objects and no horn/strobe device was provided in the common use areas.

Faculty offices, graduate student offices, and conference rooms used for student meetings, lacked accessible entry door hardware, operating force where closers were installed, accessible signage, and view panels usable by short people. Conference rooms also lacked assistive listening systems. The clear floor space needed to enable use of whiteboards and the chalkboards was blocked by furniture or stored items in some locations. The spaces generally lacked accessible light switches and outlets, coat racks and strobe devices.

The single accommodation toilet rooms provided on the first floor and a single user restroom provided on second floor were not identified as wheelchair accessible or usable by people who are short, similar to the toilet rooms described above.

The following barrier data records provide more detailed information on the barriers described above.





Field Date:	7/13/2011 Report Date 7/13/2011 Barrier #: 2245A
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477428.999 Y Coordinate: 340543.167
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Bottom
Code References:	OSSC 1109.8.6.(2)
Performance Sta	andard: No Quantity: LF As-built : 44
Barrier Description:	Bottom handrail extension not min. 12" + tread width at stair bottom
Findings:	Bottom handrail extension not accessible
Rec. Solution:	Provide accessible handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	7/13/2011 Report Date 7/13/2011 Barrier #: 2245B
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477428.999 Y Coordinate: 340543.167
Barrier Area:	Stairways
Barrier Area: Barrier Type:	Stairways Handrail Extension - Bottom
	A Company of the Comp
Barrier Type: Code	Handrail Extension - Bottom OSSC 1109.8.6.(2)
Barrier Type: Code References:	Handrail Extension - Bottom OSSC 1109.8.6.(2)
Barrier Type: Code References: Performance Sta Barrier	Handrail Extension - Bottom  OSSC 1109.8.6.(2)  Indard: No Quantity: LF As-built : 4
Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Handrail Extension - Bottom  OSSC 1109.8.6.(2)  Indard: No Quantity: LF As-built: 4  Bottom handrail extension not min. 12" + tread width at stair bottom
Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Handrail Extension - Bottom  OSSC 1109.8.6.(2)  Indard: No Quantity: LF As-built: 4  Bottom handrail extension not min. 12" + tread width at stair bottom  Bottom handrail extension not min. 12" + tread width at stair bottom  Provide accessible handrails at both sides of stairway
Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Handrail Extension - Bottom  OSSC 1109.8.6.(2)  Indard: No Quantity: LF As-built: 4  Bottom handrail extension not min. 12" + tread width at stair bottom  Bottom handrail extension not min. 12" + tread width at stair bottom  Provide accessible handrails at both sides of stairway  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open




Field Date:	7/13/2011 Report Date 7/13/2011 Barrier #: 2245C
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477428.999 Y Coordinate: 340543.167
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Top
Code References:	OSSC 1109.8.6.(2)
Performance Sta	ndard: No Quantity: LF As-built : 2
Barrier Description:	Top Handrail extension not parallel to ground/floor surface
Findings:	Top handrail extension not parallel to ground surface
Rec. Solution:	Provide accessible handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	7/13/2011 Report Date 7/13/2011 Barrier #: 2245D
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477428.999 Y Coordinate: 340543.167
Barrier Area:	Stairways
Barrier Type:	Vertical Access - Directional Sign
Code References:	2010 ADAS 403.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No form of vertical access provided at stairway to reach entry door or upper floors
	No information on alternate accessible entrance to building
Findings:	No information on alternate accessible entrance to building
_	Provide directional sign leading to accessible entry
_	Provide directional sign leading to accessible entry
Rec. Solution:	Provide directional sign leading to accessible entry  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	7/14/2011 Report Date 7/14/2011 Barrier #: 2247A
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477441.078 Y Coordinate: 340472.861
Barrier Area:	Stairways
Barrier Type:	Contrasting Color - ADA
Code References:	2010 ADAS Advisory 504.4
Performance Sta	andard: Yes Quantity: LF or TR As-built: 25
Barrier Description:	No contrasting color on each tread of exterior stairway
Findings:	No contrasting color provided
Rec. Solution:	Consider providing contrasting color on each tread
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	7/14/2011 Report Date 7/14/2011 Barrier #: 2247B
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477441.078 Y Coordinate: 340472.861
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Bottom
Code References:	OSSC 1109.8.6.(2)
Performance Sta	andard: No Quantity: LF As-built : 4
Barrier Description:	Bottom handrail extension not min. 12" + tread width at stair bottom
Findings:	Bottom handrail extension not min. 12" + tread width at stair bottom
Rec. Solution:	Provide accessible handrails at both sides of stairway
	,
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Open
Barrier Severity: Implementation	



Field Date:	7/14/2011 Report Date 7/14/2011 Barrier #: 2248A
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477404.163 Y Coordinate: 340476.506
Barrier Area:	Stairways
Barrier Type:	Contrasting Color - ADA
Code References:	2010 ADAS Advisory 504.4
Performance Sta	ndard: Yes Quantity: LF or TR As-built: 35
Barrier Description:	No contrasting color on each tread of exterior stairway
Findings:	No contrasting color provided
Rec. Solution:	Consider providing contrasting color on each tread
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	7/14/2011 Report Date 7/14/2011 Barrier #: 2248B
Bldg Name:	Hovland Hall Reference Dwg: 1 of 4
Location:	Exterior - Hovland Hall
X Coordinate:	7477404.163 Y Coordinate: 340476.506
Barrier Area:	Stairways
Barrier Type:	Handrail - Both Sides
Code References:	OSSC 1109.8.6 and 2010 ADAS 505.10.2
Performance Sta	ndard: No Quantity: LF As-built : 14
Barrier Description:	Needed handrail not provided at both sides of stairway
Findings:	No handrail provided at both sides of stairway
Rec. Solution:	Provide accessible handrails at both sides of stairway
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	





Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Automatic Doors - Sign
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: JOB As-built : 2
Barrier Description:	ISA symbol at automatic door opening device not min. 4" x 4" in size
Findings:	Existing symbols 1-1/4" high not visible from a distance
Rec. Solution:	Recommended: Provide ISA symbols min. 4" x 4" in size
Barrier Severity:	1 Necessary Cost Est \$500.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes: Baseme	nt floor is the ground floor in this building
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Automatic Doors - Actuation Device Landing
Code References:	2010 ADAS 404.2.4.4
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Actuation control not located on a level landing
Findings:	3.3% slope
Rec. Solution:	Relocate actuation device
Barrier Severity:	1 Necessary Cost Est \$400.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Automatic Doors - Reopening
Code References:	2010 ADA 404.3.2
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Automatic doors do not reopen after encountering an obstruction
Findings:	Door not reopening
Rec. Solution:	Adjust door mechanism
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes: 7 second	d opening
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1D
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 1D Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Lobby L008
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Automatic Doors - BHMA Sign  ANSI/BHMA A156.10-1999
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Automatic Doors - BHMA Sign  ANSI/BHMA A156.10-1999
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Automatic Doors - BHMA Sign  ANSI/BHMA A156.10-1999  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Automatic Doors - BHMA Sign  ANSI/BHMA A156.10-1999  ndard: No Quantity: EACH As-built: 1  No sign on door visible from both sides reading, "AUTOMATIC DOOR"
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A  Doors or Gates  Automatic Doors - BHMA Sign  ANSI/BHMA A156.10-1999  ndard: No Quantity: EACH As-built: 1  No sign on door visible from both sides reading, "AUTOMATIC DOOR"  No sign provided
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Automatic Doors - BHMA Sign  ANSI/BHMA A156.10-1999  ndard: No Quantity: EACH As-built: 1  No sign on door visible from both sides reading, "AUTOMATIC DOOR"  No sign provided  Provide new sign on both sides of door  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 46-1/4" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
-	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1G
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 1G Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Lobby L008
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  ndard: No Quantity: EACH As-built: 1  Doormat not anchored to floor (possible tripping object)
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  Indard: No Quantity: EACH As-built: 1  Doormat not anchored to floor (possible tripping object)  Door mat not secured  Secure exiting doormat or replace
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Hovland Hall  Basement - Lobby L008  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  Indard: No Quantity: EACH As-built: 1  Doormat not anchored to floor (possible tripping object)  Door mat not secured  Secure exiting doormat or replace  1 Necessary Cost Est \$500.00 Facility Function: Public Status: Open
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Basement - Lobby L008  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  Indard: No Quantity: EACH As-built: 1  Doormat not anchored to floor (possible tripping object)  Door mat not secured  Secure exiting doormat or replace  1 Necessary Cost Est \$500.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Door
Code References:	2010 ADAS 216.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Ground floor doors that exit to exterior lacks tactile exit sign
Findings:	Exit door lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT" at exit side of door
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 11  Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Lobby L008
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Alarms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Alarms  Fire Pull - Accessible Route  2010 ADAS 308.2.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A Y Coordinate: N/A  Alarms  Fire Pull - Accessible Route  2010 ADAS 308.2.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A  Alarms  Fire Pull - Accessible Route  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A  Alarms  Fire Pull - Accessible Route  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Fire pull not on accessible route
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A  Alarms  Fire Pull - Accessible Route  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Fire pull not on accessible route  4.8% slope at clear floor space. Actuator within door swing  Replace fire pull when remodeling
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L008  N/A  Y Coordinate: N/A  Alarms  Fire Pull - Accessible Route  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Fire pull not on accessible route  4.8% slope at clear floor space. Actuator within door swing  Replace fire pull when remodeling  A Low Severity Cost Est \$3,500.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1J
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route at telecom closet
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1K
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
	Basement - Lobby L008  N/A  Y Coordinate: N/A
X Coordinate:	
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	N/A Y Coordinate: N/A Signage
X Coordinate: Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2
X Coordinate: Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	N/A Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route at room 008
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route at room 008  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1L
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Drinking Fountains
Barrier Type:	Alcove - Existing (pre-1992)
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Fountain with a leading edge between 27" and 80" high protrudes more than 4" into the circulation path.
Findings:	No alcove provided
Rec. Solution:	Provide wing walls as detectable warning (existing unit only)
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1M
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	
	Drinking Fountains
Barrier Type:	Drinking Fountains Hi-Low Unit
Barrier Type: Code References:	
Code	Hi-Low Unit 2010 ADAS 211.2 & 602.7
Code References:	Hi-Low Unit 2010 ADAS 211.2 & 602.7
Code References: Performance Sta Barrier	Hi-Low Unit 2010 ADAS 211.2 & 602.7  andard: No Quantity: EACH As-built: 1
Code References: Performance Sta Barrier Description:	Hi-Low Unit  2010 ADAS 211.2 & 602.7  andard: No Quantity: EACH As-built: 1  No hi-low drinking fountain provided in facility
Code References: Performance Sta Barrier Description: Findings:	Hi-Low Unit  2010 ADAS 211.2 & 602.7  andard: No Quantity: EACH As-built: 1  No hi-low drinking fountain provided in facility  No hi unit provided  Provide one hi fountain within facility
Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hi-Low Unit  2010 ADAS 211.2 & 602.7  andard: No Quantity: EACH As-built: 1  No hi-low drinking fountain provided in facility  No hi unit provided  Provide one hi fountain within facility  1 Necessary Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1N
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Drinking Fountains
Barrier Type:	Knee Clearance
Code References:	2010 ADAS 306.3
Performance Sta	ndard: No Quantity: EACH As-built : 0
Barrier Description:	Knee clearance under fountain not min. 27" high
Findings:	26" high knee clearance
Rec. Solution:	Replace drinking fountain with accessible unit or remount existing
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 10
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Sign - Lobby Info Sign
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	No lobby informational sign with location of accessible elements
Findings:	Accessible sign not provided
Rec. Solution:	Provide lobby informational sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 1P
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Strobe Installation Excessive
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: EACH As-built: 1
Barrier Description:	Excessive installation of strobes (50' distance) may cause seizures
Findings:	Strobes installed in multiple locations where they are not needed. 25 LF apart
Rec. Solution:	Recommended: remove excess strobe devices
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 2A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Description:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Description: Findings:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  AED cabinet protrudes 6" at 50-1/2" high  Remove protruding object or provide detectable warning (wing walls)
Description: Findings: Rec. Solution:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  AED cabinet protrudes 6" at 50-1/2" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 2B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	58" high AED operating point
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 2C
Field Date: Bldg Name:	6/24/2019 Report Date   9/13/2019 Barrier #:   2C   Hovland Hall   Reference Dwg:   2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Lobby L007
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A Y Coordinate: N/A  Clear Floor Space
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20  Floor surface slope exceeds 2.0%
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A  Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20  Floor surface slope exceeds 2.0%  2.5% slope at AED cabinet and fire extinguisher
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Lobby L007  N/A Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20  Floor surface slope exceeds 2.0%  2.5% slope at AED cabinet and fire extinguisher  Remodel to provide level clear floor space at controls/mechanisms  2 Necessary Cost Est \$11,500.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 2D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Fire Extinguisher - Protruding Object
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Fire extinguisher protrudes into circulation path more than 4" between 27" and 80"
Findings:	Fire extinguisher protrudes 4-1/2" at 28" high
Rec. Solution:	Remount extinguisher with leading edge below 27" or provide detectable warning
Barrier Severity:	4 Low Severity Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 2E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Lobby L007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	andard: No Quantity: SF As-built: 20
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	5.3% slope
Rec. Solution:	Remodel to provide accessible route
Barrier Severity:	4 Low Severity Cost Est \$11,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 3A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Unisex Toilet Room 007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Sign - Braille Location
Code References:	2010 ADAS 703.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Braille not 3/8" and max. 1/2" directly below the tactile characters
Findings:	1/3" below the tactile characters
Rec. Solution:	Replace signage
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 3B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Unisex Toilet Room 007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Landing - Level
Code References:	2010 ADAS 404.2.4.4
Performance Sta	andard: No Quantity: SF As-built: 40
Barrier Description:	Door landing is not level on both sides of door
Findings:	2.2% slope
Rec. Solution:	Demolish and reconstruct level landing
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 3C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Unisex Toilet Room 007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Stall Door Closer
Code References:	2010 ADAS 604.8.1.2
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Stall door not equipped with an automatic closing device
Findings:	Door not self-closing
Rec. Solution:	Replace compartment hinge with adjustable mechanism
Barrier Severity:	2 Recommended Cost Est \$1,650.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 3D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Unisex Toilet Room 007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Coat Hook
Code References:	2010 ADAS 603.4
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Clothing hooks not max. 48" high AFF
Findings:	72" high
Rec. Solution:	Provide additional hook in new location
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 3E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Unisex Toilet Room 007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	andard: No Quantity: SF As-built: 80
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	6.3% slope
Rec. Solution:	Remodel to provide level clear floor space at controls/mechanisms
Barrier Severity:	2 Necessary Cost Est \$46,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes: 80" x 72	at outward swinging door. 59" front transfer and 60" wide to make accessible
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 3F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Unisex Toilet Room 007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Dispensers - Protruding Object
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: EACH As-built : 2
Barrier Description:	Protruding dispenser creates protruding object in path of travel
Findings:	Soap and paper towel dispensers protrude 5" - 9" at 39" - 43-1/2" high
Rec. Solution:	Relocate dispensers or provide cane-detectable warnings
Rec. Solution: Barrier Severity:	
	2 Recommended Cost Est \$1,100.00 Facility Function: Public Status: Open



6/24/2019 Report Date 9/13/2019 Barrier #: 3G
0/11/11010
Hovland Hall Reference Dwg: 2 of 4
Basement - Unisex Toilet Room 007
N/A Y Coordinate: N/A
Restrooms
Toilet - Rear Grab Bar
2010 ADAS 604.5.2
andard: No Quantity: JOB As-built : 1
Rear grab bar not centered 12" from wall and 24" on the other side of WC
11-1/2" OC
Replace grab bars with reinforcement
3 Hindrance Cost Est \$450.00 Facility Function: Public Status: Open
Priority: 3 Implementation Phase: Implementation Date:
, , , , , , , , , , , , , , , , , , , ,
6/24/2019 Report Date 9/13/2019 Barrier #: 3H
6/24/2019 Report Date 9/13/2019 Barrier #: 3H
6/24/2019 Report Date 9/13/2019 Barrier #: 3H Hovland Hall Reference Dwg: 2 of 4
6/24/2019 Report Date 9/13/2019 Barrier #: 3H Hovland Hall Reference Dwg: 2 of 4 Basement - Unisex Toilet Room 007
6/24/2019 Report Date 9/13/2019 Barrier #: 3H  Hovland Hall Reference Dwg: 2 of 4  Basement - Unisex Toilet Room 007  N/A Y Coordinate: N/A
6/24/2019 Report Date 9/13/2019 Barrier #: 3H Hovland Hall Reference Dwg: 2 of 4  Basement - Unisex Toilet Room 007  N/A Y Coordinate: N/A  Restrooms
6/24/2019 Report Date 9/13/2019 Barrier #: 3H Hovland Hall Reference Dwg: 2 of 4  Basement - Unisex Toilet Room 007  N/A Y Coordinate: N/A  Restrooms  Toilet Paper Dispenser
6/24/2019 Report Date 9/13/2019 Barrier #: 3H Hovland Hall Reference Dwg: 2 of 4 Basement - Unisex Toilet Room 007 N/A Y Coordinate: N/A Restrooms Toilet Paper Dispenser 2010 ADAS 604.7
G/24/2019   Report Date   9/13/2019   Barrier #:   3H   Hovland Hall   Reference Dwg:   2 of 4   Basement - Unisex Toilet Room 007   N/A   Y Coordinate:   N/A   Restrooms   Toilet Paper Dispenser   2010 ADAS 604.7   As-built :   1
G/24/2019   Report Date   9/13/2019   Barrier #: 3H   Hovland Hall   Reference Dwg: 2 of 4   Basement - Unisex Toilet Room 007   N/A   Y Coordinate: N/A   Restrooms   Toilet Paper Dispenser   2010 ADAS 604.7   EACH   As-built : 1   Toilet tissue dispenser not within 7" to 9" from front edge of toilet
G/24/2019   Report Date   9/13/2019   Barrier #: 3H     Hovland Hall   Reference Dwg: 2 of 4     Basement - Unisex Toilet Room 007     N/A
G/24/2019   Report Date   9/13/2019   Barrier #: 3H     Hovland Hall   Reference Dwg: 2 of 4     Basement - Unisex Toilet Room 007     N/A



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 3I
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Unisex Toilet Room 007
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Seat Cover Dispenser
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: JOB As-built : 12
Barrier Description:	Seat cover dispenser not located on an accessible route.
Findings:	6.3% slope at seat cover dispenser
Rec. Solution:	Provide level clear floor space at controls/mechanisms
Barrier Severity:	2 Recommended Cost Est \$1,500.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes: Stairwa	y is not an enclosed stairway



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	14 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4C
	10/10/10/10
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	
	Hovland Hall Reference Dwg: 2 of 4
Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002
Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways
Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways  Door Closer - Interior Sweep ADA  2010 ADAS 404.2.8.1
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways  Door Closer - Interior Sweep ADA  2010 ADAS 404.2.8.1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways  Door Closer - Interior Sweep ADA  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways  Door Closer - Interior Sweep ADA  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Door Closer - Interior Sweep ADA  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period  3 second sweep
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways  Door Closer - Interior Sweep ADA  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period  3 second sweep  Replace or adjust door closer  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (≥ 5.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	ndard: No Quantity: SF As-built : 20
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	5.3% slope
Rec. Solution:	Remodel to provide accessible route
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4E
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 4E  Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  ndard: Yes Quantity: LF or TR As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 1  No contrasting color on each tread of interior stairway
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Mo contrasting color on each tread of interior stairway  Step at door lacks contrasting colors at nosing of tread  Recommended: Consider providing contrasting color on each tread
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 1  No contrasting color on each tread of interior stairway  Step at door lacks contrasting colors at nosing of tread  Recommended: Consider providing contrasting color on each tread  2 Recommended Cost Est \$35.00  Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible where thumb activation and simultaneous pulling are needed
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 63" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	
Implementation	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit with low level illuminated sign lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4I
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Height
Code References:	2010 ADAS 505.10.2
Performance Sta	ndard: No Quantity: LF As-built: 11
Barrier Description:	Handrail grip measured at center not 34"- 38" high
Findings:	32" handrail grip height
Rec. Solution:	Provide handrails at both sides of stairwav
Barrier Severity:	2 Recommended Cost Est \$2,475.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4J
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Bottom
Code References:	2010 ADAS 505.10.3
Performance Sta	andard: No Quantity: LF As-built : 0
Barrier Description:	Extension not sloped for length of one tread beyond the last riser nosing
Findings:	Extension not sloped for the length of one tread long. No level extensions
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4K
Field Date: Bldg Name:	6/24/2019         Report Date         9/13/2019         Barrier #:         4K           Hovland Hall         Reference Dwg:         2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2  No contrasting color on each tread of interior stairway
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2  No contrasting color on each tread of interior stairway  Treads lack contrasting color defined as 70% contrast  Recommended: Consider providing contrasting color on each tread
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2  No contrasting color on each tread of interior stairway  Treads lack contrasting color defined as 70% contrast  Recommended: Consider providing contrasting color on each tread  2 Recommended Cost Est \$70.00 Facility Function: Public Status: Open
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Stairways  Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2  No contrasting color on each tread of interior stairway  Treads lack contrasting color defined as 70% contrast  Recommended: Consider providing contrasting color on each tread  2 Recommended Cost Est \$70.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4L
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Vertical Access - Elevator
Code References:	2010 ADAS 403.1
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	No form of vertical access provided at stairway to reach upper floors
Findings:	No vertical access provided in building to upper floors
Rec. Solution:	Provide a passenger elevator or lift to reach upper floors
Barrier Severity:	1 Necessary Cost Est \$250,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 4M
i icia bate.	1972 1720 25 17 17 17 18 19720 25 17 17 17 17 17 17 17 17 17 17 17 17 17
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Alarms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall Reference Dwg: 2 of 4  Basement - Stairway S002  N/A Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  Indard: No Quantity: EACH As-built: 1  No horn/strobes in common use areas
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  Indard: No Quantity: EACH As-built: 1  No horn/strobes in common use areas  No device provided  Provide strobe in common use area
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Stairway S002  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  Indard: No Quantity: EACH As-built: 1  No horn/strobes in common use areas  No device provided  Provide strobe in common use area  1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 5A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H006
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Location - 48" to 60" high
Code References:	2010 ADAS 703.4.1
Performance Sta	andard: No Quantity: EACH As-built: 3
Barrier Description:	Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Findings:	61-3/4" high and braille 0.32" directly below the tactile characters at staff offices 10, 11, and 12
Rec. Solution:	Provide Braille/tactile signs at latch side of doors
Barrier Severity:	1 Necessary Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 5B
Field Date: Bldg Name:	6/24/2019   Report Date   9/13/2019   Barrier #:   5B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H006
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H006  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H006  N/A Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H006  N/A Y Coordinate: N/A  Corridors  Floor Surface - Slope  2010 ADAS 302 & 303
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H006  N/A Y Coordinate: N/A  Corridors  Floor Surface - Slope  2010 ADAS 302 & 303
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H006  N/A  Y Coordinate: N/A  Corridors  Floor Surface - Slope  2010 ADAS 302 & 303  andard: No Quantity: SF As-built: 136
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H006  N/A Y Coordinate: N/A  Corridors  Floor Surface - Slope  2010 ADAS 302 & 303  andard: No Quantity: SF As-built: 136  Floor surface slope exceeds 2.0%
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H006  N/A  Y Coordinate: N/A  Corridors  Floor Surface - Slope  2010 ADAS 302 & 303  andard: No Quantity: SF As-built: 136  Floor surface slope exceeds 2.0%  2.5% - 3.6% slope for 34 LF  Remodel to provide level clear floor space at controls/mechanisms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H006  N/A  Y Coordinate: N/A  Corridors  Floor Surface - Slope  2010 ADAS 302 & 303  andard: No Quantity: SF As-built: 136  Floor surface slope exceeds 2.0%  2.5% - 3.6% slope for 34 LF  Remodel to provide level clear floor space at controls/mechanisms  2 Necessary  Cost Est \$78,200.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 5C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H006
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Findings:	AED sign protrudes 5-1/2" at 66" high
Rec. Solution:	Remove protruding object or provide detectable warning (wing walls)
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 5D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H006
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Strobe Installation Excessive
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: EACH As-built : 1
Barrier Description:	Excessive installation of strobes (50' distance) may cause seizures
Findings:	Strobes installed in multiple locations where they are not needed. 24LF apart
Findings: Rec. Solution:	Strobes installed in multiple locations where they are not needed. 24LF apart  Recommended: remove excess strobe devices
_	Recommended: remove excess strobe devices
Rec. Solution:	Recommended: remove excess strobe devices  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Location - 48" to 60" high
Code References:	2010 ADAS 703.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Findings:	61-3/4" high and Braille 1/3" directly below the tactile characters
Rec. Solution:	Provide Braille/tactile sign at latch side of door
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	16 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Interior Sweep Period
Code References:	2010 ADAS 404.2.8.1
Performance Sta	ndard: No Quantity: EACH As-built : 0
Barrier Description:	Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Findings:	3 second sweep
Rec. Solution:	Replace or adjust door closer
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (2.1% to 3.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	ndard: No Quantity: SF As-built : 40
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	2.9% slope
Rec. Solution:	Demolish and reconstruct level landing
Barrier Severity:	4 Low Severity Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	
	Priority: 2 Implementation Phase: Implementation Date:



	6/24/2019 Report Date 9/13/2019 Barrier #: 6E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 44" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6F
	6/24/2019 Report Date 9/13/2019 Barrier #: 6F Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	
Field Date: Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  mdard: No Quantity: ADMINI As-built: 1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door  59" deep to counter  Rearrange furniture to provide access to door when exiting and maneuvering clearance in front
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Arts & Sciences Business Center 008  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door  59" deep to counter  Rearrange furniture to provide access to door when exiting and maneuvering clearance in front 1 Necessary  Cost Est \$0.00  Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: EACH As-built: 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Counter - Surface Height
Code References:	2010 ADAS 902.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No section at least 3 feet long between 28" and 34" provided at existing counter
•	
Findings:	45" high
·	
Findings:	45" high Provide min. 3 ft long section of counter at max. 34" high
Findings: Rec. Solution:	45" high  Provide min. 3 ft long section of counter at max. 34" high  3 Hindrance Cost Est \$875.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6I
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Passageway - Min. 36" (Stored Item)
Code References:	2010 ADAS 403.5.1
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Circulation route not min. 36" wide between elements
Findings:	30" wide circulation route
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6J
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Desk - Clear Floor Space
Code References:	2010 ADAS 902.3
Performance Sta	andard: No Quantity: EACH As-built : 0
Barrier Description:	Clear floor space 30" x 48" not provided at desk
Findings:	36" deep to partition at student assistant desk
Rec. Solution:	Rearrange furniture to provide wheelchair access at desk
	incurrange furniture to provide wheelerian access at acsic
Barrier Severity:	
Barrier Severity: Implementation	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6K
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Desk - Knee Clearance
Code References:	2010 ADAS 902.3
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	25" knee clearance at student assistant desk
Rec. Solution:	Provide min. one accessible desk or workstation
Barrier Severity:	3 Hindrance Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 6L
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Arts & Sciences Business Center 008
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	
	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No Quantity: EACH As-built: 1  No horn/strobe in staff areas
Barrier	
Barrier Description:	No horn/strobe in staff areas
Barrier Description: Findings:	No horn/strobe in staff areas  No device provided
Barrier Description: Findings: Rec. Solution:	No horn/strobe in staff areas  No device provided  Provide horn/strobe where programs. services and activities take place  3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 7A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Office Service 009
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	andard: No Quantity: SF As-built: 100
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	3.3% slope
Rec. Solution:	Remodel to provide level clear floor space at controls/mechanisms
Barrier Severity:	2 Necessary Cost Est \$57,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 7B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Office Service 009
X Coordinate:	
	N/A Y Coordinate: N/A
Barrier Area:	N/A
Barrier Area: Barrier Type:	
	Clear Floor Space
Barrier Type: Code	Clear Floor Space Protruding Object 2010 ADAS 307
Barrier Type: Code References:	Clear Floor Space Protruding Object 2010 ADAS 307
Barrier Type: Code References: Performance Sta Barrier	Clear Floor Space Protruding Object 2010 ADAS 307  andard: No Quantity: EACH As-built: 1
Barrier Type: Code References: Performance Sta Barrier Description:	Clear Floor Space Protruding Object  2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high
Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Clear Floor Space Protruding Object  2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high  Paper towel dispenser protrudes 9" at 52" high  Remove protruding object or provide detectable warning (wing walls)
Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Clear Floor Space Protruding Object  2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high  Paper towel dispenser protrudes 9" at 52" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 7C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Office Service 009
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	Paper towel dispenser 53" high
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 7D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Office Service 009
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Cabinet blocks paper towel dispenser clear floor space
Rec. Solution:	Move cabinet
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



	6/24/2019 Report Date 9/13/2019 Barrier #: 7E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Office Service 009
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	Microwave controls 49" high
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 7F
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 7F Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Office Service 009
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Office Service 009  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Office Service 009  N/A Y Coordinate: N/A  Counters and Tables
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Office Service 009  N/A Y Coordinate: N/A  Counters and Tables  Workstation - Knee Clearance  2010 ADAS 902
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Office Service 009  N/A Y Coordinate: N/A  Counters and Tables  Workstation - Knee Clearance  2010 ADAS 902
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Office Service 009  N/A Y Coordinate: N/A  Counters and Tables  Workstation - Knee Clearance  2010 ADAS 902  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Office Service 009  N/A Y Coordinate: N/A  Counters and Tables  Workstation - Knee Clearance  2010 ADAS 902  Indard: No Quantity: EACH As-built: 1  Knee clearance not min. 27" high, 19" deep or 30" wide
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Office Service 009  N/A  Y Coordinate: N/A  Counters and Tables  Workstation - Knee Clearance  2010 ADAS 902  ndard: No Quantity: EACH As-built: 1  Knee clearance not min. 27" high, 19" deep or 30" wide  25" high and 28" wide knee clearance  Provide min. 1 accessible workstation of each type or overall 5%
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Office Service 009  N/A Y Coordinate: N/A  Counters and Tables  Workstation - Knee Clearance  2010 ADAS 902  Indard: No Quantity: EACH As-built: 1  Knee clearance not min. 27" high, 19" deep or 30" wide  25" high and 28" wide knee clearance  Provide min. 1 accessible workstation of each type or overall 5%  1 Necessary Cost Est \$875.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Location - 48" to 60" high
Code References:	2010 ADAS 703.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Findings:	61-3/4" high and braille 0.32" directly below the tactile characters
Rec. Solution:	Provide Braille/tactile sign at latch side of door
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8B
Field Date: Bldg Name:	6/24/2019         Report Date         9/13/2019         Barrier #:         8B           Hovland Hall         Reference Dwg:         2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Conference Room 009A
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (2.1% to 3.0%)  2010 ADAS 404.2.4.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (2.1% to 3.0%)  2010 ADAS 404.2.4.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (2.1% to 3.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 40
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (2.1% to 3.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 40  Door or gate lacks landing on both sides of door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (2.1% to 3.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 40  Door or gate lacks landing on both sides of door  2.2% slope  Demolish and reconstruct level landing
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Conference Room 009A  N/A Y Coordinate: N/A  Doors or Gates  Landing - Existing (2.1% to 3.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 40  Door or gate lacks landing on both sides of door  2.2% slope  Demolish and reconstruct level landing  4 Low Severity Cost Est \$5,000.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 44" above the floor
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door 10" Bottom Surface - Kickplate
Code References:	2010 ADAS 404.2.10
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate lacks min. 10" smooth uninterrupted bottom surface
Findings:	Bottom of door not smooth and uninterrupted
Rec. Solution:	Provide smooth kick plate min. 10" high at push side of door
Barrier Severity:	1 Necessary Cost Est \$225.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Protruding Object
	J. Total Basilian
Code References:	2010 ADAS 307
	2010 ADAS 307
References:	2010 ADAS 307
References: Performance Sta Barrier	2010 ADAS 307  Indard: No Quantity: EACH As-built: 1
References: Performance Sta Barrier Description:	2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high
References: Performance Sta Barrier Description: Findings:	ndard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high  Monitor and shelf protrude 6" - 17" at 37" - 51" high  Remove protruding object or provide detectable warning (wing walls)
References: Performance Sta Barrier Description: Findings: Rec. Solution:	ndard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high  Monitor and shelf protrude 6" - 17" at 37" - 51" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Assembly Areas
Barrier Type:	Shared Assistive Listening System
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	No shared assistive listening system for room with min. 10 seats
Findings:	No system provided in conference room providing 23 seats
Rec. Solution:	Provide shared ALS system with signage
Barrier Severity:	2 Recommended Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Workstation - Surface Max. 34"
Code References:	2010 ADAS 902
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Workstation surface height exceeds 34" high
Findings:	No knee clearance at flipchart. Pedestal base blocks use by people using wheelchairs
Rec. Solution:	Provide min. 1 accessible workstation of each type or overall 5%
Barrier Severity:	3 Hindrance Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	· _ · · · · <u> </u>
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 8I
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Conference Room 009A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Shelves or Cabinets
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 3
Barrier Description:	Shelf or cabinet not mounted max. 48" above floor or ground
Findings:	Holders 50" - 71" high
Rec. Solution:	Provide additional shelf at accessible height or provide assistance
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9A
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 9A Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  Indard: No Quantity: EACH As-built: 1  No sign with raised characters and Braille at permanent room or space with visual sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  No sign with raised characters and Braille at permanent room or space with visual sign  No tactile info on sign with visual information  Provide sign at latch side of entry door, where possible
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  Indard: No Quantity: EACH As-built: 1  No sign with raised characters and Braille at permanent room or space with visual sign  No tactile info on sign with visual information  Provide sign at latch side of entry door, where possible  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	14 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9C
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 9C Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep  Replace or adjust door closer  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Vision Lights in Doors
Code References:	2010 ADAS 404.2.11
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Doors or gates with view panels or side lights adjacent to doors not max. 43" high
Findings:	View panels higher than 43" above the ground. 60" high
Rec. Solution:	Replace door or vision panel in door
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Door - Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Door knob not accessible
Rec. Solution:	Replace hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Relocate Door
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	2" strike edge clearance where door recessed 12"
Rec. Solution:	Install automatic door opening device at door leading to ramp
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall   Reference Dwg:  2 of 4     Basement - Corridor H002
_	
Location:	Basement - Corridor H002
Location: X Coordinate:	Basement - Corridor H002  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates
Location: X Coordinate: Barrier Area: Barrier Type: Code	Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Basement - Corridor H002  N/A  Y Coordinate:  N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard:  NO  Quantity:  SF  As-built:  1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Basement - Corridor H002  N/A  Y Coordinate:  N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard:  No  Quantity:  SF  As-built:  Door or gate lacks landing on both sides of door
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard: No Quantity: SF As-built: 1  Door or gate lacks landing on both sides of door  6.4% -26.0% slope. Door landing within ramp run  Install incline platform lift or other form of vertical access
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard: No Quantity: SF As-built: 1  Door or gate lacks landing on both sides of door  6.4% -26.0% slope. Door landing within ramp run  Install incline platform lift or other form of vertical access  1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Ramp
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built: 1
Barrier Description:	Door leading into an exit ramp lacks tactile exit sign
Findings:	Door to exit ramp with low level illuminated sign lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT RAMP DOWN (or UP)" at exit side of ramp
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9
Field Date: Bldg Name:	6/24/2019   Report Date   9/13/2019   Barrier #:   9
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Ramps
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Ramps  Ramp Landing - Existing (>5.0% or more)  2010 ADAS 405.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Ramps  Ramp Landing - Existing (>5.0% or more)  2010 ADAS 405.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Ramps  Ramp Landing - Existing (>5.0% or more)  2010 ADAS 405.7  ndard: No Quantity: LF As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Ramps  Ramp Landing - Existing (>5.0% or more)  2010 ADAS 405.7  ndard: No Quantity: LF As-built: 0  Landing is not level (>5.0% or more)
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Ramps  Ramp Landing - Existing (>5.0% or more)  2010 ADAS 405.7  ndard: No Quantity: LF As-built: 0  Landing is not level (>5.0% or more)  No top landing provided. 26.0% slope within ramp run  Install incline platform lift or other form of vertical access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Ramps  Ramp Landing - Existing (>5.0% or more)  2010 ADAS 405.7  ndard: No Quantity: LF As-built: 0  Landing is not level (>5.0% or more)  No top landing provided. 26.0% slope within ramp run  Install incline platform lift or other form of vertical access  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Ramps  Ramp Landing - Existing (>5.0% or more)  2010 ADAS 405.7  ndard: No Quantity: LF As-built: 0  Landing is not level (>5.0% or more)  No top landing provided. 26.0% slope within ramp run  Install incline platform lift or other form of vertical access  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9J
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Running Slope - Existing (>9.5% or more)
Code References:	2010 ADAS 405.3
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Running slope exceeds 8.33% (>9.5% or more)
Findings:	26.0% running slope
Rec. Solution:	Install incline platform lift or other form of vertical access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9K
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Handrail Height
Code References:	2010 ADAS 505.4
Performance Sta	ndard: No Quantity: LF As-built : 24
Barrier Description:	Handrails not 34"-38" high
Findings:	32-1/2" handrail height
Rec. Solution:	Replace handrails at both sides of ramp
Barrier Severity:	3 Hindrance Cost Est \$5,400.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9L
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Handrail Extension - Length
Code References:	2010 ADAS 505.10
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Handrail extension not min. 12" long
Findings:	No top and bottom extensions provided
Rec. Solution:	Replace handrail extension at both sides of ramp
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9M
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Protruding object in route of travel between 27" and 80" high
Findings:	Pipe protrudes at 77" high
Rec. Solution:	Remove protruding object or provide detectable warning
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9N
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Location - 48" to 60" high
Code References:	2010 ADAS 703.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Findings:	61-3/4" high and braille 0.32" directly below the tactile characters. Sign located within ramp run
Rec. Solution:	Provide Braille/tactile sign at latch side of door
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 90
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Location:	Basement - Corridor H002
Location: X Coordinate:	Basement - Corridor H002  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors
Location: X Coordinate: Barrier Area: Barrier Type: Code	Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  Indard: No Quantity: EACH As-built: 1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  Exit sign protrudes at 77" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  Exit sign protrudes at 77" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9P
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Findings:	AED sign protrudes 5-1/2" at 66" high
Rec. Solution:	Remove protruding object or provide detectable warning (wing walls)
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9Q
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 9Q Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Running Slope - Existing (5.0% - 8.2%)  2010 ADAS 403.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Running Slope - Existing (5.0% - 8.2%)  2010 ADAS 403.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Running Slope - Existing (5.0% - 8.2%)  2010 ADAS 403.3  Indard: No Quantity: LF As-built: 5
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Running Slope - Existing (5.0% - 8.2%)  2010 ADAS 403.3  Indard: No Quantity: LF As-built: 5  Walkway running slope exceeds 5.0% (5.0% - 5.5%) creating a ramp
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Running Slope - Existing (5.0% - 8.2%)  2010 ADAS 403.3  mdard: No Quantity: LF As-built: 5  Walkway running slope exceeds 5.0% (5.0% - 5.5%) creating a ramp  7.0% running slope for 5 LF  Provide new handrails at both sides of ramp with landings
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Running Slope - Existing (5.0% - 8.2%)  2010 ADAS 403.3  Indard: No Quantity: LF As-built: 5  Walkway running slope exceeds 5.0% (5.0% - 5.5%) creating a ramp  7.0% running slope for 5 LF  Provide new handrails at both sides of ramp with landings  1 Necessary Cost Est \$625.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 9R
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	andard: No Quantity: SF As-built : 60
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	2.2% - 2.3% cross slope for 10LF
Rec. Solution:	Remodel to provide level floor
Barrier Severity:	2 Necessary Cost Est \$34,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 10A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V006
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	andard: No Quantity: SF As-built : 48
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	2.2% - 2.4% slope for 8LF
Rec. Solution:	Remodel to provide level floor
Barrier Severity:	
•	2 Necessary Cost Est \$27,600.00 Facility Function: Public Status: Open
Implementation	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 10B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V006
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Sign - Permanent Room/Space
Code References:	2010 ADAS 703.1
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	No sign with raised characters and Braille at permanent room or space with visual sign
Findings:	No tactile info on signs with visual information at rooms 4 and 6
Rec. Solution:	Provide signs at latch side of entry doors, where possible
Barrier Severity:	1 Necessary Cost Est \$500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 10C
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 10C Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Vestibule V006
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  mdard: No Quantity: EACH As-built: 1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  61-3/4" high and braille 0.32" directly below the tactile characters at storage room 5  Provide Braille/tactile sign at latch side of door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V006  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  61-3/4" high and braille 0.32" directly below the tactile characters at storage room 5  Provide Braille/tactile sign at latch side of door  1 Necessary  Cost Est \$250.00  Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Location - 48" to 60" high
Code References:	2010 ADAS 703.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Findings:	61-3/4" high and braille 0.32" directly below the tactile characters
Rec. Solution:	Provide Braille/tactile sign at latch side of door
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Clear Width
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Clear width passage through door, sliding/folding door or gate is not min. 32"
Findings:	28" clear width
Rec. Solution:	Replace door or gate and frame
Barrier Severity:	1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	
•	Priority: 2 Implementation Phase: Implementation Date:



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Headroom - Existing
Code References:	2010 ADAS 404.2.3
Performance Sta	andard: No Quantity: EACH As-built : 0
Barrier Description:	Door/Gate clearance not min. 80" high
Findings:	78-1/2" high
Rec. Solution:	Replace door or gate
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Implementation	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hinge App/push 42"
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate with hinge approach with min. 22" beyond hinge at push side lacks min. 42" perpendicular to door
Findings:	37" perpendicular to door
Rec. Solution:	Install automatic door opening device to compensate for a lack of maneuvering clearance
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (3.1% to 4.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	andard: No Quantity: SF As-built: 20
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	3.1% slope
Rec. Solution:	Demolish and reconstruct level landing
Barrier Severity:	3 Hindrance Cost Est \$2,500.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Chairs blocks electrical switch and first aid kit clear floor space
Rec. Solution:	Move chair
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
Findings:	51" high
Rec. Solution:	Relocate switch box top edge to max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Stillidianice States Stores and States and States States States
Implementation	Priority: 2 Implementation Phase: Implementation Date:



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 111
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	First Aid Kit - Obstructed Reach Range
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Opening mechanism on first aid kit not at max. 44" over an obstruction of max. 25"
Findings:	63" high
Rec. Solution:	Relocate control or mechanism
Barrier Severity:	1 Necessary Cost Est \$275.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11J
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	ndard: No Quantity: SF As-built: 120
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	2.3% - 3.3% slope
Rec. Solution:	Remodel to provide level floor
Barrier Severity:	2 Necessary Cost Est \$69,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11K
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Kitchens
Barrier Type:	Sink - Clear Floor Space
Code References:	2010 ADAS 606.2
Performance Sta	ndard: No Quantity: EACH As-built: 0
Barrier Description:	Clear floor space of min. 30" by 48" not provided in front of a sink to allow forward approach
Findings:	3.3% slope at landing in front of sink and table reduces clear floor space to 32" at sink
Rec. Solution:	Remodel to provide level floor and move table
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11L
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
Location: X Coordinate:	Basement - Employee Break Room 003  N/A  Y Coordinate: N/A
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	N/A Y Coordinate: N/A Kitchens
X Coordinate: Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Kitchens  Sink - Knee Clearance  2010 ADAS 804.4 & 606.2
X Coordinate: Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Kitchens  Sink - Knee Clearance  2010 ADAS 804.4 & 606.2
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A Y Coordinate: N/A  Kitchens  Sink - Knee Clearance  2010 ADAS 804.4 & 606.2  Indard: No Quantity: EACH As-built: 1
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	N/A  Y Coordinate: N/A  Kitchens  Sink - Knee Clearance  2010 ADAS 804.4 & 606.2  Indard: No Quantity: EACH As-built: 1  Knee clearance not min. 27" high, 19" deep or 30" wide
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Kitchens  Sink - Knee Clearance  2010 ADAS 804.4 & 606.2  Indard: No Quantity: EACH As-built: 1  Knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance  Replace cabinet and remount sink if needed
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	N/A  Kitchens  Sink - Knee Clearance  2010 ADAS 804.4 & 606.2  Indard: No Quantity: EACH As-built: 1  Knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance  Replace cabinet and remount sink if needed  1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11M
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Kitchens
Barrier Type:	Sink - Rim
Code References:	2010 ADAS 606.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Sinks not mounted with the counter or rim no higher than 34" above the finish floor
Findings:	37-1/2" high
Rec. Solution:	Remount or replace sink
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11N
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	
Code	Protruding Object
References:	Protruding Object 2010 ADAS 307
	2010 ADAS 307
References:	2010 ADAS 307
References: Performance Sta Barrier	2010 ADAS 307  Indard: No Quantity: EACH As-built: 1
References: Performance Sta Barrier Description:	2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high
References: Performance Sta Barrier Description: Findings:	2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high  Paper towel dispenser protrudes 6" at 36" high  Remove protruding object or provide detectable warning (wing walls)
References: Performance Sta Barrier Description: Findings: Rec. Solution:	2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high  Paper towel dispenser protrudes 6" at 36" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in circulation path protrudes more than 4" between 27" and 80" high  Paper towel dispenser protrudes 6" at 36" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 110
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Kitchens
Barrier Type:	Shelving
Code References:	2010 ADAS 804.5 & 811
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	50% of shelving provided is not accessible
Findings:	Shelves not accessible
Rec. Solution:	Provide additional shelving at max. 48" above floor
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 11P
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Employee Break Room 003
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Common Use Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobes in common use areas
Findings:	No device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Door Closer - Interior Sweep Period
Code References:	2010 ADAS 404.2.8.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Findings:	4 second sweep
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance
Barrier Severity:	2 Recommended Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Door Landing - Existing (≥ 5.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	andard: No Quantity: SF As-built : 0
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	21.8% landing slope
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Door - Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Door knob not accessible
Rec. Solution:	Replace hardware
Barrier Severity:	
	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 45" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Headroom - Existing
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate clearance not min. 80" high
Findings:	79" high
Rec. Solution:	Replace door or gate
Barrier Severity:	3 Hindrance Cost Est \$1,750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Relocate Door
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: EACH As-built: 0
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	15" strike edge clearance at pull side
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	
	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12I
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Vestibule V001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Findings:	Exit sign protrudes at 77" high
Rec. Solution:	Remove protruding object or provide detectable warning (wing walls)
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 12J
Field Date: Bldg Name:	6/24/2019 Report Date 9/13/2019 Barrier #: 12J Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Vestibule V001
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 3  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A  Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  Indard: No Quantity: EACH As-built: 3  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  60" - 63" high. Also, braille 0.32" below tactile characters at staff offices 1A, 1B, and 1C
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Vestibule V001  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  Mard: No Quantity: EACH As-built: 3  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  60" - 63" high. Also, braille 0.32" below tactile characters at staff offices 1A, 1B, and 1C  Provide Braille/tactile signs at latch side of doors. where possible  1 Necessary Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13B
Field Date: Bldg Name:	6/24/2019   Report Date   9/13/2019   Barrier #:   13B   Hovland Hall   Reference Dwg:   2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard: No Quantity: SF As-built: 40
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 40  Door or gate lacks landing on both sides of door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 40  Door or gate lacks landing on both sides of door  21.6% running slope  Demolish and reconstruct level landing
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard: No Quantity: SF As-built: 40  Door or gate lacks landing on both sides of door  21.6% running slope  Demolish and reconstruct level landing  1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	C/24/2010 Percett Date 10/42/2010 Percian H. 142D
ricia Bate.	6/24/2019 Report Date 9/13/2019 Barrier #: 13D
Bldg Name:	Hovland Hall   Reference Dwg:   2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Headroom - Existing  2010 ADAS 404.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Headroom - Existing  2010 ADAS 404.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Doors or Gates  Headroom - Existing  2010 ADAS 404.2.3  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Headroom - Existing  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1  Door/Gate clearance not min. 80" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Headroom - Existing  2010 ADAS 404.2.3  ndard: No Quantity: EACH As-built: 1  Door/Gate clearance not min. 80" high  Replace door or gate
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Doors or Gates  Headroom - Existing  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1  Door/Gate clearance not min. 80" high  Replace door or gate  3 Hindrance Cost Est \$1,750.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route to vestibule
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Cross Slope - Existing (>5.0% or more)
Code References:	2010 ADAS 405.3
Performance Sta	ndard: No Quantity: LF As-built : 20
Barrier Description:	Cross slope exceeds 2.0% (>5.0% or more)
Findings:	11.1% cross slope to office 2A
Rec. Solution:	Demolish existing and construct new ramp
Barrier Severity:	1 Necessary Cost Est \$4,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Running Slope - Existing (>9.5% or more)
Code References:	2010 ADAS 405.3
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Running slope exceeds 8.33% (>9.5% or more)
Findings:	21.6% running slope
Rec. Solution:	Demolish existing and construct new ramp
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Ramp Landing - Top Landing
Code References:	2010 ADAS 405.7.3
Performance Sta	ndard: No Quantity: LF As-built : 5
Barrier Description:	Top landing is not min. 60" long
Findings:	No top landing provided
Rec. Solution:	Demolish existing and construct new ramp
Barrier Severity:	2 Recommended Cost Est \$1,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	·



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13I
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Handrail
Code References:	2010 ADAS 505.2
Performance Sta	ndard: No Quantity: LF As-built: 12
Barrier Description:	No handrail provided at both sides
Findings:	Ramp lacks handrail at both sides in two directions
Rec. Solution:	Replace handrails at both sides of ramp
Barrier Severity:	1 Necessary Cost Est \$2,700.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13J
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Ramp Surface - Extended
Code References:	2010 ADAS 405.9.1
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Sides of ramp not extended min. 12" to prevent wheels from slipping off ramp
Findings:	No min. 12" extension at sides of ramp at top and bottom
Rec. Solution:	Demolish existing and construct new ramp
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13K
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	First Aid Kit - High Reach Range
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Opening mechanism on first aid kit not at max. 48" high for side reach
Findings:	65-1/2" high
Rec. Solution:	Relocate control or mechanism to max. 48" high
Barrier Severity:	1 Necessary Cost Est \$275.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13L
	6/24/2019 Report Date 9/13/2019 Barrier #: 13L Hovland Hall Reference Dwg: 2 of 4
Bldg Name:	
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  mdard: No Quantity: EACH As-built: 3  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  Indard: No Quantity: EACH As-built: 3  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  61" - 61-3/4" high. Also, braille 0.32" below tactile characters at staff offices 2A, 2B, and 2C
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Corridors  Sign - Tactile Location 48" to 60" high  2010 ADAS 703.4.1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  61" - 61-3/4" high. Also, braille 0.32" below tactile characters at staff offices 2A, 2B, and 2C  Provide Braille/tactile signs at latch side of doors. where possible  1 Necessary  Cost Est \$750.00  Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13M
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Fire Alarm - Pull Actuator Height
Code References:	2010 ADAS 308.2.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Fire pulls not between 42" and 48" high
Findings:	50" high
Rec. Solution:	Replace fire pull when remodeling
Barrier Severity:	4 Low Severity Cost Est \$3,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13N
Field Date: Bldg Name:	6/24/2019   Report Date   9/13/2019   Barrier #:   13N   Hovland Hall   Reference Dwg:   2 of 4
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Corridor H002
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Door leading directly into an exit stairway lacks tactile exit sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Door leading directly into an exit stairway lacks tactile exit sign  Door to exit stair with low level illuminated sign lacks tactile exit sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Corridor H002  N/A Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Door leading directly into an exit stairway lacks tactile exit sign  Door to exit stair with low level illuminated sign lacks tactile exit sign  Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door  2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 130
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Doormat
Code References:	2010 ADAS 302.2 & Advisory 302.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Doormat not anchored to floor (possible tripping object)
Findings:	Door mat not secured
Rec. Solution:	Remount or replace lavatory
Barrier Severity:	1 Necessary Cost Est \$500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13P
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Automatic Doors - Reopening
Code References:	2010 ADA 404.3.2
Performance Sta	andard: No Quantity: JOB As-built: 1
Barrier Description:	Automatic doors do not reopen after encountering an obstruction
Description:	Automatic doors do not reopen after encountering an obstruction
Description: Findings:	Automatic doors do not reopen after encountering an obstruction  Door does not reopen  Adjust door mechanism
Description: Findings: Rec. Solution:	Automatic doors do not reopen after encountering an obstruction  Door does not reopen  Adjust door mechanism  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13Q
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Automatic Doors - BHMA Sign
Code References:	ANSI/BHMA A156.10-1999
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No sign on door visible from both sides reading, "AUTOMATIC DOOR"
Findings:	No signs provided
Rec. Solution:	Provide new signs on both sides of door
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13R
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Headroom - Existing
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate clearance not min. 80" high
Findings:	78-1/2" high
Rec. Solution:	Replace door or gate
Barrier Severity:	3 Hindrance Cost Est \$1,750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13S
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Threshold - Height exceeding 1/2"
Code References:	2010 ADAS 404.2.5
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Door/Gate threshold exceeds 1/2" in height
Findings:	5/8" high
Rec. Solution:	Provide new door threshold
Barrier Severity:	1 Necessary Cost Est \$275.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 13T
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Corridor H002
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Barrier Type: Code References:	
Code	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Code References:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Code References: Performance Sta Barrier	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1
Code References: Performance Sta Barrier Description: Findings:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Code References: Performance Sta Barrier Description: Findings:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign
Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Sign - No Tactile Characters
Code References:	2010 ADAS 703.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces
Findings:	No tactile characters at sign provided
Rec. Solution:	Replace sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Sign - Pictograms Raised
Code References:	2010 ADAS 703.2.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Pictogram not raised min. 1/32" from face of sign
Findings:	Pictogram not raised
Rec. Solution:	Replace signage
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	
	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	10 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
Location: X Coordinate:	Basement - Women's Restroom 014  N/A  Y Coordinate: N/A
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	N/A Y Coordinate: N/A  Restrooms
X Coordinate: Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Restrooms  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
X Coordinate: Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Restrooms  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	N/A  Restrooms  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	N/A  Restrooms  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Restrooms  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  andard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep  Replace or adjust door closer
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	N/A  Restrooms  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  Replace or adjust door closer  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14E
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Latch App/push 48"
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate with latch approach & closer at push side lacks min. 48" perpendicular to door
Findings:	37" deep to wall where corridor is 37" wide in low occupancy area
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14F
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (2.1% to 3.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	andard: No Quantity: SF As-built: 0
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	2.4% slope
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	
	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14G
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Hardware - Privacy Latch
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Privacy latch provided involves tight grasping, pinching or twisting
Findings:	Hardware not accessible
Rec. Solution:	Replace door latch
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14H
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Floor Drain - Existing
Code References:	2010 ADAS 304.2
Performance Sta	ndard: No Quantity: SF As-built: 120
Barrier Description:	Floor drain located within clear floor space of fixture
Findings:	2.5% - 3.9% slope
Rec. Solution:	Remodel drain inlet to have less than 1/2" lip
Barrier Severity:	3 Hindrance Cost Est \$30,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14I
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Rim Height
Code References:	2010 ADAS 606.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Lavatory rim or counter edge is higher than 34" AFF
Findings:	34-3/4" high
Rec. Solution:	Remount or replace lavatory
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14J
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Knee Clearance
Code References:	2010 ADAS 606.2 & 306
Performance Sta	ndard: No Quantity: JOB As-built : 0
Barrier Description:	Lavatory bottom apron/edge not at least 27" high
Findings:	No knee clearance
Rec. Solution:	Remount or replace lavatory
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14K
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Mirror
Code References:	2010 ADAS 603.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Mirror at lavatory/countertop not max. 40" AFF at edge of reflecting surface
Findings:	44" high
Rec. Solution:	Replace or remount mirror
Barrier Severity:	3 Hindrance Cost Est \$375.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14L
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Stall Entry - Front Approach - Push
Code References:	2010 ADAS 604.8.1.2 & Table 404.2.4.1
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Door with front approach corridor (push side) lacks min. 48" space perpendicular to door
Findings:	No 48" approach provided
Rec. Solution:	Replace compartments when altering toilet room to provide wheelchair access
Barrier Severity:	2 Recommended Cost Est \$1,650.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	, ,



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14M
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Stall Door Closer
Code References:	2010 ADAS 604.8.1.2
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Stall door not equipped with an automatic closing device
Findings:	Stall door not self-closing
Rec. Solution:	Replace compartment hinge with adjustable mechanism
Barrier Severity:	2 Recommended Cost Est \$1,650.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14N
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Stall Door Hardware
Code References:	2010 ADAS 604.8.1.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Stall door hardware involves tight grasping/pinching to close and no U-pull provided
Findings:	No inner U-pull provided
Rec. Solution:	Provide U-pull hardware on outside and inside of stall door
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 140
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Clear Width
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door clear width is not min. 32"
Findings:	Stall door clear width not accessible
Rec. Solution:	Replace door/gate and frame
Barrier Severity:	1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	Providence Providence Providence
i ieiu Date.	6/24/2019 Report Date 9/13/2019 Barrier #: 14P
Bldg Name:	14P     14P
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Women's Restroom 014
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1  Space in room not adequate to allow wheelchair user to enter and close door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1  Space in room not adequate to allow wheelchair user to enter and close door  No 48" clear space beyond door swing
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1  Space in room not adequate to allow wheelchair user to enter and close door  No 48" clear space beyond door swing  Change door swing  1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14Q
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet Transfer - Floor-mounted
Code References:	2010 ADAS 604.8.1.1
Performance Sta	ndard: No Quantity: SF As-built: 120
Barrier Description:	Min. 60" wide x 59" deep clear floor space not provided at floor-mounted fixture
Findings:	Water closet not accessible
Rec. Solution:	Remodel to provide front transfer space
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14R
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Grab Bars
Code References:	2010 ADAS 604.5
Mercrences.	2010 ADAS 004.5
Performance Sta	
Performance Sta Barrier	ndard: No Quantity: JOB As-built : 2
Performance Sta Barrier Description:	ndard: No Quantity: JOB As-built : 2  No grab bars provided at water closet
Performance Sta Barrier Description: Findings:	No Quantity: JOB As-built: 2  No grab bars provided at water closet  No grab bars provided  Provide side and rear grab bars with reinforcement
Performance Sta Barrier Description: Findings: Rec. Solution:	No grab bars provided at water closet  No grab bars provided  No grab bars provided  Provide side and rear grab bars with reinforcement  1 Necessary Cost Est \$1,800.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14S
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet Paper Dispenser
Code References:	2010 ADAS 604.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Toilet tissue dispenser not within 7" to 9" from front edge of toilet
Findings:	Toilet paper not accessible
Rec. Solution:	Reposition or replace toilet paper dispenser
Barrier Severity:	3 Hindrance Cost Est \$225.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14T
Field Date: Bldg Name:	6/24/2019         Report Date         9/13/2019         Barrier #:         14T           Hovland Hall         Reference Dwg:         2 of 4
	THE PARTY OF THE P
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 2 of 4  Basement - Women's Restroom 014
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Seat Cover Dispenser  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A  Y Coordinate: N/A  Restrooms  Seat Cover Dispenser  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A  Y Coordinate: N/A  Restrooms  Seat Cover Dispenser  2010 ADAS 307.2  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A Y Coordinate: N/A  Restrooms  Seat Cover Dispenser  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1  Seat cover dispenser not located on an accessible route. Blocked by water closet
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A  Y Coordinate: N/A  Restrooms  Seat Cover Dispenser  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1  Seat cover dispenser not located on an accessible route. Blocked by water closet  Access to dispenser blocked by water closet  Replace or remount dispenser on an accessible route with clear floor space
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 2 of 4  Basement - Women's Restroom 014  N/A  Y Coordinate: N/A  Restrooms  Seat Cover Dispenser  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1  Seat cover dispenser not located on an accessible route. Blocked by water closet  Access to dispenser blocked by water closet  Replace or remount dispenser on an accessible route with clear floor space  2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 14U
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Women's Restroom 014
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Strobe - No Horn
Code References:	2010 ADAS 702.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No horn provided with strobe
Findings:	No device provided
Rec. Solution:	Provide horn device with strobe device
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 15A
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Height
Code References:	2010 ADAS 505.10.2
Performance Sta	andard: No Quantity: LF As-built: 22
Barrier Description:	Handrail grip measured at center not 34"- 38" high
Findings:	33" handrail grip height
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$4,950.00 Facility Function: Public Status: Open
Implementation	
Notes:	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 15B
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Bottom
Code References:	2010 ADAS 505.10.3
Performance Sta	andard: No Quantity: LF As-built : 0
Barrier Description:	Extension not sloped for length of one tread beyond the last riser nosing
Findings:	Handrail extensions return to wall without sloped for one tread
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 15C
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Top
Code References:	2010 ADAS 505.10.2
Performance Sta	andard: No Quantity: LF As-built : 0
Barrier Description:	Extension does not extend horizontally above landing for min. 12" from first riser nosing
Findings:	Handrail extensions return to wall
Rec. Solution:	
	Provide handrails at both sides of stairway
Barrier Severity:	
Barrier Severity: Implementation	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/24/2019 Report Date 9/13/2019 Barrier #: 15D
Bldg Name:	Hovland Hall Reference Dwg: 2 of 4
Location:	Basement - Stairway S001
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Contrasting Color - ADA
Code References:	2010 ADAS Advisory 504.4
Performance Sta	andard: Yes Quantity: LF or TR As-built : 2
Barrier Description:	No contrasting color on each tread of interior stairway
Findings:	Treads lack contrasting color defined as 70% contrast
Rec. Solution:	Recommended: Consider providing contrasting color on each tread
Barrier Severity:	2 Recommended Cost Est \$70.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Ramp Landing - Top Landing
Code References:	2010 ADAS 405.7.3
Performance Sta	andard: No Quantity: LF As-built : 5
Barrier Description:	Top landing is not min. 60" long
Findings:	No top landing provided
Rec. Solution:	Demolish existing and construct new ramp
Barrier Severity:	2 Recommended Cost Est \$1,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Running Slope - Existing (>9.5% or more)
Code References:	2010 ADAS 405.3
Performance Sta	ndard: No Quantity: LF As-built: 5
Barrier Description:	Running slope exceeds 8.33% (>9.5% or more)
Findings:	10.7% running slope
Rec. Solution:	Demolish existing and construct new ramp
Barrier Severity:	1 Necessary Cost Est \$1,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	
A Coordinate.	N/A Y Coordinate: N/A
Barrier Area:	N/A Y Coordinate: N/A Ramps
Barrier Area:	Ramps
Barrier Area: Barrier Type: Code	Ramps Ramp Landing - Top Landing 2010 ADAS 405.7.3
Barrier Area: Barrier Type: Code References:	Ramps Ramp Landing - Top Landing 2010 ADAS 405.7.3
Barrier Area: Barrier Type: Code References: Performance Sta Barrier	Ramps Ramp Landing - Top Landing  2010 ADAS 405.7.3  ndard: No Quantity: LF As-built: 5
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Ramps Ramp Landing - Top Landing  2010 ADAS 405.7.3  Indard: No Quantity: LF As-built: 5  Bottom landing is not min. 60" long
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Ramp Landing - Top Landing  2010 ADAS 405.7.3  ndard: No Quantity: LF As-built: 5  Bottom landing is not min. 60" long  Bottom landing not min 60" long  Demolish existing and construct new ramp
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Ramp Landing - Top Landing  2010 ADAS 405.7.3  Indard: No Quantity: LF As-built: 5  Bottom landing is not min. 60" long  Bottom landing not min 60" long  Demolish existing and construct new ramp  2 Recommended Cost Est \$1,000.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Handrail
Code References:	2010 ADAS 505.2
Performance Sta	andard: No Quantity: LF As-built : 4
Barrier Description:	No handrail provided at both sides
Findings:	Ramp lacks handrail at both sides
Rec. Solution:	Replace handrails at both sides of ramp
Barrier Severity:	1 Necessary Cost Est \$900.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
-	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16E
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 16E  Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A  Ramps
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Ramps  Handrail Height  2010 ADAS 505.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A  Ramps  Handrail Height  2010 ADAS 505.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A  Ramps Handrail Height 2010 ADAS 505.4  Indard: No Quantity: LF As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101 N/A Y Coordinate: N/A Ramps Handrail Height 2010 ADAS 505.4  Indard: No Quantity: LF As-built: 0  Handrails not 34"-38" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101 N/A Y Coordinate: N/A Ramps Handrail Height 2010 ADAS 505.4  Indard: No Quantity: LF As-built: 0 Handrails not 34"-38" high  Handrails not accessible  Replace handrails at both sides of ramp
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Ramps  Handrail Height  2010 ADAS 505.4  Indard: No Quantity: LF As-built: 0  Handrails not 34"-38" high  Handrails not accessible  Replace handrails at both sides of ramp  3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Ramps
Barrier Type:	Handrail Extension - Length
Code References:	2010 ADAS 505.10
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Handrail extension not min. 12" long
Findings:	No top and bottom extensions
Rec. Solution:	Replace handrail extension at both sides of ramp
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16G
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 16G Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101 N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101 N/A Y Coordinate: N/A Signage Tactile Exit Signs - Passage Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign  Passageway to exterior exit lacks tactile exit sign at door to North Lobby
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign  Passageway to exterior exit lacks tactile exit sign at door to North Lobby  Provide sign stating "EXIT ROUTE" at exit side of door  2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (≥ 5.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	ndard: No Quantity: SF As-built: 20
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	10.7% slope at door to leading to North Lobby
Rec. Solution:	Demolish and reconstruct level landing
Barrier Severity:	1 Necessary Cost Est \$2,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16I
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible at door to North Lobby
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	
Notes:	Priority: 2 Implementation Phase: Implementation Date:



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16J
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 57" high at door to North Lobby
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16K
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Relocate Door
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: LF As-built : 10
Barrier	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Description:	Door/Gate at pull side with mill. 60 lacks mill. 16 strike edge clearance at pull side
Description: Findings:	8-1/2" strike edge clearance to wall. Handrails obstructs strike edge clearance at pull side at door to North Lobby
·	8-1/2" strike edge clearance to wall. Handrails obstructs strike edge clearance at pull side at
Findings:	8-1/2" strike edge clearance to wall. Handrails obstructs strike edge clearance at pull side at door to North Lobby  Alter corridor to provide an accessible route between the lobby and central corridor
Findings: Rec. Solution:	8-1/2" strike edge clearance to wall. Handrails obstructs strike edge clearance at pull side at door to North Lobby  Alter corridor to provide an accessible route between the lobby and central corridor  1 Necessary  Cost Est \$22,500.00  Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16L
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16M
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Walkways
Barrier Type:	Running Slope - Existing (8.3% or more)
Code References:	2010 ADAS 403.3
Performance Sta	andard: No Quantity: LF As-built : 0
Performance Sta Barrier Description:	Indard: No Quantity: LF As-built: 0  Walkway running slope exceeds 5.0% (8.3% or more)
Barrier	
Barrier Description:	Walkway running slope exceeds 5.0% (8.3% or more)
Barrier Description: Findings:	Walkway running slope exceeds 5.0% (8.3% or more)  14.8% running slope  Alter corridor to provide an accessible route between the lobby and central corridor
Barrier Description: Findings: Rec. Solution:	Walkway running slope exceeds 5.0% (8.3% or more)  14.8% running slope  Alter corridor to provide an accessible route between the lobby and central corridor  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	
	6/25/2019 Report Date 9/13/2019 Barrier #: 16N
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Passageway - Min. 36"
Code References:	2010 ADAS 403.5.1
Performance Sta	andard: No Quantity: LF As-built: 0
Barrier Description:	Circulation route through corridor not min. 36"
Findings:	34" wide to pipe
Rec. Solution:	Alter corridor to provide an accessible route between the lobby and central corridor
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 160
	6/25/2019 Report Date 9/13/2019 Barrier #: 160 Hovland Hall Reference Dwg: 3 of 4
Field Date:	
Field Date: Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Field Date: Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101
Field Date: Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A
Field Date: Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A  Doors or Gates
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9  andard: No Quantity: EACH As-built: 1
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9  andard: No Quantity: EACH As-built: 1  Door opening force exceeds 5 lbf
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101 N/A Y Coordinate: N/A  Doors or Gates Door Closer - Interior Adjustment 2010 ADAS 404.2.9  andard: No Quantity: EACH As-built: 1  Door opening force exceeds 5 lbf  10 lbf at door to corridor H103  Replace or adjust existing closer
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9  andard: No Quantity: EACH As-built: 1  Door opening force exceeds 5 lbf  10 lbf at door to corridor H103  Replace or adjust existing closer  1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16P
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible at door to corridor H103
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16Q
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 56-1/4" high at door to corridor H103
Rec. Solution:	
	Replace door/gate or vision panel
Barrier Severity:	
Barrier Severity: Implementation	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16R
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Relocate Door
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	12-1/2" strike edge clearance at pull side at door to corridor H103
Rec. Solution:	Install automatic door opening device to provide an accessible route between the lobby and ce
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16S
Field Date: Bldg Name:	6/25/2019   Report Date   9/13/2019   Barrier #:   16S   Hovland Hall   Reference Dwg:   3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard: No Quantity: SF As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  Indard: No Quantity: SF As-built: 0  Door or gate lacks landing on both sides of door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 0  Door or gate lacks landing on both sides of door  14.8% slope. Landing within ramp run at door to corridor H103  Alter corridor to provide an accessible route between the lobby and central corridor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Doors or Gates  Landing - Existing (≥ 5.0%)  2010 ADAS 404.2.4.4  ndard: No Quantity: SF As-built: 0  Door or gate lacks landing on both sides of door  14.8% slope. Landing within ramp run at door to corridor H103  Alter corridor to provide an accessible route between the lobby and central corridor  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



	6/25/2019 Report Date 9/13/2019 Barrier #: 16T
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit with low level illuminated sign lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 16U
	6/25/2019 Report Date 9/13/2019 Barrier #: 16U  Hovland Hall Reference Dwg: 3 of 4
Field Date: Bldg Name: Location:	
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Corridor H101
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Alarms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Corridor  2010 ADAS 702.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Corridor  2010 ADAS 702.1
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Corridor  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Alarms  Horn/Strobe - Corridor  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1  No horn/strobes in corridor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Alarms  Horn/Strobe - Corridor  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1  No horn/strobes in corridor  No device provided  Provide strobe in common use area
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H101  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Corridor  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1  No horn/strobes in corridor  No device provided  Provide strobe in common use area  1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route from exterior
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Exterior Adjustment
Code References:	Performance Standard
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 8.5 lbf
Findings:	14 lbf
Rec. Solution:	Replace or adjust existing closers
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	
ו וכוע שמנפ:	6/25/2019 Report Date 9/13/2019 Barrier #: 17D
Bldg Name:	6/25/2019   Report Date   9/13/2019   Barrier #:   17D   Hovland Hall   Reference Dwg:   3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Lobby L100
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Lobby L100 N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Clear Width  2010 ADAS 404.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Clear Width  2010 ADAS 404.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Clear Width  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Clear Width  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1  Clear width passage through door, sliding/folding door or gate is not min. 32"
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Clear Width  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1  Clear width passage through door, sliding/folding door or gate is not min. 32"  27" clear width  Replace doors or gates and frames or install automatic door opening device that opens both do
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Clear Width  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1  Clear width passage through door, sliding/folding door or gate is not min. 32"  27" clear width  Replace doors or gates and frames or install automatic door opening device that opens both do  1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door 10" Bottom Surface - Door Hardware
Code References:	2010 ADAS 404.2.10
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Door hardware interrupts min. 10" smooth bottom surface
Findings:	Door hardware extends into bottom 10" of door
Rec. Solution:	Remove element at bottom of doors at push side
Barrier Severity:	1 Necessary Cost Est \$150.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17F
Field Date: Bldg Name:	6/25/2019   Report Date   9/13/2019   Barrier #:   17F   Hovland Hall   Reference Dwg:   3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Lobby L100
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  Indard: No Quantity: EACH As-built: 5
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  ndard: No Quantity: EACH As-built: 5  Doormat not anchored to floor (possible tripping object)
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  mdard: No Quantity: EACH As-built: 5  Doormat not anchored to floor (possible tripping object)  Door mats not secured at exterior  Secure existing doormats or replace
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Doors or Gates  Doormat  2010 ADAS 302.2 & Advisory 302.2  Indard: No Quantity: EACH As-built: 5  Doormat not anchored to floor (possible tripping object)  Door mats not secured at exterior  Secure existing doormats or replace  1 Necessary Cost Est \$2,500.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Stairway
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built: 1
Barrier Description:	Door leading directly into an exit stairway lacks tactile exit sign
Findings:	Door to exit stair with low level illuminated sign lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Actuator/Control - Hi/low Reach
Code References:	2010 ADAS 308.2.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Use of control involves low reach of less than 15" above floor or more than 48" high
Findings:	Hand sanitizer 52" high
Rec. Solution:	Relocate to area at min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17I
Bldg Name:	Hoyland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
Findings:	55-1/2" high
Rec. Solution:	Relocate switch box top edge to max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17J
Field Date: Bldg Name:	Hoyland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Lobby L100
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A Y Coordinate: N/A  Alarms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Alarms  Fire Pull - Height  2010 ADAS 308.2.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Alarms  Fire Pull - Height  2010 ADAS 308.2.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Alarms  Fire Pull - Height  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Alarms  Fire Pull - Height  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Fire pulls not between 42" and 48" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Alarms  Fire Pull - Height  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Fire pulls not between 42" and 48" high  Go" high  Replace fire pull when remodeling
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Alarms  Fire Pull - Height  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Fire pulls not between 42" and 48" high  GO" high  Replace fire pull when remodeling  A Low Severity Cost Est \$3,500.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17K
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Fire Extinguisher - Protruding Object
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Fire extinguisher protrudes into circulation path more than 4" between 27" and 80"
Findings:	Fire extinguisher protrudes 4-1/2" at 31" high
Rec. Solution:	Remount extinguisher with leading edge below 27" or provide detectable warning
Barrier Severity:	4 Low Severity Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17L
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Lobby Info Sign
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	No lobby informational sign with location of accessible elements
Findings:	Accessible signs not provided
Rec. Solution:	Provide lobby informational signs
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	
	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17M
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Chairs block outlet clear floor space
Rec. Solution:	Move chairs
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	C/25/2010 Penert Pete 2/42/2010 Perrier #1 47N
	6/25/2019 Report Date 9/13/2019 Barrier #: 17N
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Lobby L100
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Controls and Mechanisms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Outlets - Hi/Low Reach  2010 ADAS 308.2.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Outlets - Hi/Low Reach  2010 ADAS 308.2.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Outlets - Hi/Low Reach  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Outlets - Hi/Low Reach  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Use of outlet involves low reach of less than 15" above floor or more than 48" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Outlets - Hi/Low Reach  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Use of outlet involves low reach of less than 15" above floor or more than 48" high  11-1/2" high  Relocate outlet to area at min. 15" or max. 48" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Lobby L100  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Outlets - Hi/Low Reach  2010 ADAS 308.2.2  Indard: No Quantity: EACH As-built: 1  Use of outlet involves low reach of less than 15" above floor or more than 48" high  11-1/2" high  Relocate outlet to area at min. 15" or max. 48" high  Relocate outlet to area at min. 15" or max. 48" high  3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 170
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Protruding object in circulation path protrudes more than 4" between 27" and 80" high
Findings:	AED sign protrudes 5-1/2" at 74" high
Rec. Solution:	Remove protruding object or provide detectable warning (wing walls)
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17P
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
Location: X Coordinate:	Floor 1 - Lobby L100  N/A  Y Coordinate: N/A
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	N/A Y Coordinate: N/A Signage
X Coordinate: Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2
X Coordinate: Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route at room 101
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route at room 101  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 17Q
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Lobby L100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn - No Strobe
Code References:	2010 ADAS 702
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Horn provided in location where no strobe is provided
Findings:	No strobe device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 18A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Stairway S101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail - Opening Limitations
Code References:	Performance Standard
Performance Sta	ndard: No Quantity: LF As-built : 23
Barrier Description:	Guard not min 42" high
Findings:	Guardrail 32" high
Rec. Solution:	Replace guardrail
Barrier Severity:	1 Necessary Cost Est \$5,175.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 18B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Stairway S101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail - Both Sides
Code References:	ADAAG 4.9.4* & 2010 ADAS 505.10.2
Performance Sta	ndard: No Quantity: LF As-built : 24
Barrier Description:	No handrail provided at both sides of stairway
Findings:	No handrail provided at left side along guardrail
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$5,400.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 18C
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 18C Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Stairway S101
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  ndard: No Quantity: LF As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  Indard: No Quantity: LF As-built: 0  Handrail grip measured at center not 34"- 38" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  mdard: No Quantity: LF As-built: 0  Handrail grip measured at center not 34"- 38" high  32" handrail grip height  Provide handrails at both sides of stairway
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  Indard: No Quantity: LF As-built: 0  Handrail grip measured at center not 34"- 38" high  32" handrail grip height  Provide handrails at both sides of stairway  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 18D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Stairway S101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Bottom
Code References:	2010 ADAS 505.10.3
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Extension not sloped for length of one tread beyond the last riser nosing
Findings:	Extension not sloped for the length of one tread long
Rec. Solution:	Provide handrails at outer side of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 18E
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 18E  Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Stairway S101
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Extension - Top  2010 ADAS 505.10.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Extension - Top  2010 ADAS 505.10.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Extension - Top  2010 ADAS 505.10.2  ndard: No Quantity: LF As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Extension - Top  2010 ADAS 505.10.2  ndard: No Quantity: LF As-built: 0  Extension does not extend horizontally above landing for min. 12" from first riser nosing
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Stairway S101 N/A Stairways Handrail Extension - Top 2010 ADAS 505.10.2  mdard: No Quantity: LF As-built: 0  Extension does not extend horizontally above landing for min. 12" from first riser nosing  Extension not provided
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway S101  N/A  Y Coordinate: N/A  Stairways  Handrail Extension - Top  2010 ADAS 505.10.2   mdard: No Quantity: LF As-built: 0  Extension does not extend horizontally above landing for min. 12" from first riser nosing  Extension not provided  Provide handrails at right side of stairway  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 18F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Stairway S101
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Contrasting Color - ADA
Code References:	2010 ADAS Advisory 504.4
Performance Sta	ndard: Yes Quantity: LF or TR As-built: 2
Barrier Description:	No contrasting color on each tread of interior stairway
Findings:	Treads lack contrasting color defined as 70% contrast
Rec. Solution:	Recommended: Consider providing contrasting color on each tread
Barrier Severity:	2 Recommended Cost Est \$70.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
DIAS INGILIC.	novialid Hall Reference Dwg.  3 01 4
Location:	Floor 1 - Classroom 100
_	
Location:	Floor 1 - Classroom 100
Location: X Coordinate:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Signage
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Signage  Location - Within 18" of Door  2010 ADAS 703.4.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 1 - Classroom 100  N/A  Y Coordinate:  N/A  Signage  Location - Within 18" of Door  2010 ADAS 703.4.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Signage  Location - Within 18" of Door  2010 ADAS 703.4.2  Indard: No Quantity: EACH As-built: 1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Signage  Location - Within 18" of Door  2010 ADAS 703.4.2  ndard: No  Quantity: EACH  As-built:  Approach to tactile characters on sign not centered at 18" minimum from door swing
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Classroom 100  N/A Y Coordinate: N/A  Signage  Location - Within 18" of Door  2010 ADAS 703.4.2  Indard: No Quantity: EACH As-built: 1  Approach to tactile characters on sign not centered at 18" minimum from door swing  Sign approach located within stairs and Braille 1/3" directly below the tactile characters  Replace sign and relocate, where possible
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Signage  Location - Within 18" of Door  2010 ADAS 703.4.2  Indard: No Quantity: EACH As-built: 1  Approach to tactile characters on sign not centered at 18" minimum from door swing  Sign approach located within stairs and Braille 1/3" directly below the tactile characters  Replace sign and relocate, where possible  1 Necessary Cost Est \$150.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (≥ 5.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	ndard: No Quantity: SF As-built : 20
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	18.8% slope
Rec. Solution:	Demolish and reconstruct level landing
Barrier Severity:	1 Necessary Cost Est \$2,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19C
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 19C Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Classroom 100
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Classroom 100 N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Location  2010 ADAS 404.2.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Location  2010 ADAS 404.2.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Location  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Location  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 1  Hardware not located between 34" and 48" above ground/floor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Location  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 1  Hardware not located between 34" and 48" above ground/floor  33" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Location  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 1  Hardware not located between 34" and 48" above ground/floor  33" high  Remount new hardware at max. 48" high  1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 55" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door 10" Bottom Surface - Kickplate
Code References:	2010 ADAS 404.2.10
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate lacks min. 10" smooth uninterrupted bottom surface
Findings:	Bottom of door not smooth and uninterrupted. 8" high
Rec. Solution:	Provide smooth kick plate min. 10" high at push side of door
Barrier Severity:	1 Necessary Cost Est \$225.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	Desk blocks strike edge clearance at pull side
Rec. Solution:	Rearrange desk to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Passageway - Min. 36" (Stored Item)
Code References:	2010 ADAS 404.2.9
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Passageway is not min. 36" wide
Findings:	Circulation route through classroom not min. 36"
Rec. Solution:	Rearrange desk to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	p.oo.



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Chairs block accessible route and clear floor space at pencil sharpener
Rec. Solution:	Rearrange desk to provide wheelchair access
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19I
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 19I Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Classroom 100
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  mdard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall  Pencil sharpener protrudes 4-1/2" at 55" high  Remove protruding object or provide detectable warning for the visually impaired
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  mdard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall  Pencil sharpener protrudes 4-1/2" at 55" high  Remove protruding object or provide detectable warning for the visually impaired  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19J
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	Pencil sharpener 59" high
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19K
Bldg Name:	Deference Duration Co. C.A.
blug Maille.	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
Location:	Floor 1 - Classroom 100
Location: X Coordinate:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 1 - Classroom 100  N/A Y Coordinate: N/A  Classrooms
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Classroom 100  N/A Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 1 - Classroom 100  N/A Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 1 - Classroom 100  N/A  Y Coordinate:  N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  Indard:  Yes  Quantity:  EACH  As-built:  1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  andard: Yes  Quantity: EACH  As-built:  Bottom edge of writing surface not max. 38" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  Indard: Yes Quantity: EACH As-built: 1  Bottom edge of writing surface not max. 38" high  Lower edge of writing surface 40-1/4" high from floor  Remount whiteboard/chalkboard or provide alternate for use by short people
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  Indard: Yes Quantity: EACH As-built: 1  Bottom edge of writing surface not max. 38" high  Lower edge of writing surface 40-1/4" high from floor  Remount whiteboard/chalkboard or provide alternate for use by short people  3 Hindrance Cost Est \$1,200.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19L
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Chairs block chalkboard clear floor space
Rec. Solution:	Move chairs
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19M
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Assembly Areas
Barrier Type:	Shared Assistive Listening System
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: EACH As-built : 1
Barrier Description:	No shared assistive listening system for room with min. 10 seats
Findings:	No system provided in classroom providing 30 seats
Rec. Solution:	Provide shared ALS system with signage
Barrier Severity:	2 Recommended Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	· _ · · · <u> </u>
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19N
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Desk - Ratio
Code References:	2010 ADAS 902
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	At least 1 desk or 5% of all desks not accessible
Findings:	30 total seating with 1 adjustable desk that may be made accessible
Rec. Solution:	Provide additional 1 accessible desk to satisfy the 5% ratio
Barrier Severity:	3 Hindrance Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 190
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Stored elements block accessible desk clear floor space
Rec. Solution:	Move stored items
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19P
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Desk - Integration
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Desk not integrated into assembly seating
Findings:	Desk identified as accessible is not integrated into typical seating
Rec. Solution:	Move desk to integrated setting
Barrier Severity:	2 Necessary Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19Q
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Desk - Knee Clearance
Code References:	2010 ADAS 902
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	28-1/2" wide knee clearance at instructor's desk where students give presentations
Rec. Solution:	Reposition desk to provide knee clearance
Barrier Severity:	1 Necessary Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19R
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	Telephone operating point 51" high
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19S
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Podium - Surface Height
Code References:	2010 ADAS 504.2
Performance Sta	·
	ndard: No Quantity: EACH As-built : 1
Barrier Description:	ndard: No Quantity: EACH As-built: 1  Surface height exceeds 34" high
Description: Findings:	Surface height exceeds 34" high
Description: Findings:	Surface height exceeds 34" high Portable podium on workstation not accessible
Description: Findings: Rec. Solution:	Portable podium on workstation not accessible  Provide min. 1 accessible podium  4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19T
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Podium - Knee Clearance
Code References:	2010 ADAS 504.2
Performance Sta	ndard: No Quantity: EACH As-built : 0
Barrier Description:	Podium knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	Portable podium on workstation not accessible
Rec. Solution:	Provide min. 1 accessible podium
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19U
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 19U  Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Classroom 100
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  ndard: No Quantity: EACH As-built: 2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  mdard: No Quantity: EACH As-built: 2  Wall mounted object protrudes more than 4" from wall
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  Mall mounted object protrudes more than 4" from wall  Monitor and camera protrude 7" at 54" high  Remove protruding objects or provide detectable warnings for the visually impaired. Workstati
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Classroom 100  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  Mall mounted object protrudes more than 4" from wall  Monitor and camera protrude 7" at 54" high  Remove protruding objects or provide detectable warnings for the visually impaired. Workstati  1 Necessary  Cost Est \$1,100.00  Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19V
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	Monitor controls 49-1/2" high
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19W
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Desk and chair blocks emergency phone and whiteboard clear floor space
Rec. Solution:	Relocate desk
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19X
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Protruding Object - Wall-mounted
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Wall mounted object protrudes more than 4" from wall
Findings:	Emergency phone protrudes 4-1/2" at 46" high
Rec. Solution:	Remove protruding object or provide detectable warning for the visually impaired
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19Y
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	N/A Y Coordinate: N/A Classrooms
	N/A Y Coordinate: N/A
Barrier Area:	N/A Y Coordinate: N/A  Classrooms
Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Classrooms  Actuator/Control - Side Reach High Unobstructed  2010 ADAS 305.3
Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Classrooms  Actuator/Control - Side Reach High Unobstructed  2010 ADAS 305.3
Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A Y Coordinate: N/A  Classrooms  Actuator/Control - Side Reach High Unobstructed  2010 ADAS 305.3  ndard: No Quantity: EACH As-built: 1
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	N/A  Classrooms  Actuator/Control - Side Reach High Unobstructed  2010 ADAS 305.3  ndard: No Quantity: EACH As-built: 1  Control or mechanism not at min. 15" or max. 48" high
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Classrooms Actuator/Control - Side Reach High Unobstructed 2010 ADAS 305.3  ndard: No Quantity: EACH As-built: 1  Control or mechanism not at min. 15" or max. 48" high  Emergency phone control 50" high  Relocate control or mechanism to min. 15" or max. 48" high
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Classrooms Actuator/Control - Side Reach High Unobstructed  2010 ADAS 305.3  ndard: No Quantity: EACH As-built: 1  Control or mechanism not at min. 15" or max. 48" high  Emergency phone control 50" high  Relocate control or mechanism to min. 15" or max. 48" high  3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 19Z
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Classroom 100
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Alarm - No Horn/Strobe
Code References:	2010 ADAS 702.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Where a fire alarm is installed, no horn/strobe provided
Findings:	No device provided
Rec. Solution:	Provide horn/strobe
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Sign - Braille at Border
Code References:	2010 ADAS 703.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Braille dots not at least 3/8" from raised borders and decorative elements
Findings:	Braille 1/3" below raised characters
Rec. Solution:	Replace signage
Barrier Severity:	Course terrors Surface
	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	10 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Closer - Interior Sweep Period
Code References:	2010 ADAS 404.2.8.1
Performance Sta	ndard: No Quantity: EACH As-built: 0
Barrier Description:	Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Findings:	3 second sweep
Rec. Solution:	Replace or adjust door closer
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Operating controls involve tight grasping, pinching or twisting
Findings:	Hardware not accessible
Rec. Solution:	Replace hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A
Location:	Floor 1 - Unisex Toilet Room 105A
Location: X Coordinate:	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door Hardware - Privacy Latch  2010 ADAS 404.2.7
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door Hardware - Privacy Latch  2010 ADAS 404.2.7
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate:  N/A  Restrooms  Door Hardware - Privacy Latch  2010 ADAS 404.2.7  Indard:  No  Quantity:  EACH  As-built:  1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door Hardware - Privacy Latch  2010 ADAS 404.2.7  andard: No  Quantity: EACH  As-built:  Privacy latch provided involves tight grasping, pinching or twisting
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door Hardware - Privacy Latch  2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 1  Privacy latch provided involves tight grasping, pinching or twisting  Privacy latch not fist operable  Replace door latch
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door Hardware - Privacy Latch  2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 1  Privacy latch provided involves tight grasping, pinching or twisting  Privacy latch not fist operable  Replace door latch  1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open



Field Date:	C/25/2010 Penert Date 10/42/2010 Perrier #1 205
Field Date:	6/25/2019 Report Date   9/13/2019 Barrier #:   20F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Clear Width
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door clear width is not min. 32"
Findings:	24-1/2" clear width
Rec. Solution:	Replace door/gate and frame
Barrier Severity:	1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20G
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 20G Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105A
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  ndard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  ndard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface  Bottom 10" not smooth and uninterrupted  Provide kick plate at push side of door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  ndard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface  Bottom 10" not smooth and uninterrupted  Provide kick plate at push side of door  1 Necessary Cost Est \$225.00 Facility Function: Public Status: Open
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  ndard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface  Bottom 10" not smooth and uninterrupted  Provide kick plate at push side of door  1 Necessary Cost Est \$225.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Clearance - Pull Side
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door lacks min. 18" strike edge clearance at pull side
Findings:	7" strike edge clearance due to lavatory and paper towel dispenser
Rec. Solution:	Relocate door or gate to provide maneuvering clearance or alter toilet room to provide wheelc
Barrier Severity:	1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
-	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 201
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 201 Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105A
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1  Space in room not adequate to allow wheelchair user to enter and close door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1  Space in room not adequate to allow wheelchair user to enter and close door  48" clear space not provided beyond door swing
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A  Restrooms  Single Accommodation - In-swinging Door  2010 ADAS 603.2.3  ndard: No Quantity: JOB As-built: 1  Space in room not adequate to allow wheelchair user to enter and close door  48" clear space not provided beyond door swing  Alter toilet room to provide wheelchair access  1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20J
Bldg Name:	Transmit II
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Rim Height
Code References:	2010 ADAS 606.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Lavatory rim or counter edge is higher than 34" AFF
Findings:	34-5/8" high
Rec. Solution:	Remount lavatory
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20K
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Toe Clearance
Code References:	2010 ADAS 606.2 & 306
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Lavatory lacks toe clearance min. 9" high extending to max 6" from wall
Findings:	No toe clearance due to piping and faucet
Rec. Solution:	Replace lavatory
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20L
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Drainpipes
Code References:	2010 ADAS 606.5
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Hot water and drainpipes accessible under lavatory not insulated or covered
Findings:	No insulation provided
Rec. Solution:	Insulate drainpipes and hot water pipes
Barrier Severity:	2 Recommended Cost Est \$220.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20M
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Mirror
Code References:	2010 ADAS 603.3
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Mirror at lavatory/countertop not max. 40" AFF at edge of reflecting surface
Findings:	52" high
Rec. Solution:	Replace or remount mirror
Barrier Severity:	3 Hindrance Cost Est \$375.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20N
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Dispensers - Height
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Dispenser control point or operating mechanism not max. 48" AFF
Findings:	Paper towel dispenser 54" high
Rec. Solution:	Remount no higher than 48" above floor
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 200
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	
Location.	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	Floor 1 - Unisex Toilet Room 105A  N/A  Y Coordinate: N/A
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	N/A Y Coordinate: N/A Restrooms
X Coordinate: Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1
X Coordinate: Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  Indard: No Quantity: SF As-built: 80
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  Indard: No Quantity: SF As-built: 80  No 60" turning circle provided in toilet facility (min. 27" high above floor)
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  andard: No Quantity: SF As-built: 80  No 60" turning circle provided in toilet facility (min. 27" high above floor)  59" deep x 71" wide  Remodel toilet room to provide wheelchair access
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  Indard: No Quantity: SF As-built: 80  No 60" turning circle provided in toilet facility (min. 27" high above floor)  59" deep x 71" wide  Remodel toilet room to provide wheelchair access  2 Recommended Cost Est \$46,000.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20P
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Clear Space (pre-ADA)
Code References:	2010 ADAS 604.3.1 & 604.8.1.1
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Water closet clear space not min. 60" measured wall-to-wall
Findings:	42-1/2" from lavatory to water closet side wall
Rec. Solution:	No remediation recommended
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Closed
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20Q
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Grab Bars
Code References:	2010 ADAS 604.5
Performance Sta	ndard: No Quantity: JOB As-built : 2
Barrier Description:	No grab bars provided at water closet
Findings:	No grab bars provided
Rec. Solution:	Provide side and rear grab bars with reinforcement
Barrier Severity:	1 Necessary Cost Est \$1,800.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20R
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Flush Handle
Code References:	2010 ADAS 604.6
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Handle does not point to wide side of stall or compartment
Findings:	Handle pointing towards small side of stall/room
Rec. Solution:	Replace water closet
Barrier Severity:	1 Necessary Cost Est \$850.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20S
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet Paper Dispenser
Code References:	2010 ADAS 604.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Toilet tissue dispenser not within 7" to 9" from front edge of toilet
Findings:	Not 7" to 9" from front edge of toilet
Rec. Solution:	Reposition or replace toilet paper dispenser
Barrier Severity:	3 Hindrance Cost Est \$225.00 Facility Function: Public Status: Open
Implementation	
	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20T
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Seat Cover Dispenser
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Seat cover dispenser not located on an accessible route. Blocked by water closet
Findings:	Access to dispenser blocked by water closet
Rec. Solution:	Replace or remount dispenser on an accessible route with clear floor space
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 20U
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Common Use Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobes in common use areas
Findings:	No device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	
barrier severity.	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 21A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Findings:	AED sign protrudes 5-1/2" at 72" high
Rec. Solution:	Remove protruding object or provide detectable warning (wing walls)
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 21B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	ndard: No Quantity: SF As-built: 10
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	5.9% slope
Rec. Solution:	Remodel to provide level clear floor space at controls/mechanisms
Barrier Severity:	2 Necessary Cost Est \$5,750.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 21C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors Page 100 Corridors
Barrier Type:	Sign - Viewing From Distance >70" high
Code References:	2010 ADAS 703.5.5 & Table 703.5.5
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Signs between 70" and 120" high lack characters at least 2" high
Findings:	Characters on overhanging signs 3/4" high at 84" - 89" high
Rec. Solution:	Replace sign with characters min. 2" in height for viewing at a distance
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 21D
Field Date: Bldg Name:	6/25/2019         Report Date         9/13/2019         Barrier #:         21D           Hovland Hall         Reference Dwg:         3 of 4
	Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Corridor H103
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Corridors  Sign - Viewing From Distance >70" high  2010 ADAS 703.5.5 & Table 703.5.5
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Corridors  Sign - Viewing From Distance >70" high  2010 ADAS 703.5.5 & Table 703.5.5
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Corridors  Sign - Viewing From Distance >70" high  2010 ADAS 703.5.5 & Table 703.5.5  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Corridors  Sign - Viewing From Distance >70" high  2010 ADAS 703.5.5 & Table 703.5.5  Indard: No Quantity: EACH As-built: 1  Signs between 70" and 120" high lack characters at least 2" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Corridors  Sign - Viewing From Distance >70" high  2010 ADAS 703.5.5 & Table 703.5.5  Indard: No Quantity: EACH As-built: 1  Signs between 70" and 120" high lack characters at least 2" high  Characters on overhanging signs 1" high at 84" - 89" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Corridor H103  N/A  Y Coordinate: N/A  Corridors  Sign - Viewing From Distance >70" high  2010 ADAS 703.5.5 & Table 703.5.5  Indard: No Quantity: EACH As-built: 1  Signs between 70" and 120" high lack characters at least 2" high  Characters on overhanging signs 1" high at 84" - 89" high  Replace sign with characters min. 2" in height for viewing at a distance  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 21E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Corridor H103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Strobe
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No strobe provided in corridor where horn is provided where fire alarm exists in building
Findings:	No strobe where horn is provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 22A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Vestibule V103
X Coordinate:	
Darriar Araa.	N/A Y Coordinate: N/A
Barrier Area:	N/A Y Coordinate: N/A Signage
Barrier Type:	
	Signage
Barrier Type: Code	Signage  Location - 48" to 60" high  2010 ADAS 703.4.1
Barrier Type: Code References:	Signage  Location - 48" to 60" high  2010 ADAS 703.4.1
Barrier Type: Code References: Performance Sta Barrier	Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 1
Barrier Type: Code References: Performance Sta Barrier Description:	Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  65" high and Braille 1/3" below the tactile characters
Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  mdard: No Quantity: EACH As-built: 1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  65" high and Braille 1/3" below the tactile characters  Provide Braille/tactile sign at latch side of door  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 22B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Vestibule V103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Abrupt Change in Level
Code References:	2010 ADAS 303.3
Performance Sta	andard: No Quantity: SF As-built: 10
Barrier Description:	Change in level greater than 1/2" in clear floor space
Findings:	3-1/2" change in level in clear floor space
Rec. Solution:	Repair tripping object. Remodel where needed
Barrier Severity:	1 Necessary Cost Est \$5,750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 22C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Vestibule V103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Contrasting Color - ADA
Code References:	2010 ADAS Advisory 504.4
Performance Sta	andard: Yes Quantity: LF or TR As-built: 1
Barrier Description:	No contrasting color on each tread of interior stairway
Findings:	Treads lack contrasting color defined as 70% contrast
Rec. Solution:	Recommended: Consider providing contrasting color on each tread
Barrier Severity:	2 Recommended Cost Est \$35.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 22D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Vestibule V103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Vertical Access - Lift
Code References:	2010 ADAS 403.1
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	No form of vertical access provided at stairway to reach upper floors
Findings:	No vertical access provided to restroom
Rec. Solution:	Provide a wheelchair lift to reach upper floors or provide accessible restroom in an accessible lo
Barrier Severity:	1 Necessary Cost Est \$16,500.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 22E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Vestibule V103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Clear Width
Code References:	2010 ADAS 404.2.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Clear width passage through door, sliding/folding door or gate is not min. 32"
Findings:	31" wide
Rec. Solution:	Replace door or gate and frame
Barrier Severity:	1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes: Door re	moved



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 22F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Vestibule V103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit with low level illuminated sign lacks tactile exit sign to corridor
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
-	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23A
	6/25/2019 Report Date 9/13/2019 Barrier #: 23A Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Signage  Braille - Distance from Characters  2010 ADAS 703.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Signage  Braille - Distance from Characters  2010 ADAS 703.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Signage  Braille - Distance from Characters  2010 ADAS 703.3  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Signage  Braille - Distance from Characters  2010 ADAS 703.3  ndard: No Quantity: EACH As-built: 1  Braille not 3/8" and max. 1/2" directly below the tactile characters
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Signage  Braille - Distance from Characters  2010 ADAS 703.3  ndard: No Quantity: EACH As-built: 1  Braille not 3/8" and max. 1/2" directly below the tactile characters  Braille 1/3" directly below raised characters and recycling bin blocks approach to tactile sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Signage  Braille - Distance from Characters  2010 ADAS 703.3  ndard: No Quantity: EACH As-built: 1  Braille not 3/8" and max. 1/2" directly below the tactile characters  Braille 1/3" directly below raised characters and recycling bin blocks approach to tactile sign  Provide accessible sign and move recycling bin  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Stall Door Closer
Code References:	2010 ADAS 604.8.1.2
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Stall door not equipped with an automatic closing device
Findings:	Door not self closing
Rec. Solution:	Replace compartment hinge with adjustable mechanism
Barrier Severity:	2 Recommended Cost Est \$1,650.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23C
Field Date: Bldg Name:	6/25/2019   Report Date   9/13/2019   Barrier #:   23C   Hovland Hall   Reference Dwg:   3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clear Width  2010 ADAS 404.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clear Width  2010 ADAS 404.2.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clear Width  2010 ADAS 404.2.3  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clear Width  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1  Door clear width is not min. 32"
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clear Width  2010 ADAS 404.2.3  ndard: No Quantity: EACH As-built: 1  Door clear width is not min. 32"  29-1/2" clear width  Replace door/gate and frame
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clear Width  2010 ADAS 404.2.3  Indard: No Quantity: EACH As-built: 1  Door clear width is not min. 32"  29-1/2" clear width  Replace door/gate and frame  I Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Headroom
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 0
Barrier Description:	Door clearance not min. 80" high
Findings:	79-3/8" high
Rec. Solution:	Replace door and frame
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	
	Floor 1 - Unisex Toilet Room 105
X Coordinate:	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A
X Coordinate: Barrier Area:	
	N/A Y Coordinate: N/A
Barrier Area:	N/A Y Coordinate: N/A Restrooms
Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10
Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10
Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  Indard: No Quantity: EACH As-built: 1
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	N/A Y Coordinate: N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  andard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  ndard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface  Bottom 10" not smooth and uninterrupted  Provide kick plate at push side of door
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Restrooms  Door 10" Bottom Surface  2010 ADAS 404.2.10  Indard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface  Bottom 10" not smooth and uninterrupted  Provide kick plate at push side of door  1 Necessary Cost Est \$225.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Clearance - 60"
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door lacks min. 60" perpendicular to door swing
Findings:	Lavatory reduces door maneuvering clearance to 44" deep
Rec. Solution:	Relocate door or gate to provide maneuvering clearance
Barrier Severity:	1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23G
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 23G  Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clearance - Pull Side  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clearance - Pull Side  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clearance - Pull Side  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clearance - Pull Side  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: EACH As-built: 1  Door lacks min. 18" strike edge clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clearance - Pull Side  2010 ADAS Figure 404.2.4.1  Door lacks min. 18" strike edge clearance at pull side  7-1/2" strike edge clearance to paper towel dispenser. Trash bin blocks strike edge clearance  Install automatic door opening device to compensate for lack of maneuvering clearance and re
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Door Clearance - Pull Side  2010 ADAS Figure 404.2.4.1  Door lacks min. 18" strike edge clearance at pull side  7-1/2" strike edge clearance to paper towel dispenser. Trash bin blocks strike edge clearance  Install automatic door opening device to compensate for lack of maneuvering clearance and re  1 Necessary  Cost Est \$5,000.00  Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Single Accommodation - In-swinging Door
Code References:	2010 ADAS 603.2.3
Performance Sta	ndard: No Quantity: SF As-built : 80
Barrier Description:	Space in room not adequate to allow wheelchair user to enter and close door
Findings:	48" clear space not provided outside of door swing
Rec. Solution:	Remodel toilet room to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$46,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23I
Field Date: Bldg Name:	6/25/2019 Report Date   9/13/2019   Barrier #:   23    Hovland Hall   Reference Dwg:   3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  Indard: No Quantity: SF As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  Indard: No Quantity: SF As-built: 0  No 60" turning circle provided in toilet facility (min. 27" high above floor)
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  ndard: No Quantity: SF As-built: 0  No 60" turning circle provided in toilet facility (min. 27" high above floor)  36" wide from lavatory to wall and 58" from wall-to-wall  Remodel toilet room to provide wheelchair access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Maneuvering Clearance  2010 ADAS 603.2.1  Indard: No Quantity: SF As-built: 0  No 60" turning circle provided in toilet facility (min. 27" high above floor)  36" wide from lavatory to wall and 58" from wall-to-wall  Remodel toilet room to provide wheelchair access  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23J
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Dispensers - Protruding Object
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Protruding dispenser creates protruding object in path of travel
Findings:	Sanitary and paper towel dispensers protrude 5-5/8" - 9" at 45" - 48" high
Rec. Solution:	Relocate dispensers or provide cane-detectable warnings
Barrier Severity:	2 Recommended Cost Est \$1,100.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23K
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	
-	Hovland Hall Reference Dwg: 3 of 4
Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105
Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Height  2010 ADAS 307.2
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code  References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Height  2010 ADAS 307.2
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code  References:  Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Height  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code  References:  Performance Sta  Barrier  Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Height  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1  Dispenser control point or operating mechanism not max. 48" AFF
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Height  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1  Dispenser control point or operating mechanism not max. 48" AFF  Paper towel dispenser 50" high  Remount no higher than 48" above floor
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Height  2010 ADAS 307.2  Indard: No Quantity: EACH As-built: 1  Dispenser control point or operating mechanism not max. 48" AFF  Paper towel dispenser 50" high  Remount no higher than 48" above floor  2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23L
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Dispensers - Sanitary Products
Code References:	2010 ADAS 603.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Sanitary product dispenser not usable with a closed fist
Findings:	Dispenser not fist operable
Rec. Solution:	Replace sanitary napkin dispenser
Barrier Severity:	1 Necessary Cost Est \$650.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23M
Field Date: Bldg Name:	6/25/2019   Report Date   9/13/2019   Barrier #:   23M   Hovland Hall   Reference Dwg:   3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Sanitary Products  2010 ADAS 603.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Sanitary Products  2010 ADAS 603.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Sanitary Products  2010 ADAS 603.3  andard: No Quantity: EACH As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Sanitary Products  2010 ADAS 603.3  andard: No Quantity: EACH As-built: 0  Sanitary product dispenser coin slot or control not max. 48" AFF
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Sanitary Products  2010 ADAS 603.3  andard: No Quantity: EACH As-built: 0  Sanitary product dispenser coin slot or control not max. 48" AFF  50-1/2" - 54" high  Remount no higher than 48" above floor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Dispensers - Sanitary Products  2010 ADAS 603.3  andard: No Quantity: EACH As-built: 0  Sanitary product dispenser coin slot or control not max. 48" AFF  50-1/2" - 54" high  Remount no higher than 48" above floor  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23N
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Dispensers - Protruding Object
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Protruding dispenser creates protruding object in path of travel
Findings:	Soap dispenser protrudes 5" at 46-1/2" high
Rec. Solution:	Relocate dispenser or provide cane-detectable warning
Barrier Severity:	2 Recommended Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 230
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Clear Floor Space
Code References:	2010 ADAS 606.2
Performance Sta	indard: No Quantity: JOB As-built : 1
Barrier Description:	No clear floor space 30" x 48" at lavatory to allow forward approach
Findings:	
i iliuliigs.	Clear floor space not accessible
Rec. Solution:	Relocate or replace lavatory
_	Relocate or replace lavatory
Rec. Solution:	Relocate or replace lavatory  1 Necessary Cost Est \$375.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23P
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Rim Height
Code References:	2010 ADAS 606.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Lavatory rim or counter edge is higher than 34" AFF
Findings:	34-1/4" high
Rec. Solution:	Remount lavatory
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23Q
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Knee Clearance
Code References:	2010 ADAS 606.2 & 306
Performance Sta	ndard: No Quantity: JOB As-built : 0
Barrier Description:	Lavatory bottom apron/edge not at least 27" high
Findings:	No knee clearance
Rec. Solution:	Remount or replace lavatory
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23R
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Mirror
Code References:	2010 ADAS 603.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Mirror at lavatory/countertop not max. 40" AFF at edge of reflecting surface
Findings:	47" high
Rec. Solution:	Replace or remount mirror
Barrier Severity:	3 Hindrance Cost Est \$375.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23S
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Unisex Toilet Room 105
•	
Location:	Floor 1 - Unisex Toilet Room 105
Location: X Coordinate:	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 1 - Unisex Toilet Room 105  N/A Y Coordinate: N/A  Restrooms
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (pre-ADA)  2010 ADAS 604.8.1.1
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (pre-ADA)  2010 ADAS 604.8.1.1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (pre-ADA)  2010 ADAS 604.8.1.1  andard: No Quantity: SF As-built: 60
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (pre-ADA)  2010 ADAS 604.8.1.1  andard: No Quantity: SF As-built: 60  Min. 60" wide x 59" deep clear floor space not provided at floor-mounted fixture
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (pre-ADA)  2010 ADAS 604.8.1.1  andard: No Quantity: SF As-built: 60  Min. 60" wide x 59" deep clear floor space not provided at floor-mounted fixture  58" deep and 43-1/2" wide from wall to lavatory  No remediation recommended
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Unisex Toilet Room 105  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (pre-ADA)  2010 ADAS 604.8.1.1  Min. 60" wide x 59" deep clear floor space not provided at floor-mounted fixture  58" deep and 43-1/2" wide from wall to lavatory  No remediation recommended  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Closed



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23T
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Rear Grab Bar
Code References:	2010 ADAS 604.5
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Rear grab bar not provided at rear wall behind water closet
Findings:	No rear grab bar provided
Rec. Solution:	Replace grab bars with reinforcement
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23U
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Side Grab Bar
Code References:	2010 ADAS 604.5.1
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Side grab bar does not extend min. 54" from rear wall
Findings:	42" from rear wall
Rec. Solution:	Replace grab bars with reinforcement
Barrier Severity:	3 Hindrance Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23V
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Side Grab Bar
Code References:	2010 ADAS 604.5.1
Performance Sta	andard: No Quantity: JOB As-built : 0
Barrier Description:	Side grab bar not min. 42" long
Findings:	36" long
Rec. Solution:	Replace grab bars with reinforcement
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23W
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
	Fider 1 Chisex Folice Room 105
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	
	N/A Y Coordinate: N/A
Barrier Area:	N/A Y Coordinate: N/A Restrooms
Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Restrooms  Toilet - Flush Handle  2010 ADAS 604.6
Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Restrooms  Toilet - Flush Handle  2010 ADAS 604.6
Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A Y Coordinate: N/A  Restrooms  Toilet - Flush Handle  2010 ADAS 604.6  Indard: No Quantity: JOB As-built: 1
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	N/A  Restrooms  Toilet - Flush Handle  2010 ADAS 604.6  Indard: No Quantity: JOB As-built: 1  Handle does not point to wide side of stall or compartment
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Restrooms  Toilet - Flush Handle  2010 ADAS 604.6  Indard: No Quantity: JOB As-built: 1  Handle does not point to wide side of stall or compartment  Handle pointing towards small side of stall/room  Replace water closet
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Restrooms Toilet - Flush Handle 2010 ADAS 604.6  Indard: No Quantity: JOB As-built: 1  Handle does not point to wide side of stall or compartment  Handle pointing towards small side of stall/room  Replace water closet  1 Necessary Cost Est \$850.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23X
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet Paper Dispenser
Code References:	2010 ADAS 604.7
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Toilet tissue dispenser not within 7" to 9" from front edge of toilet
Findings:	Dispenser not within 7" to 9" from front edge of toilet
Rec. Solution:	Reposition or replace toilet paper dispenser
Barrier Severity:	3 Hindrance Cost Est \$225.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23Y
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Seat Cover Dispenser
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Seat cover dispenser not located on an accessible route. Blocked by water closet
Findings:	Access to dispenser blocked by water closet
Rec. Solution:	Replace or remount dispenser on an accessible route with clear floor space
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 23Z
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Unisex Toilet Room 105
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Alarm - Horn/Strobe
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Where a fire alarm is installed, no horn/strobe provided
Findings:	No device provided
Rec. Solution:	Provide horn/strobe in sanitary facility
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 24A
	6/25/2019 Report Date 9/13/2019 Barrier #: 24A Hovland Hall Reference Dwg: 3 of 4
Field Date: Bldg Name: Location:	( C4 )
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Stairway to Staff 108
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A  Stairways
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  ndard: No Quantity: LF As-built: 12
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  Indard: No Quantity: LF As-built: 12  Handrail grip measured at center not 34"- 38" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  mdard: No Quantity: LF As-built: 12  Handrail grip measured at center not 34"- 38" high  33" handrail grip height  Provide handrails at both sides of stairway
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Stairway to Staff 108  N/A  Y Coordinate: N/A  Stairways  Handrail Height  2010 ADAS 505.10.2  Indard: No Quantity: LF As-built: 12  Handrail grip measured at center not 34"- 38" high  33" handrail grip height  Provide handrails at both sides of stairway  2 Recommended Cost Est \$2,700.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 24B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Stairway to Staff 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Bottom
Code References:	2010 ADAS 505.10.3
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Extension not sloped for length of one tread beyond the last riser nosing
Findings:	Extension not sloped for the length of one tread long. 5" extension
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 24C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Stairway to Staff 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Stallways
	Contrasting Color - ADA
Code References:	
Code	Contrasting Color - ADA 2010 ADAS Advisory 504.4
Code References:	Contrasting Color - ADA 2010 ADAS Advisory 504.4
Code References: Performance Sta Barrier	Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2
Code References: Performance Sta Barrier Description:	Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2  No contrasting color on each tread of interior stairway
Code References: Performance Sta Barrier Description: Findings:	Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2  No contrasting color on each tread of interior stairway  Treads lack contrasting color defined as 70% contrast  Recommended: Consider providing contrasting color on each tread
Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Contrasting Color - ADA  2010 ADAS Advisory 504.4  Indard: Yes Quantity: LF or TR As-built: 2  No contrasting color on each tread of interior stairway  Treads lack contrasting color defined as 70% contrast  Recommended: Consider providing contrasting color on each tread  2 Recommended Cost Est \$70.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 24D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Stairway to Staff 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Common Use Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobes in common use areas
Findings:	No device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Agricultural Sci & Marine Sci Business Center 108
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
Location: X Coordinate:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate:  N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate:  N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate:  N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard:  No  Quantity:  EACH  As-built:  1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate:  N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard:  No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108 N/A Y Coordinate: N/A Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	10 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25C
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 25C  Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Agricultural Sci & Marine Sci Business Center 108
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep  Replace or adjust door closer
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  ndard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep  Replace or adjust door closer  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Headroom - Existing
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate clearance not min. 80" high
Findings:	79-1/2" high
Rec. Solution:	Replace door or gate
Barrier Severity:	3 Hindrance Cost Est \$1,750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Relocate Door
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	7" strike edge clearance at pull side
Rec. Solution:	Install automatic door opening device
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (2.1% to 3.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	andard: No Quantity: SF As-built: 0
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	3.0% slope
Rec. Solution:	Install automatic door opening device
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Stairway
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: EACH As-built : 1
Barrier Description:	Door leading directly into an exit stairway lacks tactile exit sign
	J
Findings:	Door to exit stair lacks tactile exit sign
Findings: Rec. Solution:	Door to exit stair lacks tactile exit sign  Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door
_	Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door
Rec. Solution:	Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door  2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Desk - Clear Floor Space
Code References:	2010 ADAS 902.3
Performance Sta	ndard: No Quantity: EACH As-built: 0
Barrier Description:	Clear floor space 30" x 48" not provided at desk
Findings:	Stored items block desk clear floor space at student desk
Rec. Solution:	Provide accessible desk or workstation
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25I
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Desk - Knee Clearance
Code References:	2010 ADAS 902.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	22" high knee clearance at student desk
Rec. Solution:	Provide min. one accessible desk or workstation
Barrier Severity:	3 Hindrance Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



	6/25/2019 Report Date 9/13/2019 Barrier #: 25J
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Outlets - Hi/Low Reach
Code References:	2010 ADAS 308.2.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Use of outlet involves low reach of less than 15" above floor or more than 48" high
Findings:	12-1/2" high
Rec. Solution:	Relocate outlet to area at min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25K
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 25K  Hovland Hall Reference Dwg: 3 of 4
	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  andard: No Quantity: EACH As-built: 3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Andard: No Quantity: EACH As-built: 3  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Andard: No Quantity: EACH As-built: 3  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at doors within public route at rooms 108A  Provide accessible signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Andard: No Quantity: EACH As-built: 3  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at doors within public route at rooms 108A  Provide accessible signs  1 Necessary Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25L
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Shelves or Cabinets
Code	2010 ADAS 305.3
References:	
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Shelf or cabinet not mounted max. 48" above floor or ground
Findings:	Flyer holder 62" high
Rec. Solution:	Provide additional shelf at accessible height or provide assistance
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25M
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Desk blocks flyer clear floor space
Rec. Solution:	Move stored items
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25N
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 4
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at doors within public route at rooms 106B, 106C, 106D and 106E
Rec. Solution:	Provide accessible signs
Barrier Severity:	1 Necessary Cost Est \$1,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 250
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mark misus
	Controls and Mechanisms
Barrier Type:	Shelves or Cabinets
Code	
Code References:	Shelves or Cabinets 2010 ADAS 305.3
Code References: Performance Sta Barrier	Shelves or Cabinets 2010 ADAS 305.3
Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Shelves or Cabinets  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1
Code References: Performance Sta Barrier Description:	Shelves or Cabinets  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground
Code References: Performance Sta Barrier Description: Findings:	Shelves or Cabinets  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground  Shelf and cabinet not accessible  Provide additional shelf at accessible height or provide assistance
Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Shelves or Cabinets  2010 ADAS 305.3  ndard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground  Shelf and cabinet not accessible  Provide additional shelf at accessible height or provide assistance  3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Shelves or Cabinets  2010 ADAS 305.3  ndard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground  Shelf and cabinet not accessible  Provide additional shelf at accessible height or provide assistance  3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25P
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Stored items block light switch clear floor space
Rec. Solution:	Move stored items
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25Q
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Fire Pull - Operation
Code References:	2010 ADAS 309.4
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Fire pull has no fist operable hardware
Findings:	Fire pull not fist operable
Rec. Solution:	Replace fire pull when remodeling
Barrier Severity:	4 Low Severity Cost Est \$3,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25R
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Stairway
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: EACH As-built: 1
Barrier Description:	Door leading directly into an exit stairway lacks tactile exit sign
Findings:	Door to exit stair with low level illuminated sign lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25S
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel located higher than 43" above the floor. 48" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25T
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Agricultural Sci & Marine Sci Business Center 108
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Threshold - Height exceeding 1/4" without bevel
Code References:	2010 ADAS 404.2.5
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate threshold exceeds 1/4" in height without a bevel
Findings:	Carpet at threshold not secured. May be a tripping object
Rec. Solution:	Provide new door threshold to secure carpet
Barrier Severity:	1 Necessary Cost Est \$275.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 25U
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 25U Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Agricultural Sci & Marine Sci Business Center 108  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail - Opening Limitations
Code References:	Performance Standard
Performance Sta	andard: No Quantity: LF As-built : 8
Barrier Description:	Guard or handrail have openings that allow passage of a 4" sphere
Findings:	Guardrail 5-1/2" opening
Rec. Solution:	Replace handrails
Barrier Severity:	1 Necessary Cost Est \$1,800.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Height
Code References:	2010 ADAS 505.10.2
Performance Sta	andard: No Quantity: LF As-built : 23
Barrier Description:	Handrail grip measured at center not 34"- 38" high
Findings:	33-1/2" handrail grip height
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$5,175.00 Facility Function: Public Status: Open
	2 Recommended Cost Est  35,175.00   racinty runction.  Fubile Status.  Open
Implementation	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Top
Code References:	2010 ADAS 505.10.2
Performance Sta	ndard: No Quantity: LF As-built : 0
Barrier Description:	Extension does not extend horizontally above landing for min. 12" from first riser nosing
Findings:	No top extension at the wall side
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail Extension - Bottom
Code References:	2010 ADAS 505.10.3
Performance Sta	ndard: No Quantity: LF As-built: 0
Barrier Description:	Extension not sloped for length of one tread beyond the last riser nosing
Findings:	Extension not sloped for the length of one tread long
Rec. Solution:	Provide handrails at both sides of stairway
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail - Opening Limitations
Code References:	Performance Standard
Performance Sta	ndard: No Quantity: LF As-built : 21
Barrier Description:	Guard or handrail have openings that allow passage of a 4" sphere
Findings:	5-1/2" opening
Rec. Solution:	Replace handrails
Barrier Severity:	1 Necessary Cost Est \$4,725.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Handrail - Opening Limitations
Code References:	Performance Standard
Performance Sta	ndard: No Quantity: LF As-built: 0
Barrier Description:	Guard or handrail have openings that allow passage of a 4" sphere
Findings:	Guardrail not provided
Rec. Solution:	Provide guardrails
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Stairways
Barrier Type:	Contrasting Color - ADA
Code References:	2010 ADAS Advisory 504.4
Performance Sta	ndard: Yes Quantity: LF or TR As-built: 21
Barrier Description:	No contrasting color on each tread of exterior stairway
Findings:	Treads lack contrasting color defined as 70% contrast
Rec. Solution:	Recommended: Consider providing contrasting color on each tread
Barrier Severity:	2 Recommended Cost Est \$735.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 26H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - West Egress Stairway
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	ISA - Directional Sign
Code References:	2010 ADAS 216.6 Advisory
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No directional signage provided where accessible route diverges from main route
Findings:	Accessible sign not provided
Rec. Solution:	Provide directional signage
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
	Thecessary cost Est   5230.00 Tacinty Function.   Public Status.   Open
implementation	Priority: 3 Implementation Phase: Implementation Date:



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Seminar Room 104
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Seminar Room 104
V 6 12 1 -	
X Coordinate:	N/A Y Coordinate: N/A
x Coordinate: Barrier Area:	N/A
Barrier Area:	Doors or Gates
Barrier Area: Barrier Type: Code	Doors or Gates Vision Lights - Existing 2010 ADAS 404.2.11
Barrier Area: Barrier Type: Code References:	Doors or Gates Vision Lights - Existing 2010 ADAS 404.2.11
Barrier Area: Barrier Type: Code References: Performance Sta Barrier	Doors or Gates Vision Lights - Existing 2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Doors or Gates  Vision Lights - Existing  2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1  View panels in or adjacent to doors or gates not max. 43" above floor or ground
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Doors or Gates  Vision Lights - Existing  2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1  View panels in or adjacent to doors or gates not max. 43" above floor or ground  View panel located 46" above the floor  Replace door/gate or vision panel
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Doors or Gates  Vision Lights - Existing  2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1  View panels in or adjacent to doors or gates not max. 43" above floor or ground  View panel located 46" above the floor  Replace door/gate or vision panel  3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Seminar Room 104
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	Recycle bin blocks strike edge clearance at pull side
Rec. Solution:	Move recycling bin
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27D
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 27D Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Philosophy Seminar Room 104
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Controls and Mechanisms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Recycling bin blocks electrical switch clear floor space
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Recycling bin blocks electrical switch clear floor space  Move recycling bin  1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Seminar Room 104
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Assembly Areas
Barrier Type:	Shared Assistive Listening System
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	No shared assistive listening system for room with min. 10 seats
Findings:	No system provided in room providing 10 seats
Rec. Solution:	Provide shared ALS system with signage
Barrier Severity:	2 Recommended Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Philosophy Seminar Room 104
Location:	Floor 1 - Philosophy Seminar Room 104
Location: X Coordinate:	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables  Table - Pedestal Base  2010 ADAS 306.2.2 & 306.2.3
Location:  X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables  Table - Pedestal Base  2010 ADAS 306.2.2 & 306.2.3
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code  References:  Performance Sta	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables  Table - Pedestal Base  2010 ADAS 306.2.2 & 306.2.3  Indard: No Quantity: EACH As-built: 0
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables  Table - Pedestal Base  2010 ADAS 306.2.2 & 306.2.3  andard: No  Quantity: EACH  As-built:  Knee clearance not min. 27" high, 19" deep or 30" wide
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables  Table - Pedestal Base  2010 ADAS 306.2.2 & 306.2.3  Indard: No Quantity: EACH As-built: 0  Knee clearance not min. 27" high, 19" deep or 30" wide  Pedestal base blocks knee clearance  Provide min. 1 accessible table. Avoid pedestal base tables.
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables  Table - Pedestal Base  2010 ADAS 306.2.2 & 306.2.3  Indard: No Quantity: EACH As-built: 0  Knee clearance not min. 27" high, 19" deep or 30" wide  Pedestal base blocks knee clearance  Provide min. 1 accessible table. Avoid pedestal base tables.  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Counters and Tables  Table - Pedestal Base  2010 ADAS 306.2.2 & 306.2.3  ndard: No Quantity: EACH As-built: 0  Knee clearance not min. 27" high, 19" deep or 30" wide  Pedestal base blocks knee clearance  Provide min. 1 accessible table. Avoid pedestal base tables.  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Seminar Room 104
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Workstation - Knee Clearance
Code References:	2010 ADAS 902
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	25" high knee clearance
Rec. Solution:	Provide min. 1 accessible workstation of each type or overall 5%
Barrier Severity:	1 Necessary Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
· · · · · · · · · · · · · · · · · · ·	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27H
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 27H Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Philosophy Seminar Room 104
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Classrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  ndard: Yes Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  ndard: Yes Quantity: EACH As-built: 1  Bottom edge of writing surface not max. 38" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  ndard: Yes Quantity: EACH As-built: 1  Bottom edge of writing surface not max. 38" high  Lower edge of writing surface 41-1/2" high from floor  Remount whiteboard/chalkboard or provide alternate for use by short people
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Philosophy Seminar Room 104  N/A  Y Coordinate: N/A  Classrooms  Chalkboard/Whiteboard - Area of Use  Performance Standard (2010 ADAS 904.3.3)  ndard: Yes Quantity: EACH As-built: 1  Bottom edge of writing surface not max. 38" high  Lower edge of writing surface 41-1/2" high from floor  Remount whiteboard/chalkboard or provide alternate for use by short people  3 Hindrance Cost Est \$1,200.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 27I
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Seminar Room 104
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Meeting Room
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobes in meeting room
Findings:	No device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 46" above the floor
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door 10" Bottom Surface - Kickplate
Code References:	2010 ADAS 404.2.10
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate lacks min. 10" smooth uninterrupted bottom surface
Findings:	Bottom of door not smooth and uninterrupted. 9" high to vent
Rec. Solution:	Provide smooth kick plate min. 10" high at push side of door
Barrier Severity:	1 Necessary Cost Est \$225.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28E
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 28E  Hovland Hall Reference Dwg: 3 of 4
	i illica
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Graduate Student Office 103
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  6" strike edge clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Graduate Student Office 103  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  6" strike edge clearance at pull side  Rearrange furniture to provide wheelchair access  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Desk blocks electrical switch clear floor space
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Coat Hook - Clear Floor Space
Code References:	2010 ADAS 603.4
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Clothing hooks not located within 30" x 48" clear floor space
Findings:	Door swings obstruct coat hook clear floor space
Rec. Solution:	Provide additional hook in accessible location
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	Friority. 2 Implementation Friase.



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Coat Hook - Height
Code References:	2010 ADAS 308.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Clothing hooks not max. 48" high AFF
Findings:	69" high
Rec. Solution:	Provide additional hook in accessible location
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28I
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route to Room 103A
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 28J
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 29A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Rec. Solution: Barrier Severity:	
	Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 29B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Locking mechanism not operable with a closed fist
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 29C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Threshold - Height exceeding 1/2"
Code References:	2010 ADAS 404.2.5
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate threshold exceeds 1/2" in height
Findings:	3/4" lip
Rec. Solution:	Provide new door threshold
Rec. Solution: Barrier Severity:	
	1 Necessary Cost Est \$275.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 29D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	andard: No Quantity: EACH As-built : 2
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at doors within public route at doors to 103 and 102E
Rec. Solution:	Provide accessible signs
Barrier Severity:	1 Necessary Cost Est \$500.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 29E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Graduate Student Office 103A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	A Little Court Cou
	andard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Description:	No horn/strobe in staff areas
Description: Findings:	No horn/strobe in staff areas  No device provided  Provide horn/strobe where programs, services and activities take place
Description: Findings: Rec. Solution:	No horn/strobe in staff areas  No device provided  Provide horn/strobe where programs, services and activities take place  3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30A
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	10 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 47-1/2" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door 10" Bottom Surface - Door Stop
Code References:	2010 ADAS 404.2.10
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Door stop interrupts min.10" smooth bottom surface
Findings:	Door stop at bottom of door can create trapping condition
Rec. Solution:	Remove door stop or other element at bottom of door at push side
Barrier Severity:	1 Necessary Cost Est \$75.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 60" - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Findings:	Paper bin and desk reduces door maneuvering clearance at pull side
Rec. Solution:	Remove stored items and rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built: 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Stored items block electrical switch clear floor space
Rec. Solution:	Move stored items
Barrier Severity:	Cost Est 16425 00 Facility Experience D. Liv. Status: 10
Implementation	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
implementation	Priority: 2 Implementation Phase: Implementation Date:



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30I
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Desk - Knee Clearance
Code References:	2010 ADAS 902.3
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	25" high knee clearance
Rec. Solution:	Provide min. one accessible desk or workstation
Barrier Severity:	3 Hindrance Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30J
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Counters and Tables
Barrier Type:	Counter - Clear Floor Space
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Clear floor space 30" x 48" not provided at counter
Findings:	Stored items block printer clear floor space
Rec. Solution:	Move stored items
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	
	Priority: 2 Implementation Phase: Implementation Date:



Ciold Data:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30K
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Outlets - Hi/Low Reach
Code References:	2010 ADAS 308.2.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Use of outlet involves low reach of less than 15" above floor or more than 48" high
Findings:	11" high
Rec. Solution:	Relocate outlet to area at min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30L
Dida Nama	
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Philosophy Faculty Offices 102
Location:	Floor 1 - Philosophy Faculty Offices 102
Location: X Coordinate: Barrier Area:	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code  References:	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors  Passageway - Min. 36"  2010 ADAS 403.5.1
Location: X Coordinate:	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors  Passageway - Min. 36"  2010 ADAS 403.5.1
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code  References:  Performance Sta	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors  Passageway - Min. 36"  2010 ADAS 403.5.1  ndard: No Quantity: LF As-built: 5
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors  Passageway - Min. 36"  2010 ADAS 403.5.1  ndard: No Quantity: LF As-built: 5  Circulation route through corridor not min. 36"
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors  Passageway - Min. 36"  2010 ADAS 403.5.1  ndard: No Quantity: LF As-built: 5  Circulation route through corridor not min. 36"  33-1/2" wide to faculty offices 102A and 102B
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors  Passageway - Min. 36"  2010 ADAS 403.5.1  ndard: No Quantity: LF As-built: 5  Circulation route through corridor not min. 36"  33-1/2" wide to faculty offices 102A and 102B  Demolish existing and construct new passageway  1 Necessary Cost Est \$625.00 Facility Function: Public Status: Open
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Floor 1 - Philosophy Faculty Offices 102  N/A  Y Coordinate: N/A  Corridors  Passageway - Min. 36"  2010 ADAS 403.5.1  ndard: No Quantity: LF As-built: 5  Circulation route through corridor not min. 36"  33-1/2" wide to faculty offices 102A and 102B  Demolish existing and construct new passageway  1 Necessary Cost Est \$625.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30M
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Headroom - Existing
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate clearance not min. 80" high
Findings:	79-1/2" high
Rec. Solution:	Replace door or gate
Barrier Severity: Implementation	
Notes:	Priority. 2 implementation Phase. 1 implementation Date.
Notes.	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30N
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	ndard: No Quantity: SF As-built: 20
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	3.8% slope
Rec. Solution:	Remodel to provide level clear floor space at controls/mechanisms
Barrier Severity:	2 Necessary Cost Est \$11,500.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 300
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Clear Floor Space - Stored Items
Code References:	2010 ADAS 306.3.2
Performance Sta	andard: No Quantity: JOB As-built: 1
Barrier Description:	Clear floor space of min. 30" by 48" not provided
Findings:	Chair blocks switch clear floor space
Rec. Solution:	Move chair
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30P
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Sign - Permanent Room/Space
Code References:	2010 ADAS 703.1
Performance Sta	andard: No Quantity: EACH As-built : 3
Barrier Description:	No sign with raised characters and Braille at permanent room or space with visual sign
Findings:	No tactile info on signs with visual information at 102A, 102B, and 102C
Rec. Solution:	Provide signs at latch side of entry doors, where possible
Barrier Severity:	
	1 Necessary Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 30Q
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Philosophy Faculty Offices 102
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Common Use Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobes in common use areas
Findings:	No device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31A
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 31A Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102E
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102E
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31C
	6/25/2019 Report Date 9/13/2019 Barrier #: 31C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102E
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Relocate Door  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Relocate Door  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Relocate Door  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Relocate Door  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: EACH As-built: 1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102E N/A  Doors or Gates Front App/pull 60" - Relocate Door 2010 ADAS Figure 404.2.4.1  Indard: No Quantity: EACH As-built: 1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door  43" deep to wall
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Relocate Door  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door  43" deep to wall  Relocate door or gate to provide maneuvering clearance  1 Necessary  Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102E
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Passageway - Min. 36" (Stored Item)
Code References:	2010 ADAS 403.5.1
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Circulation route not min. 36" wide between elements
Findings:	Min. 36" wide circulation route not provided due to chairs
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31E
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102E
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Clear Floor Space - Wheelchair Use
Code References:	2010 ADAS 305
Performance Sta	ndard: No Quantity: JOB As-built : 1
Performance Sta Barrier Description:	ndard: No Quantity: JOB As-built : 1  Clear floor space of min. 30" by 48" not provided
Barrier	
Barrier Description:	Clear floor space of min. 30" by 48" not provided
Barrier Description: Findings:	Clear floor space of min. 30" by 48" not provided  Chair blocks electrical switch clear floor space  Move chair
Barrier Description: Findings: Rec. Solution:	Clear floor space of min. 30" by 48" not provided  Chair blocks electrical switch clear floor space  Move chair  1 Necessary  Cost Est \$0.00  Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102E
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Outlets - Hi/Low Reach
Code References:	2010 ADAS 308.2.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Use of outlet involves low reach of less than 15" above floor or more than 48" high
Findings:	14" high
Rec. Solution:	Relocate outlet to area at min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31G
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 31G Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102E
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102E N/A Y Coordinate: N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102E  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route to office 103A  Provide accessible sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102E N/A Y Coordinate: N/A Signage Permanent Room/Space - Tactile Characters 2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1 No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route to office 103A  Provide accessible sign  I Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 31H
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102E
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 32A
Field Date: Bldg Name:	6/25/2019 Report Date 9/13/2019 Barrier #: 32A Hovland Hall Reference Dwg: 3 of 4
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102D
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 32B
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102D
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 32C
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
_	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102D
Location:	
Location:	Floor 1 - Office 102D
Location: X Coordinate:	Floor 1 - Office 102D  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 1 - Office 102D  N/A Y Coordinate: N/A  Doors or Gates
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 1 - Office 102D  N/A  Y Coordinate:  N/A  Doors or Gates  Vision Lights - Existing  2010 ADAS 404.2.11
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 1 - Office 102D  N/A  Y Coordinate:  N/A  Doors or Gates  Vision Lights - Existing  2010 ADAS 404.2.11
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	Floor 1 - Office 102D  N/A  Y Coordinate:  N/A  Doors or Gates  Vision Lights - Existing  2010 ADAS 404.2.11  Indard:  No  Quantity:  EACH  As-built:  1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Doors or Gates  Vision Lights - Existing  2010 ADAS 404.2.11  Indard: No  Quantity: EACH  As-built:  View panels in or adjacent to doors or gates not max. 43" above floor or ground
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 1 - Office 102D N/A Y Coordinate: N/A  Doors or Gates Vision Lights - Existing 2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1  View panels in or adjacent to doors or gates not max. 43" above floor or ground  View panel 55" high  Replace door/gate or vision panel
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 1 - Office 102D N/A Y Coordinate: N/A  Doors or Gates Vision Lights - Existing 2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1  View panels in or adjacent to doors or gates not max. 43" above floor or ground  View panel 55" high  Replace door/gate or vision panel 3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 32D
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102D
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	Shelf and cabinet blocks door maneuvering clearance at pull side
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 32E
	6/25/2019 Report Date 9/13/2019 Barrier #: 32E Hovland Hall Reference Dwg: 3 of 4
Field Date: Bldg Name: Location:	
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102D
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 3 of 4 Floor 1 - Office 102D N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Controls and Mechanisms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  ndard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  ndard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  ndard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Shelf blocks electrical switch clear floor space  Rearrange furniture to provide wheelchair access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 3 of 4  Floor 1 - Office 102D  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  ndard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Shelf blocks electrical switch clear floor space  Rearrange furniture to provide wheelchair access  1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open



Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 32F
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102D
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
Findings:	51" high
Rec. Solution:	Relocate switch box top edge to max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/25/2019 Report Date 9/13/2019 Barrier #: 32G
Bldg Name:	Hovland Hall Reference Dwg: 3 of 4
Location:	Floor 1 - Office 102D
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 33A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Fire Alarm - Pull Actuator Operation
Code References:	2010 ADAS 309.4
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Fire pull has no usable hardware
Findings:	Hardware not accessible
Rec. Solution:	Replace fire pull when remodeling
Barrier Severity:	4 Low Severity Cost Est \$3,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 33B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Fire Alarm - Pull Actuator Height
Code References:	2010 ADAS 308.2.2
Performance Sta	ndard: No Quantity: EACH As-built : 0
Barrier Description:	Fire pulls not between 42" and 48" high
Findings:	60-1/2" high
Rec. Solution:	Replace fire pull when remodeling
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 33C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Electrical Switches - High Unobstructed
Code References:	2010 ADAS 308.2.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
Findings:	54" high
Rec. Solution:	Relocate switch box top edge to max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 33D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Fire Extinguisher - Protruding Object
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Fire extinguisher protrudes into circulation path more than 4" between 27" and 80"
Findings:	Fire extinguisher protrudes 5-1/2" at 33" high
Rec. Solution:	Demonstration is a suitable adian adea below 2711 as a secide detectable consider
	Remount extinguisher with leading edge below 27" or provide detectable warning
Barrier Severity:	
Barrier Severity: Implementation	4 Low Severity Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 33E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Carpet - Firmly Attached
Code References:	2010 ADAS 302.2
Performance Sta	ndard: No Quantity: SF As-built : 1
Barrier Description:	Carpet, carpet tile or exposed edges of carpet not securely attached or fastened to floor
Findings:	Carpet not firmly attached to floor
Rec. Solution:	Fasten carpet or tiles firmly to floor, remove or replace
Barrier Severity:	2 Recommended Cost Est \$12.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 33F
Plda Namo	
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Corridor H201
Location:	Floor 2 - Corridor H201
Location: X Coordinate:	Floor 2 - Corridor H201  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 2 - Corridor H201  N/A  Y Coordinate: N/A  Corridors
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 2 - Corridor H201  N/A Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 2 - Corridor H201  N/A Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 2 - Corridor H201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 2 - Corridor H201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Corridor H201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  Fire riser protrudes 14" at 77-1/2" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 2 - Corridor H201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  Fire riser protrudes 14" at 77-1/2" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 33G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Strobe
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No strobe provided in corridor where horn is provided where fire alarm exists in building
Findings:	No strobe where horn is provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 34A
	6/26/2019 Report Date 9/13/2019 Barrier #: 34A Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Corridor H200
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Corridor H200 N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  ndard: No Quantity: EACH As-built: 1  No sign with raised characters and Braille at permanent room or space with visual sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  ndard: No Quantity: EACH As-built: 1  No sign with raised characters and Braille at permanent room or space with visual sign  No tactile info on sign with visual information
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Sign - Permanent Room/Space  2010 ADAS 703.1  No sign with raised characters and Braille at permanent room or space with visual sign  No tactile info on sign with visual information  Provide sign at latch side of entry door, where possible  1 Necessary  Cost Est \$250.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 34B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H200
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	7 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 34C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Corridor H200
_	
Location:	Floor 2 - Corridor H200
Location: X Coordinate:	Floor 2 - Corridor H200  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 2 - Corridor H200  N/A Y Coordinate: N/A  Corridors
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 2 - Corridor H200  N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 2 - Corridor H200  N/A  Y Coordinate:  N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  andard: No Quantity: EACH As-built: 0
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 2 - Corridor H200  N/A  Y Coordinate:  N/A  Corridors  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  andard:  No  Quantity:  EACH  As-built:  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Corridor H200 N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period 2010 ADAS 404.2.8.1  andard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  4 second sweep  Replace or adjust door closer
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 2 - Corridor H200 N/A Y Coordinate: N/A  Corridors  Door Closer - Interior Sweep Period 2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  4 second sweep  Replace or adjust door closer  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 34D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H200
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Door - Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Door knob not accessible
Rec. Solution:	Replace hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	
i icia Date.	6/26/2019 Report Date 9/13/2019 Barrier #: 34E
Bldg Name:	6/26/2019   Report Date   9/13/2019   Barrier #:   34E   Hovland Hall   Reference Dwg:   4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Corridor H200
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Vision Lights in Doors  2010 ADAS 404.2.11
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Vision Lights in Doors  2010 ADAS 404.2.11
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Vision Lights in Doors  2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Vision Lights in Doors  2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1  Doors or gates with view panels or side lights adjacent to doors not max. 43" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Vision Lights in Doors  2010 ADAS 404.2.11  Doors or gates with view panels or side lights adjacent to doors not max. 43" high  View panels 44" high  Replace door or vision panel in door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Corridor H200  N/A  Y Coordinate: N/A  Corridors  Vision Lights in Doors  2010 ADAS 404.2.11  Indard: No Quantity: EACH As-built: 1  Doors or gates with view panels or side lights adjacent to doors not max. 43" high  View panels 44" high  Replace door or vision panel in door  3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 34F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H200
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Relocate Door
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	5" strike edge clearance at pull side
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 34G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H200
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route at office 200B
Rec. Solution:	Provide accessible sign
	i Tottae accessiste sign
Barrier Severity:	
Barrier Severity: Implementation	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 34H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H200
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Horn/Strobe Device
Code References:	2010 ADAS 702.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No horn or strobe in corridor where fire alarm exists in building
Findings:	No horn/strobe provided
Rec. Solution:	Provide horn/strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 35A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 200B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Area: Barrier Type:	Signage   Permanent Room/Space - Tactile Characters   Permanent
Barrier Type: Code	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Barrier Type: Code References:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Barrier Type: Code References: Performance Sta Barrier	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1
Barrier Type: Code References: Performance Sta Barrier Description:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign
Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 35B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 200B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible. Locking mechanism not fist operable
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 35C
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 35C  Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 200B
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Office 200B  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 200B  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 200B  N/A  Y Coordinate: N/A  Doors or Gates  Hinge App/push 42"  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 200B  N/A  Y Coordinate: N/A  Doors or Gates  Hinge App/push 42"  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 200B  N/A  Y Coordinate: N/A  Doors or Gates  Hinge App/push 42"  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1  Door/Gate with hinge approach with min. 22" beyond hinge at push side lacks min. 42"
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 200B  N/A  Y Coordinate: N/A  Doors or Gates  Hinge App/push 42"  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: EACH As-built: 1  Door/Gate with hinge approach with min. 22" beyond hinge at push side lacks min. 42" perpendicular to door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 200B N/A Y Coordinate: N/A  Doors or Gates Hinge App/push 42" 2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1  Door/Gate with hinge approach with min. 22" beyond hinge at push side lacks min. 42" perpendicular to door  40" perpendicular to door. Corridor is 40" wide in low occupancy area
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 200B  N/A  Y Coordinate: N/A  Doors or Gates  Hinge App/push 42"  2010 ADAS Figure 404.2.4.1  Door/Gate with hinge approach with min. 22" beyond hinge at push side lacks min. 42" perpendicular to door  40" perpendicular to door. Corridor is 40" wide in low occupancy area  Install automatic door opening device to compensate for lack of maneuvering clearance  1 Necessary  Cost Est \$5,000.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 35D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 200B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	Trash bin and cabinet blocks door maneuvering clearance at pull side
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 35E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 200B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Findings: Rec. Solution:	No device provided  Provide horn/strobe where programs, services and activities take place
_	Provide horn/strobe where programs, services and activities take place
Rec. Solution:	Provide horn/strobe where programs, services and activities take place    3 Hindrance   Cost Est   \$5,500.00   Facility Function:   Public   Status:   Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 36A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Study Room 200C
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 36B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Study Room 200C
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible. Locking mechanism not fist operable
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 36C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Study Room 200C
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Headroom - Existing
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate clearance not min. 80" high
Findings:	79-3/4" high
Rec. Solution:	Replace door or gate
Barrier Severity:	3 Hindrance Cost Est \$1,750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 36D
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 36D Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Study Room 200C
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  mdard: No Quantity: ADMINI As-built: 1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door  Shelf and stored items reduce door maneuvering clearance to 51" deep  Rearrange furniture and remove stored items to provide access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Study Room 200C  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 60" - Blocked  2010 ADAS Figure 404.2.4.1  Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door  Shelf and stored items reduce door maneuvering clearance to 51" deep  Rearrange furniture and remove stored items to provide access  1 Necessary  Cost Est \$0.00  Facility Function: Public Status: Open



Bldg Name: Hovland Hall Reference Dwg: 4 of 4	7
Location: Floor 2 - Study Room 200C	
X Coordinate: N/A Y Coordinate: N/A	
Barrier Area: Counters and Tables	
Barrier Type: Table - Knee Clearance	
Code 2010 ADAS 305.3 References:	
Performance Standard: No Quantity: EACH As-built: 1	
Barrier Knee clearance not min. 27" high, 19" deep or 30" wide Description:	
24-3/8" high knee clearance Findings:	
Rec. Solution: Provide min. 1 accessible table. Avoid pedestal base tables.	
Barrier Severity: 3 Hindrance Cost Est \$450.00 Facility Function	n: Public Status: Open
Implementation Priority: 2 Implementation Phase: Impleme	entation Date:
Notes:	
J.	
Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 36F	
Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 36F  Bldg Name: Hovland Hall Reference Dwg: 4 of 4	
Bldg Name: Hovland Hall Reference Dwg: 4 of 4	
Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Study Room 200C	
Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Study Room 200C  X Coordinate: N/A Y Coordinate: N/A	
Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Study Room 200C  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Controls and Mechanisms	
Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Study Room 200C  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Controls and Mechanisms  Barrier Type: Clear Floor Space - Stored Elements  Code 2010 ADAS 305.3	
Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Study Room 200C  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Controls and Mechanisms  Clear Floor Space - Stored Elements  Code  References: 2010 ADAS 305.3	hanism
Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Study Room 200C  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Controls and Mechanisms  Barrier Type: Clear Floor Space - Stored Elements  Code 2010 ADAS 305.3  Performance Standard: No Quantity: JOB As-built: 1  Barrier Clear floor space for wheelchair not provided at control or medians.	hanism
Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Study Room 200C X Coordinate: N/A Y Coordinate: N/A Barrier Area: Controls and Mechanisms Barrier Type: Clear Floor Space - Stored Elements Code 2010 ADAS 305.3 Performance Standard: No Quantity: JOB As-built: 1 Barrier Description: Clear floor space for wheelchair not provided at control or mechanisms Code 2010 ADAS 305.3	hanism
Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Study Room 200C  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Controls and Mechanisms  Barrier Type: Clear Floor Space - Stored Elements  Code 2010 ADAS 305.3  Performance Standard: No Quantity: JOB As-built: 1  Barrier Description: Sofa and chair block whiteboard clear floor space  Findings:	
Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Study Room 200C X Coordinate: N/A Y Coordinate: N/A Barrier Area: Controls and Mechanisms Barrier Type: Clear Floor Space - Stored Elements Code 2010 ADAS 305.3  Performance Standard: No Quantity: JOB As-built: 1  Barrier Description: Clear floor space for wheelchair not provided at control or mechanisms  Sofa and chair block whiteboard clear floor space Findings: Rearrange furniture to provide wheelchair access  Barrier Severity: 1 Necessary Cost Est \$125.00 Facility Function	



Field Date:	
	6/26/2019 Report Date 9/13/2019 Barrier #: 36G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Study Room 200C
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route at Storage 200D
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 36H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Study Room 200C
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Shelves or Cabinets
	Jameires of Cabillets
Code References:	2010 ADAS 305.3
Code	2010 ADAS 305.3
Code References:	2010 ADAS 305.3
Code References: Performance Sta Barrier	2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1
Code References: Performance Sta Barrier Description:	2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground
Code References: Performance Sta Barrier Description: Findings:	2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground  Shelf not accessible  Provide additional shelf at accessible height or provide assistance
Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground  Shelf not accessible  Provide additional shelf at accessible height or provide assistance  3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 36I
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Study Room 200C
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Common Use Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	No horn/strobes in common use areas
Findings:	No device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	
	Priority: 3 Implementation Phase: Implementation Date:



P. Control of the Con	6/26/2019 Report Date 9/13/2019 Barrier #: 37B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Star	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	10 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation F	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
<u> </u>	6/26/2019 Report Date 9/13/2019 Barrier #: 37C
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37C  Hovland Hall Reference Dwg: 4 of 4
Field Date:	
Field Date:  Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Field Date:  Bldg Name:  Location:  X Coordinate:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Department of Fisheries and Wildlife 208
Field Date:  Bldg Name:  Location:  X Coordinate:  Barrier Area:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A Y Coordinate: N/A
Field Date:  Bldg Name:  Location:  X Coordinate:  Barrier Area:  Barrier Type:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Doors or Gates
Field Date:  Bldg Name:  Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Star Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Star Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  adard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Star Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Star Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep  Replace or adiust door closer  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible. Locking mechanism not fist operable
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door 10" Bottom Surface - Door Stop
Code References:	2010 ADAS 404.2.10
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door stop interrupts min.10" smooth bottom surface
Findings:	Door stop at bottom of door can create trapping condition
Rec. Solution:	Remove door stop or other element at bottom of door at push side
Barrier Severity:	1 Necessary Cost Est \$75.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Performance Sta Barrier Description:	Indard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high
Barrier	
Barrier Description:	Light switch control box top edge not at max. 48" high
Barrier Description: Findings:	Light switch control box top edge not at max. 48" high  55" high  Relocate switch box top edge to max. 48" high
Barrier Description: Findings: Rec. Solution:	Light switch control box top edge not at max. 48" high  55" high  Relocate switch box top edge to max. 48" high  3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Furniture and door swing blocks cabinet clear floor space
Rec. Solution:	Move furniture and relocate cabinet to accessible location
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37I
Dida Nass	
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall   Reference Dwg:   4 of 4   Floor 2 - Department of Fisheries and Wildlife 208
_	
Location:	Floor 2 - Department of Fisheries and Wildlife 208
Location: X Coordinate:	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Controls and Mechanisms
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate:  N/A  Controls and Mechanisms  Shelves or Cabinets  2010 ADAS 305.3
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate:  N/A  Controls and Mechanisms  Shelves or Cabinets  2010 ADAS 305.3
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Controls and Mechanisms  Shelves or Cabinets  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Controls and Mechanisms  Shelves or Cabinets  2010 ADAS 305.3  andard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Controls and Mechanisms  Shelves or Cabinets  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground  Cabinet not accessible  Provide additional shelf at accessible height or provide assistance
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Controls and Mechanisms  Shelves or Cabinets  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Shelf or cabinet not mounted max. 48" above floor or ground  Cabinet not accessible  Provide additional shelf at accessible height or provide assistance  3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37J
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Passageway - Min. 36" (Stored Item)
Code References:	2010 ADAS 403.5.1
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Circulation route not min. 36" wide between elements
Findings:	Min. 36" wide circulation route not provided within room
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
-	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37K
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 37K Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Clear Floor Space
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  2010 ADAS 305
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  2010 ADAS 305
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  2010 ADAS 305  ndard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  2010 ADAS 305  ndard: No Quantity: JOB As-built: 1  Clear floor space of min. 30" by 48" not provided
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  2010 ADAS 305  ndard: No Quantity: JOB As-built: 1  Clear floor space of min. 30" by 48" not provided  No space provided in lobby for people who use mobility device  Rearrange furniture to provide wheelchair access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  2010 ADAS 305  ndard: No Quantity: JOB As-built: 1  Clear floor space of min. 30" by 48" not provided  No space provided in lobby for people who use mobility device  Rearrange furniture to provide wheelchair access  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37L
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Protruding Object
Code References:	2010 ADAS 307
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Protruding object in circulation path protrudes more than 4" between 27" and 80" high
Findings:	Display box protrudes 8-1/2" at 55" high
Rec. Solution:	Remove protruding object or provide detectable warning (wing walls). Cardboards and chair no
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 1 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37M
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible at door to corridor H203
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	· — · · — · · — · · — · · · · · · · · ·
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37N
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 44" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 370
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 60" - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Findings:	Desk reduces door maneuvering clearance at pull side
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37P
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Department of Fisheries and Wildlife 208
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route from corridor H203
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 37Q
Field Date: Bldg Name:	6/26/2019         Report Date         9/13/2019         Barrier #:         37Q           Hovland Hall         Reference Dwg:         4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Department of Fisheries and Wildlife 208
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Alarms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1  No horn/strobes in common use areas
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Y Coordinate: N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1  No horn/strobes in common use areas  No device provided  Provide strobe in common use area
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Department of Fisheries and Wildlife 208  N/A  Alarms  Horn/Strobe - Common Use Area  2010 ADAS 702.1  ndard: No Quantity: EACH As-built: 1  No horn/strobes in common use areas  No device provided  Provide strobe in common use area  1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open



Field Date:	
ricia Date.	6/26/2019 Report Date 9/13/2019 Barrier #: 38A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38B
	0/20/2019 Report Date  3/13/2019 Burner #:  38B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	
	Hovland Hall Reference Dwg: 4 of 4
Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B
Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Doors or Gates
Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B N/A Y Coordinate: N/A Doors or Gates Door Closer - Interior Adjustment 2010 ADAS 404.2.9
Location:  X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9  andard: No Quantity: EACH As-built: 1
Location:  X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Poors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9  Indard: No Quantity: EACH As-built: 1  Door opening force exceeds 5 lbf
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B N/A Y Coordinate: N/A  Doors or Gates Door Closer - Interior Adjustment 2010 ADAS 404.2.9  andard: No Quantity: EACH As-built: 1  Door opening force exceeds 5 lbf  Replace or adjust existing closer
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Adjustment  2010 ADAS 404.2.9  andard: No Quantity: EACH As-built: 1  Door opening force exceeds 5 lbf  7 lbf  Replace or adjust existing closer  1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Interior Sweep Period
Code References:	2010 ADAS 404.2.8.1
Performance Sta	andard: No Quantity: EACH As-built : 0
Barrier Description:	Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Findings:	4 second sweep
Rec. Solution:	Replace or adjust door closer
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
-	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38D
Field Date: Bldg Name:	6/26/2019   Report Date   9/13/2019   Barrier #:   38D   Hovland Hall   Reference Dwg:   4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B N/A Y Coordinate: N/A Doors or Gates Hardware - Operation 2010 ADAS 404.2.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B N/A Y Coordinate: N/A  Doors or Gates Hardware - Operation 2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Poors or Gates  Hardware - Operation  2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B N/A Y Coordinate: N/A Doors or Gates Hardware - Operation 2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 2 Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable  Provide new hardware
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable  Provide new hardware  1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 48-1/2" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/push 12" SEC
Code	
References:	2010 ADAS Figure 404.2.4.1
References: Performance Sta	
Performance Sta Barrier	ndard: No Quantity: ADMINI As-built : 1
Performance Sta Barrier Description: Findings:	ndard: No Quantity: ADMINI As-built: 1  Door/Gate at push side with min. 48" lacks min. 12" strike edge clearance with latch/closer
Performance Sta Barrier Description: Findings:	ndard: No Quantity: ADMINI As-built: 1  Door/Gate at push side with min. 48" lacks min. 12" strike edge clearance with latch/closer  Chairs reduce door maneuvering clearance at push side  Rearrange furniture to provide wheelchair access
Performance Sta Barrier Description: Findings: Rec. Solution:	ndard: No Quantity: ADMINI As-built: 1  Door/Gate at push side with min. 48" lacks min. 12" strike edge clearance with latch/closer  Chairs reduce door maneuvering clearance at push side  Rearrange furniture to provide wheelchair access  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	12" strike edge clearance at pull side
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
_	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208B
Location:	
Location: X Coordinate:	Floor 2 - Office 208B
Location: X Coordinate:	Floor 2 - Office 208B  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Controls and Mechanisms
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Switches - Height  2010 ADAS 308.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Switches - Height  2010 ADAS 308.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Switches - Height  2010 ADAS 308.2  ndard: No Quantity: EACH As-built: 1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Switches - Height  2010 ADAS 308.2  ndard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Switches - Height  2010 ADAS 308.2  ndard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high  53" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 2 - Office 208B  N/A  Y Coordinate: N/A  Controls and Mechanisms  Electrical Switches - Height  2010 ADAS 308.2  ndard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high  53" high  Relocate switch box top edge to max. 48" high  3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38I
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Coat Hook - Clear Floor Space
Code References:	2010 ADAS 603.4
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Clothing hooks not located within 30" x 48" clear floor space
Findings:	Desk blocks electrical switch clear floor space
Rec. Solution:	Provide additional hook in accessible location
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 38J
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208B
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



	6/26/2019 Report Date 9/13/2019 Barrier #: 39A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208A
	FIDOI 2 - Office 208A
	N/A Y Coordinate: N/A
X Coordinate:	N/A Y Coordinate: N/A
X Coordinate: Barrier Area:	N/A Y Coordinate: N/A  Doors or Gates
X Coordinate: Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7
X Coordinate: Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 2
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Poors or Gates  Hardware - Operation  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Poors or Gates  Hardware - Operation  2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable  Provide new hardware
X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	N/A Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable  Provide new hardware  1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 48-1/2" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
<u> </u>	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39D
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 39D Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208A
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/push 12" SEC  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/push 12" SEC  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/push 12" SEC  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/push 12" SEC  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at push side with min. 48" lacks min. 12" strike edge clearance with latch/closer
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208A N/A Y Coordinate: N/A  Doors or Gates Front App/push 12" SEC 2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at push side with min. 48" lacks min. 12" strike edge clearance with latch/closer  Chair reduces door maneuvering clearance at push side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/push 12" SEC  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at push side with min. 48" lacks min. 12" strike edge clearance with latch/closer  Chair reduces door maneuvering clearance at push side  Rearrange furniture to provide wheelchair access  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 60" - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Findings:	Desk reduces door maneuvering clearance at pull side
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39F
Field Date: Bldg Name:	6/26/2019         Report Date         9/13/2019         Barrier #:         39F           Hovland Hall         Reference Dwg:         4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208A
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Controls and Mechanisms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208A N/A Y Coordinate: N/A  Controls and Mechanisms Clear Floor Space - Stored Elements 2010 ADAS 305.3  andard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  andard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Desk blocks shelf clear floor space  Rearrange furniture to provide wheelchair access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Desk blocks shelf clear floor space  Rearrange furniture to provide wheelchair access  1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Shelves or Cabinets
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Shelf or cabinet not mounted max. 48" above floor or ground
Findings:	Shelf not accessible
Rec. Solution:	Provide additional shelf at accessible height or provide assistance
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39H
Dista Nassas	
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 208A
_	
Location:	Floor 2 - Office 208A
Location: X Coordinate:	Floor 2 - Office 208A  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Signage
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  Indard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route to room 207A
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 2 - Office 208A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route to room 207A  Provide accessible sign if furniture is rearranged and door is within circulation path  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 39
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 208A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
·	
Findings:	No tactile signage provided at door within public route  Provide accessible sign
Findings: Rec. Solution:	No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Door Closer - Interior Adjustment
Code References:	2010 ADAS 404.2.9
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Door opening force exceeds 5 lbf
Findings:	7 lbf
Rec. Solution:	Replace or adjust existing closer
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40C
	10/20/2019 Hepert Date   5/13/2019   Date: W.   1400
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Vestibule V201
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Vestibule V201 N/A Y Coordinate: N/A Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  andard: No Quantity: EACH As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Poors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  Indard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep  Replace or adjust door closer
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Doors or Gates  Door Closer - Interior Sweep Period  2010 ADAS 404.2.8.1  andard: No Quantity: EACH As-built: 0  Door closer lacks min. 5 second sweep period or does not stop 5" from door frame  3 second sweep  Replace or adjust door closer  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 57-1/2" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Relocate Door
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	No strike edge clearance at pull side
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40G
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 40G Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Vestibule V201
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign  Passageway to exterior exit with low level illuminated sign lacks tactile exit sign at vestibule  Provide sign stating "EXIT ROUTE" at exit side of door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign  Passageway to exterior exit with low level illuminated sign lacks tactile exit sign at vestibule  Provide sign stating "EXIT ROUTE" at exit side of door  2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A EXIT
Barrier Area:	Corridors
Barrier Type:	Shelves or Cabinets
Code References:	2010 ADAS 603.4
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Shelf or cabinet not mounted max. 48" above floor or ground
Findings:	Shelf not accessible
Rec. Solution:	Provide additional shelf at accessible height or provide assistance
Barrier Severity:	2 Recommended Cost Est \$75.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40I
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Floor 2 - Vestibule V201
_	
Location:	Floor 2 - Vestibule V201
Location: X Coordinate:	Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  HOV 202  EXIT
Location: X Coordinate: Barrier Area:	Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Corridors
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307
Location:  X Coordinate:  Barrier Area:  Barrier Type:  Code  References:	Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 2 - Vestibule V201  N/A  Y Coordinate:  N/A  Corridors  Protruding Object  2010 ADAS 307  ndard:  No  Quantity:  EACH  As-built:  1
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  Indard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  Shelf protrudes 7" at 66" high
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 2 - Vestibule V201  N/A  Y Coordinate: N/A  Corridors  Protruding Object  2010 ADAS 307  ndard: No Quantity: EACH As-built: 1  Protruding object in in circulation path protrudes more than 4" between 27" and 80" high  Shelf protrudes 7" at 66" high  Remove protruding object or provide detectable warning (wing walls)  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40J
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A EXIT
Barrier Area:	Controls and Mechanisms
Barrier Type:	Coat Hook - Height
Code References:	2010 ADAS 308.2
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Clothing hooks not max. 48" high AFF
Findings:	55" high
Rec. Solution:	Provide additional hook in accessible location
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 40K
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Vestibule V201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
	I .
Findings:	52" high
Findings: Rec. Solution:	52" high  Relocate switch box top edge to max. 48" high
_	Relocate switch box top edge to max. 48" high
Rec. Solution:	Relocate switch box top edge to max. 48" high  3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Sign - Braille Location
Code References:	2010 ADAS 703.3
Performance Sta	andard: No Quantity: EACH As-built: 1
Barrier Description:	Braille not 3/8" and max. 1/2" directly below the tactile characters
Findings:	Braille 1/3" below tactile characters
Rec. Solution:	Replace signage
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Stall Door Closer
Code References:	2010 ADAS 604.8.1.2
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Stall door not equipped with an automatic closing device
Findings:	Stall door not self-closing
Rec. Solution:	Replace compartment hinge with adjustable mechanism
Barrier Severity:	2 Recommended Cost Est \$1,650.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Clear Width
Code References:	2010 ADAS 404.2.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Door clear width is not min. 32"
Findings:	27-1/2" clear width
Rec. Solution:	Replace door/gate and frame
Barrier Severity:	1 Necessary Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Operating controls involve tight grasping, pinching or twisting
Findings:	Hardware not accessible. Locking mechanism not fist operable
Rec. Solution:	Replace hardware
Barrier Severity:	1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Door Clearance - Pull Side
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Door lacks min. 18" strike edge clearance at pull side
Findings:	4" strike edge clearance due to lavatory and paper towel dispenser
Rec. Solution:	Install automatic door opening device to compensate for lack of maneuvering clearance or alter
Barrier Severity:	1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Single Accommodation - In-swinging Door
Code References:	2010 ADAS 603.2.3
Performance Sta	
i cirormanec sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Space in room not adequate to allow wheelchair user to enter and close door
Barrier	
Barrier Description:	Space in room not adequate to allow wheelchair user to enter and close door
Barrier Description: Findings:	Space in room not adequate to allow wheelchair user to enter and close door  46" perpendicular from water closet to door swing  Change door swing
Barrier Description: Findings: Rec. Solution:	Space in room not adequate to allow wheelchair user to enter and close door  46" perpendicular from water closet to door swing  Change door swing  1 Necessary  Cost Est \$2,250.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Maneuvering Clearance
Code References:	2010 ADAS 603.2.1
Performance Sta	ndard: No Quantity: SF As-built: 80
Barrier Description:	Entry door encroaches into min. 60" turning space by more than 12"
Findings:	42" wide from lavatory to wall
Rec. Solution:	Remodel toilet room to provide wheelchair access
Barrier Severity:	2 Recommended Cost Est \$46,000.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Knee Clearance
Code References:	2010 ADAS 606.2 & 306
Performance Sta	indard: No Quantity: JOB As-built : 1
Barrier Description:	Lavatory bottom apron/edge not at least 27" high
Findings:	Faucet and bin blocks lavatory knee clearance
Rec. Solution:	Remount or replace lavatory
Barrier Severity:	1 Necessary Cost Est \$450.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 411
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Lavatory - Drainpipes
Code References:	2010 ADAS 606.5
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hot water and drainpipes accessible under lavatory not insulated or covered
Findings:	No insulation provided
Rec. Solution:	Insulate drainpipes and hot water pipes
Barrier Severity:	2 Recommended Cost Est \$220.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
-	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41J
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 41J Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Unisex Toilet Room 201
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Mirror  2010 ADAS 603.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Mirror  2010 ADAS 603.3
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Mirror  2010 ADAS 603.3  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Mirror  2010 ADAS 603.3  ndard: No Quantity: EACH As-built: 1  Mirror at lavatory/countertop not max. 40" AFF at edge of reflecting surface
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Mirror  2010 ADAS 603.3  ndard: No Quantity: EACH As-built: 1  Mirror at lavatory/countertop not max. 40" AFF at edge of reflecting surface  54-1/2" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Mirror  2010 ADAS 603.3  Mirror at lavatory/countertop not max. 40" AFF at edge of reflecting surface  54-1/2" high  Replace or remount mirror  3 Hindrance  Cost Est \$375.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41K
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Dispensers - Height
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Dispenser control point or operating mechanism not max. 48" AFF
Findings:	Paper towel dispenser 52" high
Rec. Solution:	Remount no higher than 48" above floor
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41L
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 41L Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Unisex Toilet Room 201
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (per-ADA)  2010 ADAS 604.8.1.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (per-ADA)  2010 ADAS 604.8.1.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (per-ADA)  2010 ADAS 604.8.1.1  ndard: No Quantity: SF As-built: 0
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (per-ADA)  2010 ADAS 604.8.1.1  ndard: No Quantity: SF As-built: 0  Min. 60" wide x 59" deep clear floor space not provided at floor-mounted fixture
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (per-ADA)  2010 ADAS 604.8.1.1  mdard: No Quantity: SF As-built: 0  Min. 60" wide x 59" deep clear floor space not provided at floor-mounted fixture  59" deep x 71" wide  Alter toilet room to provide wheelchair access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Transfer - Floor-mounted (per-ADA)  2010 ADAS 604.8.1.1  ndard: No Quantity: SF As-built: 0  Min. 60" wide x 59" deep clear floor space not provided at floor-mounted fixture  59" deep x 71" wide  Alter toilet room to provide wheelchair access  2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41M
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Toilet - Grab Bars
Code References:	2010 ADAS 604.5
Performance Sta	ndard: No Quantity: JOB As-built : 2
Barrier Description:	No grab bars provided at water closet
Findings:	No grab bars provided
Rec. Solution:	Provide side and rear grab bars with reinforcement
Barrier Severity:	1 Necessary Cost Est \$1,800.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41N
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 41N Hovland Hall Reference Dwg: 4 of 4
	The state of the s
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Unisex Toilet Room 201
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Paper Dispenser  2010 ADAS 604.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Paper Dispenser  2010 ADAS 604.7
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Paper Dispenser  2010 ADAS 604.7  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Y Coordinate: N/A  Restrooms  Toilet Paper Dispenser  2010 ADAS 604.7  ndard: No Quantity: EACH As-built: 1  Toilet tissue dispenser not within 7" to 9" from front edge of toilet
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Restrooms  Toilet Paper Dispenser  2010 ADAS 604.7  Indiard: No Quantity: EACH As-built: 1  Toilet tissue dispenser not within 7" to 9" from front edge of toilet  Dispenser not within 7" to 9" from front edge of toilet
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Unisex Toilet Room 201  N/A  Restrooms  Toilet Paper Dispenser  2010 ADAS 604.7  Indiard: No Quantity: EACH As-built: 1  Toilet tissue dispenser not within 7" to 9" from front edge of toilet  Dispenser not within 7" to 9" from front edge of toilet  Reposition or replace toilet paper dispenser  3 Hindrance Cost Est \$225.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 410
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Seat Cover Dispenser
Code References:	2010 ADAS 307.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Seat cover dispenser not located on an accessible route. Blocked by water closet
Findings:	Access to dispenser blocked by water closet
Rec. Solution:	Replace or remount dispenser on an accessible route with clear floor space
Barrier Severity:	2 Recommended Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 41P
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Unisex Toilet Room 201
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Restrooms
Barrier Type:	Alarm - Horn/Strobe
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Where a fire alarm is installed, no horn/strobe provided
Findings:	No device provided
Rec. Solution:	Provide horn/strobe in sanitary facility
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 42A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Floor Surface - Slope
Code References:	2010 ADAS 302 & 303
Performance Sta	andard: No Quantity: SF As-built : 20
Barrier Description:	Floor surface slope exceeds 2.0%
Findings:	5.5% slope in corridor at control point for electrical switch and fire extinguisher
Rec. Solution:	Remodel to provide level clear floor space at controls/mechanisms
Barrier Severity:	2 Necessary Cost Est \$11,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 42B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Area: Barrier Type:	
	Corridors
Barrier Type: Code	Corridors Electrical Switches - High Unobstructed 2010 ADAS 308.2.1
Barrier Type: Code References:	Corridors  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1
Barrier Type: Code References: Performance Sta Barrier	Corridors  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1  andard: No Quantity: EACH As-built: 1
Barrier Type: Code References: Performance Sta Barrier Description:	Corridors  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1  andard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high
Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Corridors  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1  Indard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high  52" high  Relocate switch box top edge to max. 48" high
Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Corridors  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1  Indard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high  S2" high  Relocate switch box top edge to max. 48" high  3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 42C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Corridor H203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Corridors
Barrier Type:	Strobe
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No strobe provided in corridor where horn is provided where fire alarm exists in building
Findings:	No strobe where horn is provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 207A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 207A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible. Locking mechanism not fist operable
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 207A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 45" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	2 Uindowes Cost Est (2.250.00 Facility Function: Bublis Status: Once
Implementation	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
impiementation	Priority: 2 Implementation Phase: Implementation Date:



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 207A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Landing - Existing (2.1% to 3.0%)
Code References:	2010 ADAS 404.2.4.4
Performance Sta	ndard: No Quantity: SF As-built : 20
Barrier Description:	Door or gate lacks landing on both sides of door
Findings:	2.2% slope
Rec. Solution:	Demolish and reconstruct level landing
Barrier Severity:	4 Low Severity Cost Est \$2,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
, , , , , , , , , , , , , , , , , , ,	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43E
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 43E  Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Graduate Student Office 207A
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  No strike edge clearance due to desk  Rearrange furniture to provide wheelchair access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  No strike edge clearance due to desk  Rearrange furniture to provide wheelchair access  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 207A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Desk blocks electrical switch clear floor space
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
And the second s	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43G
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 43G Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Graduate Student Office 207A
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route to 208A  Provide accessible sign if door is within public circulation path
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 207A  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route to 208A  Provide accessible sign if door is within public circulation path  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 43H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 207A
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44A
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 44A  Hovland Hall Reference Dwg: 4 of 4
	The state of the s
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Service & Break Room 207
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  ISA - Non-Accessible Entry  2010 ADAS 216.6
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  ISA - Non-Accessible Entry  2010 ADAS 216.6
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  ISA - Non-Accessible Entry  2010 ADAS 216.6  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  ISA - Non-Accessible Entry  2010 ADAS 216.6  Indard: No Quantity: EACH As-built: 1  Sign directing people to accessible entrance needed where all doors are not accessible
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Signage  ISA - Non-Accessible Entry  2010 ADAS 216.6  Isign directing people to accessible entrance needed where all doors are not accessible  ISA directional sign not provided at non-accessible door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  ISA - Non-Accessible Entry  2010 ADAS 216.6  Sign directing people to accessible entrance needed where all doors are not accessible  ISA directional sign not provided at non-accessible door  Provide ISA directional sign indicating location of accessible entrance where two entry doors ar 1 Necessary  Cost Est \$250.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
	View panel 45-1/2" high
Findings:	Their paner is 1/2 mgm
Findings: Rec. Solution:	Replace door/gate or vision panel
_	Replace door/gate or vision panel
Rec. Solution:	Replace door/gate or vision panel  3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built: 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	ISA - Accessible Entry Door
Code References:	2010 ADAS 216.6
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No sign identifying door as accessible where all doors are not accessible
Findings:	No sign provided to indicate that entrance is accessible
Rec. Solution:	Provide ISA directional sign at one door where two entry doors are provided and ISA sign at oth
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	andard: No Quantity: EACH As-built : 2
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible. Locking mechanism not fist operable
Rec. Solution:	Provide new hardware at door intended to be accessible where 2 entry doors are provided
Barrier Severity:	1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 52" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44I
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 44I Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign  Passageway to exterior exit lacks tactile exit sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Passage  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Exit thru an exit enclosure/exit passageway lacks tactile exit sign  Passageway to exterior exit lacks tactile exit sign  Provide sign stating "EXIT ROUTE" at exit side of door  2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44J
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Actuator/Control - Fist Operable
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not usable with a closed fist
Findings:	Knob not fist operable
Rec. Solution:	Replace operating control
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44K
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Shelf blocks electrical switch clear floor space
Rec. Solution:	Move shelf
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



	6/26/2019 Report Date 9/13/2019 Barrier #: 44L
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
Findings:	52" high
Rec. Solution:	Relocate switch box top edge to max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44M
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 44M Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Service & Break Room 207
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Clear Floor Space
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Clear Floor Space  Passageway - Min. 36" (Stored Item)  2010 ADAS 403.5.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Clear Floor Space  Passageway - Min. 36" (Stored Item)  2010 ADAS 403.5.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Clear Floor Space  Passageway - Min. 36" (Stored Item)  2010 ADAS 403.5.1  Indard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Clear Floor Space  Passageway - Min. 36" (Stored Item)  2010 ADAS 403.5.1  Indard: No Quantity: JOB As-built: 1  Circulation route not min. 36" wide between elements
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Clear Floor Space  Passageway - Min. 36" (Stored Item)  2010 ADAS 403.5.1  Indard: No Quantity: JOB As-built: 1  Circulation route not min. 36" wide between elements  Min. 36" wide circulation route not provided  Rearrange furniture to provide wheelchair access
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Service & Break Room 207  N/A  Y Coordinate: N/A  Clear Floor Space  Passageway - Min. 36" (Stored Item)  2010 ADAS 403.5.1  Indard: No Quantity: JOB As-built: 1  Circulation route not min. 36" wide between elements  Min. 36" wide circulation route not provided  Rearrange furniture to provide wheelchair access  1 Necessary  Cost Est \$0.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 44N
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Shelves or Cabinets
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Shelf or cabinet not mounted max. 48" above floor or ground
Findings:	Shelf not accessible
Rec. Solution:	Provide additional shelf at accessible height or provide assistance
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 440
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Service & Break Room 207
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn - No Strobe
Code References:	2010 ADAS 702
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Horn provided in location where no strobe is provided
Findings:	No strobe device provided
Rec. Solution:	Provide strobe in common use area
Barrier Severity:	1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 45A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 206
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 45B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Graduate Student Office 206
_	
Location:	Floor 2 - Graduate Student Office 206
Location: X Coordinate:	Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A
Location: X Coordinate: Barrier Area:	Floor 2 - Graduate Student Office 206  N/A Y Coordinate: N/A  Doors or Gates
Location: X Coordinate: Barrier Area: Barrier Type: Code	Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7
Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Floor 2 - Graduate Student Office 206  N/A  Y Coordinate:  N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  Indard:  No  Quantity:  EACH  As-built:  2
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  Indard: No  Quantity: EACH  As-built: 2  Hardware not operable with a closed fist
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable  Provide new hardware
Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  Indard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable  Provide new hardware  1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 45C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 206
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 46" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 45D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 206
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	
	Doors or Gates
Barrier Type:	Doors or Gates  Front App/pull 18" SEC - Blocked
Barrier Type: Code References:	
Code	Front App/pull 18" SEC - Blocked 2010 ADAS Figure 404.2.4.1
Code References: Performance Sta Barrier	Front App/pull 18" SEC - Blocked 2010 ADAS Figure 404.2.4.1
Code References:	Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1
Code References: Performance Sta Barrier Description: Findings:	Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Code References: Performance Sta Barrier Description: Findings:	Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  Trash bin blocks strike edge clearance at pull side
Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  Indard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  Trash bin blocks strike edge clearance at pull side  Move trash bin  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



6/26/2019 Report Date 9/13/2019 Barrier #: 45E
Hovland Hall Reference Dwg: 4 of 4
Floor 2 - Graduate Student Office 206
N/A Y Coordinate: N/A
Doors or Gates
Front App/pull 60" - Blocked
2010 ADAS Figure 404.2.4.1
andard: No Quantity: ADMINI As-built : 1
Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Desk reduces door maneuvering clearance at pull side
Rearrange furniture to provide wheelchair access
: 1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Priority: 2 Implementation Phase: Implementation Date:
6/26/2019 Report Date 9/13/2019 Barrier #: 45F
6/26/2019 Report Date 9/13/2019 Barrier #: 45F Hovland Hall Reference Dwg: 4 of 4
THE PROPERTY OF THE PROPERTY O
Hovland Hall Reference Dwg: 4 of 4
Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Graduate Student Office 206
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Controls and Mechanisms
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  andard: No Quantity: JOB As-built: 1
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  andard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  andard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Trash bin and cabinet blocks electrical switch clear floor space
Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 206  N/A  Y Coordinate: N/A  Controls and Mechanisms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  andard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Trash bin and cabinet blocks electrical switch clear floor space  Move stored items



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 45G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 206
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Clear Floor Space
Barrier Type:	Clear Floor Space - Wheelchair Use
Code References:	CBC 11B-305 and 2010 ADAS 203.9 & 305
Performance Sta	andard: No Quantity: JOB As-built: 1
Barrier Description:	Clear floor space of min. 30" by 48" not provided
Findings:	Clear floor space for individuals with disabilities not provided
Rec. Solution:	Move stored items or alter space so individuals with disabilities can approach, enter and exit sp
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 45H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 206
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 46A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 205
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 46B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 205
X Coordinate:	
x coordinate:	N/A Y Coordinate: N/A
Barrier Area:	N/A Y Coordinate: N/A  Doors or Gates
Barrier Area:	Doors or Gates
Barrier Area: Barrier Type: Code	Doors or Gates Hardware - Operation 2010 ADAS 404.2.7
Barrier Area: Barrier Type: Code References:	Doors or Gates Hardware - Operation 2010 ADAS 404.2.7
Barrier Area: Barrier Type: Code References: Performance Sta Barrier	Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 2
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Doors or Gates  Hardware - Operation  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable
Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Doors or Gates Hardware - Operation  2010 ADAS 404.2.7  ndard: No Quantity: EACH As-built: 2  Hardware not operable with a closed fist  Hardware not accessible. Locking mechanism not fist operable  Provide new hardware  1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 46C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 205
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Findings:	View panel 46" high
Rec. Solution:	Replace door/gate or vision panel
Barrier Severity:	3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 46D
	6/26/2019 Report Date 9/13/2019 Barrier #: 46D Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 205
Field Date: Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Relocate Door  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Relocate Door  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Relocate Door  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Relocate Door  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Doors or Gates  Front App/pull 18" SEC - Relocate Door  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  7" strike edge clearance. Shelf blocks door maneuvering clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Relocate Door  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: EACH As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  7" strike edge clearance. Shelf blocks door maneuvering clearance at pull side  Install automatic door opening device to compensate for lack of maneuver clearance  1 Necessary Cost Est \$5,000.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 46E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 205
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 60" - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Findings:	Shelf blocks maneuvering clearance at pull side
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
· · · · · · · · · · · · · · · · · · ·	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 46F
	6/26/2019 Report Date 9/13/2019 Barrier #: 46F Hovland Hall Reference Dwg: 4 of 4
Field Date: Bldg Name: Location:	
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Office 205
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Clear Floor Space
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20  Floor surface slope exceeds 2.0%
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20  Floor surface slope exceeds 2.0%  3.0% slope  Remodel to provide level clear floor space at controls/mechanisms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Office 205  N/A  Y Coordinate: N/A  Clear Floor Space  Floor Surface - Slope  2010 ADAS 302 & 303  ndard: No Quantity: SF As-built: 20  Floor surface slope exceeds 2.0%  3.0% slope  Remodel to provide level clear floor space at controls/mechanisms  2 Necessary Cost Est \$11,500.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 46G
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Office 205
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 47A
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 47A Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Graduate Student Office 204
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Graduate Student Office 204  N/A  Y Coordinate: N/A  Signage  Permanent Room/Space - Tactile Characters  2010 ADAS 216.2  ndard: No Quantity: EACH As-built: 1  No tactile characters at sign identifying permanent rooms and spaces with visual signs  No tactile signage provided at door within public route  Provide accessible sign  1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 47B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 204
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 2
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible. Locking mechanism not fist operable
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$600.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 47C
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 204
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/push 48"
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	indard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at push side with min. 18" lacks min. 48" perpendicular to door
Findings:	Chair block door maneuvering clearance at push side
Rec. Solution:	
Barrier Severity:	Relocate chair
barrier severity.	
Implementation	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
•	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 47D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 204
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 60" - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	ndard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Findings:	Chair reduces door maneuvering clearance
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 47E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 204
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
Findings:	49" high
Rec. Solution:	Relocate switch box top edge to max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 47F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Graduate Student Office 204
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48A
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	ndard: No Quantity: EACH As-built: 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route
Rec. Solution:	Provide accessible sign
Barrier Severity:	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48C
	0/20/2015 Report Batte 3/13/2015 Battlet II. 460
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Post-Doc & Graduate Student Office 203
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Doors or Gates  Door 10" Bottom Surface - Kickplate  2010 ADAS 404.2.10
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Doors or Gates  Door 10" Bottom Surface - Kickplate  2010 ADAS 404.2.10
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Doors or Gates  Door 10" Bottom Surface - Kickplate  2010 ADAS 404.2.10  Indard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Doors or Gates  Door 10" Bottom Surface - Kickplate  2010 ADAS 404.2.10  Indard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Doors or Gates  Door 10" Bottom Surface - Kickplate  2010 ADAS 404.2.10  andard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface  Bottom of door not smooth and uninterrupted. 9" high to vent  Provide smooth kick plate min. 10" high at push side of door
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Doors or Gates  Door 10" Bottom Surface - Kickplate  2010 ADAS 404.2.10  Indard: No Quantity: EACH As-built: 1  Door/Gate lacks min. 10" smooth uninterrupted bottom surface  Bottom of door not smooth and uninterrupted. 9" high to vent  Provide smooth kick plate min. 10" high at push side of door  1 Necessary Cost Est \$225.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 18" SEC - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Findings:	Cabinet blocks maneuvering clearance at pull side
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48E
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Cabinet blocks electrical switch clear floor space
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Electrical Switches - Height
Code References:	2010 ADAS 308.2
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Light switch control box top edge not at max. 48" high
Findings:	68" high
Rec. Solution:	Relocate switch box top edge to max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Ciald Date	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48G
Field Date: Bldg Name:	6/26/2019   Report Date   9/13/2019   Barrier #:   48G   Hovland Hall   Reference Dwg:   4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Clear Floor Space
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  CBC 11B-305 and 2010 ADAS 203.9 & 305
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  CBC 11B-305 and 2010 ADAS 203.9 & 305
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  CBC 11B-305 and 2010 ADAS 203.9 & 305  ndard: No Quantity: JOB As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  CBC 11B-305 and 2010 ADAS 203.9 & 305  ndard: No Quantity: JOB As-built: 1  Clear floor space of min. 30" by 48" not provided
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  CBC 11B-305 and 2010 ADAS 203.9 & 305  ndard: No Quantity: JOB As-built: 1  Clear floor space of min. 30" by 48" not provided  Clear floor space for people who use wheelchairs not provided
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Post-Doc & Graduate Student Office 203  N/A  Y Coordinate: N/A  Clear Floor Space  Clear Floor Space - Wheelchair Use  CBC 11B-305 and 2010 ADAS 203.9 & 305  ndard: No Quantity: JOB As-built: 1  Clear floor space of min. 30" by 48" not provided  Clear floor space for people who use wheelchairs not provided  Move stored items or alter space so individuals with disabilities can approach, enter and exit sp  1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48H
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Hardware - Operation
Code References:	2010 ADAS 404.2.7
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Hardware not operable with a closed fist
Findings:	Hardware not accessible at door to corridor
Rec. Solution:	Provide new hardware
Barrier Severity:	1 Necessary Cost Est \$300.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48I
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Vision Lights - Existing
Code References:	2010 ADAS 404.2.11
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier	
Description:	View panels in or adjacent to doors or gates not max. 43" above floor or ground
Description: Findings:	View panels in or adjacent to doors or gates not max. 43" above floor or ground  View panel 53-1/2" high at door to corridor
·	
Findings:	View panel 53-1/2" high at door to corridor  Replace door/gate or vision panel
Findings: Rec. Solution:	View panel 53-1/2" high at door to corridor  Replace door/gate or vision panel  3 Hindrance Cost Est \$2,250.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48J
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Doors or Gates
Barrier Type:	Front App/pull 60" - Blocked
Code References:	2010 ADAS Figure 404.2.4.1
Performance Sta	andard: No Quantity: ADMINI As-built : 1
Barrier Description:	Door/Gate at with min. 18" at pull side lacks min. 60" perpendicular to door
Findings:	Desk reduce door maneuvering clearance at pull side at door to corridor
Rec. Solution:	Rearrange furniture to provide wheelchair access
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48K
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Permanent Room/Space - Tactile Characters
Code References:	2010 ADAS 216.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	No tactile characters at sign identifying permanent rooms and spaces with visual signs
Findings:	No tactile signage provided at door within public route from corridor H203
Rec. Solution:	Provide accessible sign
Barrier Severity:	
barrier severity.	1 Necessary Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 48L
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Post-Doc & Graduate Student Office 203
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Alarms
Barrier Type:	Horn/Strobe - Staff Area
Code References:	2010 ADAS 702.1
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	No horn/strobe in staff areas
Findings:	No device provided
Rec. Solution:	Provide horn/strobe where programs, services and activities take place
Barrier Severity:	3 Hindrance Cost Est \$5,500.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Et al la Davida	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49A
Field Date: Bldg Name:	6/26/2019   Report Date   9/13/2019   Barrier #:   49A   Hovland Hall   Reference Dwg:   4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  mdard: No Quantity: EACH As-built: 1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1   Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  63-1/2" high and Braille 1/3" directly below the tactile characters
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Location - 48" to 60" high  2010 ADAS 703.4.1  Braille/Tactile information on sign not mounted between 48" and 60" from ground or floor  63-1/2" high and Braille 1/3" directly below the tactile characters  Provide Braille/tactile sign at latch side of door  1 Necessary  Cost Est \$250.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49B
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Signage
Barrier Type:	Tactile Exit Signs - Passage
Code References:	Performance Standard
Performance Sta	ndard: Yes Quantity: EACH As-built : 1
Barrier Description:	Exit thru an exit enclosure/exit passageway lacks tactile exit sign
Findings:	Passageway to exterior exit with low level illuminated sign lacks tactile exit sign
Rec. Solution:	Provide sign stating "EXIT ROUTE" at exit side of door
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 3 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49C
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 49C Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Doors or Gates
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  Trash bins block door maneuvering clearance at pull side
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Doors or Gates  Front App/pull 18" SEC - Blocked  2010 ADAS Figure 404.2.4.1  ndard: No Quantity: ADMINI As-built: 1  Door/Gate at pull side with min. 60" lacks min. 18" strike edge clearance at pull side  Trash bins block door maneuvering clearance at pull side  Remove trash bins  1 Necessary  Cost Est \$0.00  Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49D
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Controls and Mechanisms
Barrier Type:	Clear Floor Space - Stored Elements
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: JOB As-built : 1
Barrier Description:	Clear floor space for wheelchair not provided at control or mechanism
Findings:	Trash bin blocks switch and pencil sharpener clear floor space
Rec. Solution:	Remove trash bins
Barrier Severity:	1 Necessary Cost Est \$125.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49E
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 49E  Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1  ndard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1  ndard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202 N/A Y Coordinate: N/A  Classrooms Electrical Switches - High Unobstructed 2010 ADAS 308.2.1  ndard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high  51" high
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Electrical Switches - High Unobstructed  2010 ADAS 308.2.1  Indard: No Quantity: EACH As-built: 1  Light switch control box top edge not at max. 48" high  51" high  Relocate switch box top edge to max. 48" high  3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49F
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	Pencil sharpener 64" high
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49G
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 49G Hovland Hall Reference Dwg: 4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Classrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance State Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall  Pencil sharpener protrudes 4-1/2" at 60" high  Remove protruding object or provide detectable warning for the visually impaired
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall  Pencil sharpener protrudes 4-1/2" at 60" high  Remove protruding object or provide detectable warning for the visually impaired  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Bldg Name: Hovland Hall Reference Dwg:	*#:  49H
5	4 of 4
Location: Floor 2 - Classroom 202	
X Coordinate: N/A Y Coordinate: N/A	
Barrier Area: Assembly Areas	
Barrier Type: Shared Assistive Listening System	
Code Performance Standard References:	
Performance Standard: Yes Quantity: EACH As-built	: 1
Barrier No shared assistive listening system for room volume.  Description:	with min. 10 seats
No system provided in classroom providing 36 Findings:	seats
Rec. Solution: Provide shared ALS system with signage	
Barrier Severity: 2 Recommended Cost Est \$750.00	Facility Function: Public Status: Open
Implementation Priority: 2 Implementation Phase:	Implementation Date:
Notes:	
Field Date: 6/26/2019 Report Date 9/13/2019 Barrier	r#:   491
	The second secon
Bldg Name: Hovland Hall Reference Dwg:	The second secon
Bldg Name: Hovland Hall Reference Dwg:	The second secon
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A	The second secon
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms	The second secon
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms	The second secon
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Desk - Ratio  Code 2010 ADAS 902	4 of 4
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Desk - Ratio  Code References:	4 of 4 : 1
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Desk - Ratio  Code 2010 ADAS 902  References:  Performance Standard: No Quantity: EACH As-built  Barrier At least 1 desk or 5% of all desks not accessible	4 of 4  : 1
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Desk - Ratio  Code 2010 ADAS 902  References: Performance Standard: No Quantity: EACH As-built  Barrier Description: At least 1 desk or 5% of all desks not accessible a	4 of 4  : 1
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Desk - Ratio  Code 2010 ADAS 902  References: Performance Standard: No Quantity: EACH As-built  Barrier Description: At least 1 desk or 5% of all desks not accessible accessible accessible for the standard of the st	4 of 4  : 1
Bldg Name: Hovland Hall Reference Dwg: Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Desk - Ratio  Code 2010 ADAS 902  References:  Performance Standard: No Quantity: EACH As-built  Barrier Description:  At least 1 desk or 5% of all desks not accessible desk  Findings:  Rec. Solution: Provide 1 additional accessible desk	4 of 4  i limit to the state of



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49J
Bldg Name:	
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Desk - Knee Clearance
Code References:	2010 ADAS 902
Performance Sta	ndard: No Quantity: EACH As-built: 0
Barrier Description:	Knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	28" wide knee clearance at desk by door
Rec. Solution:	Provide min. 2 accessible desks
Barrier Severity:	1 Necessary Cost Est \$0.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49K
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Assembly Areas
Barrier Type:	Signage
Code References:	Performance Standard
Performance Sta	andard: Yes Quantity: EACH As-built : 1
Barrier Description:	No ISA sign identifying wheelchair seating spaces
Findings:	No ISA sign provided
Rec. Solution:	Replace signage
Barrier Severity:	2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	S / S / S / S / S / S / S / S / S / S /
511 1	6/26/2019 Report Date 9/13/2019 Barrier #: 49L
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Desk - Integration
Code References:	2010 ADAS 307.2
Performance Sta	andard: No Quantity: EACH As-built : 1
Barrier Description:	Desk not integrated into assembly seating
Findings:	Desk identified as accessible is not integrated into typical seating
Rec. Solution:	Move desk to integrated setting
Barrier Severity:	2 Necessary Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
· · · · · · · · · · · · · · · · · · ·	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49M
Field Date: Bldg Name:	6/26/2019   Report Date   9/13/2019   Barrier #:   49M   Hovland Hall   Reference Dwg:   4 of 4
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Classrooms
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall  Monitor protrudes 6" at 63" high  Remove protruding object or provide detectable warning for the visually impaired
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Protruding Object - Wall-mounted  2010 ADAS 307.2  andard: No Quantity: EACH As-built: 1  Wall mounted object protrudes more than 4" from wall  Monitor protrudes 6" at 63" high  Remove protruding object or provide detectable warning for the visually impaired  1 Necessary Cost Est \$550.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49N
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Code References:	2010 ADAS 305.3
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high
Findings:	Monitor and screen controls 48-1/2" high
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 490
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Location:	Floor 2 - Classroom 202
X Coordinate:	N/A Y Coordinate: N/A
Barrier Area:	Classrooms
Barrier Type:	Desk - Knee Clearance
Code References:	2010 ADAS 902
Performance Sta	ndard: No Quantity: EACH As-built : 1
Barrier Description:	Knee clearance not min. 27" high, 19" deep or 30" wide
Findings:	Instructional desk 29" wide knee clearance
Rec. Solution:	Reposition desk to provide knee clearance
Barrier Severity:	1 Necessary Cost Est \$875.00 Facility Function: Public Status: Open
Implementation	Priority: 2 Implementation Phase: Implementation Date:
Notes:	



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49P				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Clear Floor Space				
Barrier Type:	Floor Surface - Slope				
Code References:	2010 ADAS 302 & 303				
Performance Sta	ndard: No Quantity: SF As-built : 20				
Barrier Description:	Floor surface slope exceeds 2.0%				
Findings:	11.9% slope				
Rec. Solution:	Remodel to provide level clear floor space at controls/mechanisms				
Barrier Severity:	2 Necessary Cost Est \$11,500.00 Facility Function: Public Status: Open				
Implementation	Priority: 2 Implementation Phase: Implementation Date:				
Notes:					
Et al la Data					
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49Q				
Field Date: Bldg Name:	6/26/2019   Report Date   9/13/2019   Barrier #:   49Q   Hovland Hall   Reference Dwg:   4 of 4				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202				
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A				
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Clear Floor Space - Stored Elements  2010 ADAS 305.3				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Clear Floor Space - Stored Elements  2010 ADAS 305.3				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  ndard: No Quantity: JOB As-built: 1				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Instructional desk blocks electrical switch, phone, and fan switch clear floor space				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Classrooms  Clear Floor Space - Stored Elements  2010 ADAS 305.3  Indard: No Quantity: JOB As-built: 1  Clear floor space for wheelchair not provided at control or mechanism  Instructional desk blocks electrical switch, phone, and fan switch clear floor space  Rearrange desk to provide wheelchair access  3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open				



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49R				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Classrooms				
Barrier Type:	Electrical Switches - High Unobstructed				
Code References:	2010 ADAS 308.2.1				
Performance Sta	ndard: No Quantity: EACH As-built : 1				
Barrier Description:	Light switch control box top edge not at max. 48" high				
Findings:	58" high				
Rec. Solution:	Relocate switch box top edge to max. 48" high				
Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open				
Implementation	Priority: 2 Implementation Phase: Implementation Date:				
Notes:					
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49S				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Classrooms				
Barrier Type:	Actuator/Control - Side Reach High Unobstructed				
Code References:	2010 ADAS 305.3				
Performance Sta	ndard: No Quantity: EACH As-built : 1				
Barrier Description:	Control or mechanism not at min. 15" or max. 48" high				
Findings:	Fan control point 57-1/2" high				
Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high				
Barrier Severity:					
Implementation					
Notes:					



Bildg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Classroom 202 X Coordinate: N/A Y Coordinate: N/A Barrier Area: Classrooms Barrier Type: Actuator/Control - Side Reach High Unobstructed Code References: Performance Standard: No Quantity: EACH As-built: 1 Barrier Description: Emergency phone 49" high Findings: Emergency phone 49" high Emergency phone 49" high Emergency phone 49" high Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date: Notes:  Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U Bildg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Classroom 202 X Coordinate: N/A Y Coordinate: N/A Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code 2010 ADAS 504.2 References: Performance Standard: No Quantity: EACH As-built: 1 Barrier Description: No knee clearance not min. 27" high, 19" deep or 30" wide  Performance Standard: No No knee clearance provided Findings: No knee clearance provided  Findings: Implementation Priority: 2 Implementation Phase: Implementation Date: Notes: Implementation Date: Implementation Date: Implemen	Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49T
A Coordinate: Barrier Area: Classrooms Barrier Type: Actuator/Control - Side Reach High Unobstructed Code 2010 ADAS 305.3 References: Performance Standard: No Quantity: EACH As-built: 1  Barrier Description: Emergency phone 49" high Findings: Rec. Solution: Relocate control or mechanism to min. 15" or max. 48" high Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Priority: 1 Implementation Date:  Notes:  Field Date: Bldg Name: Hovland Hall Reference Dwg: 4 of 4  ELocation: Floor 2 - Classroom 202 X Coordinate: N/A Y Coordinate: N/A PY Coordinate: N/A Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code 2010 ADAS 504.2 References: Performance Standard: No Quantity: EACH As-built: 1  Barrier Description: No knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided Findings: Rec. Solution: Provide min. 1 accessible podium Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Barrier Area: Classrooms Barrier Type: Actuator/Control - Side Reach High Unobstructed Code References: Performance Standard: No Quantity: EACH As-built: 1  Barrier Description: Emergency phone 49" high Findings: Emergency phone 49" high Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date: Produm Knee Clearance Code References: N/A Y Coordinate: N/A Barrier Type: Podium - Knee Clearance Code References: Performance Standard: No Quantity: EACH As-built: 1  Barrier Podium - Knee Clearance Code References: Podium - Knee Clearance Code Reference Description: Podium - Knee Clearance Code References: Podium - Knee Clearance References: Podium - Knee Cle	Location:	Floor 2 - Classroom 202
Barrier Type: Actuator/Control - Side Reach High Unobstructed Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  Emergency phone 49" high  Findings:  Rec. Solution: Relocate control or mechanism to min. 15" or max. 48" high  Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:  Notes:  Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U  Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description: No knee clearance not min. 27" high, 19" deep or 30" wide  Findings:  Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	X Coordinate:	N/A Y Coordinate: N/A
Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  Emergency phone 49" high  Findings:  Rec. Solution: Relocate control or mechanism to min. 15" or max. 48" high  Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:  Notes:  Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U  Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Podium - Knee Clearance  Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  No knee clearance not min. 27" high, 19" deep or 30" wide  Prindings:  Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Barrier Area:	Classrooms
References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  Emergency phone 49" high  Findings:  Rec. Solution: Relocate control or mechanism to min. 15" or max. 48" high  Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:  Notes:  Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U  Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Barrier Area: Classrooms  Barrier Type: Podium - Knee Clearance  Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  No knee clearance provided  Findings:  Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Barrier Type:	Actuator/Control - Side Reach High Unobstructed
Barrier Description:  Emergency phone 49" high  Emergency phone 49" high  Emergency phone 49" high  Emergency phone 49" high  Barrier Severity:  Rec. Solution:  Relocate control or mechanism to min. 15" or max. 48" high  Barrier Severity:  3 Hindrance  Cost Est \$750.00  Facility Function:  Public  Status: Open  Implementation Priority:  2 Implementation Phase:  Implementation Date:  Notes:  Field Date:  6/26/2019 Report Date 9/13/2019 Barrier #: 49U  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  X Coordinate:  N/A  Y Coordinate:  N/A  Y Coordinate:  N/A  Performance Standard:  Podium - Knee Clearance  Code  References:  Performance Standard:  No Quantity:  FACH As-built:  No knee clearance not min. 27" high, 19" deep or 30" wide  Description:  No knee clearance provided  Findings:  Rec. Solution:  Provide min. 1 accessible podium  Barrier Severity:  4 Low Severity  Cost Est \$1,275.00  Facility Function:  Public  Status: Open  Implementation Priority:  2 Implementation Phase:  Implementation Date:		2010 ADAS 305.3
Emergency phone 49" high  Emergency proposed in public status: Open  Emplementation Priority: 2 Implementation Phase: Implementation Date:	Performance Sta	ndard: No Quantity: EACH As-built : 1
Findings:  Rec. Solution: Relocate control or mechanism to min. 15" or max. 48" high Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date: Notes:  Field Date: Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code References: Performance Standard: Ro Quantity: EACH As-built: Description:  No knee clearance provided  No knee clearance provided  Findings: Rec. Solution: Provide min. 1 accessible podium Barrier Severity: A Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:		Control or mechanism not at min. 15" or max. 48" high
Barrier Severity: 3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:  Notes:  Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Classroom 202 X Coordinate: N/A Y Coordinate: N/A Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code 2010 ADAS 504.2 References:  Performance Standard: No Quantity: EACH As-built: 1 Barrier Description:  No knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided  Findings:  Rec. Solution: Provide min. 1 accessible podium Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Findings:	Emergency phone 49" high
Implementation Priority: 2 Implementation Phase: Implementation Date:  Notes:  Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Classroom 202 X Coordinate: N/A Y Coordinate: N/A Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code References:  Performance Standard: No Quantity: EACH As-built: 1 Barrier Description:  No knee clearance not min. 27" high, 19" deep or 30" wide Description:  No knee clearance provided  Findings:  Rec. Solution: Provide min. 1 accessible podium Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Rec. Solution:	Relocate control or mechanism to min. 15" or max. 48" high
Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Classroom 202 X Coordinate: N/A Y Coordinate: N/A Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code References: Performance Standard: No Quantity: EACH As-built: 1 Barrier Description: No knee clearance not min. 27" high, 19" deep or 30" wide Findings: Rec. Solution: Provide min. 1 accessible podium Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Barrier Severity:	3 Hindrance Cost Est \$750.00 Facility Function: Public Status: Open
Field Date: 6/26/2019 Report Date 9/13/2019 Barrier #: 49U  Bldg Name: Hovland Hall Reference Dwg: 4 of 4  Location: Floor 2 - Classroom 202  X Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Podium - Knee Clearance  Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  No knee clearance not min. 27" high, 19" deep or 30" wide  Findings:  Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Implementation	Priority: 2 Implementation Phase: Implementation Date:
Bldg Name: Hovland Hall Reference Dwg: 4 of 4 Location: Floor 2 - Classroom 202 X Coordinate: N/A Y Coordinate: N/A Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code 2010 ADAS 504.2 References: Performance Standard: No Quantity: EACH As-built: 1 Barrier Description: No knee clearance not min. 27" high, 19" deep or 30" wide Findings: Rec. Solution: Provide min. 1 accessible podium Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Notes:	
Location:  Floor 2 - Classroom 202  X Coordinate:  N/A  Parrier Area:  Classrooms  Barrier Type:  Podium - Knee Clearance  2010 ADAS 504.2  Performance Standard:  Performance Standard:  Podium knee clearance not min. 27" high, 19" deep or 30" wide  Description:  No knee clearance provided  Findings:  Rec. Solution:  Provide min. 1 accessible podium  Barrier Severity:  4 Low Severity  Cost Est \$1,275.00  Facility Function:  Public Status: Open  Implementation Priority: 2 Implementation Phase:	Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49U
A Coordinate: N/A Y Coordinate: N/A  Barrier Area: Classrooms  Barrier Type: Podium - Knee Clearance  Code 2010 ADAS 504.2  References: Performance Standard: No Quantity: EACH As-built: 1  Barrier Description: No knee clearance not min. 27" high, 19" deep or 30" wide  Findings: No knee clearance provided  Findings: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Bldg Name:	Hovland Hall Reference Dwg: 4 of 4
Barrier Area: Classrooms Barrier Type: Podium - Knee Clearance Code References: Performance Standard: No Quantity: EACH As-built: 1  Barrier Description: Podium knee clearance not min. 27" high, 19" deep or 30" wide  Findings: No knee clearance provided  Findings: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	Location	
Barrier Type: Podium - Knee Clearance  Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  No knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided  Findings:  Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	LUCALIUII.	JHOOR 2 - Classroom 202
Code References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier Description:  No knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided  Findings:  Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:		
References:  Performance Standard: No Quantity: EACH As-built: 1  Barrier	X Coordinate:	N/A Y Coordinate: N/A
Podium knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided  Findings:  Rec. Solution:  Provide min. 1 accessible podium  Barrier Severity:  4 Low Severity  Cost Est \$1,275.00  Facility Function:  Public Status: Open  Implementation Priority:  Implementation Date:	X Coordinate: Barrier Area:	N/A Y Coordinate: N/A Classrooms
No knee clearance provided  Findings:  Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open  Implementation Priority: 2 Implementation Phase: Implementation Date:	X Coordinate: Barrier Area: Barrier Type: Code	N/A Y Coordinate: N/A  Classrooms  Podium - Knee Clearance
Rec. Solution: Provide min. 1 accessible podium  Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open  Implementation Priority: 2 Implementation Phase: Implementation Date:	X Coordinate: Barrier Area: Barrier Type: Code References:	N/A Y Coordinate: N/A  Classrooms  Podium - Knee Clearance  2010 ADAS 504.2
Barrier Severity: 4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open Implementation Priority: 2 Implementation Phase: Implementation Date:	X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier	N/A Y Coordinate: N/A  Classrooms  Podium - Knee Clearance  2010 ADAS 504.2  Indard: No Quantity: EACH As-built: 1
Implementation Priority: 2 Implementation Phase: Implementation Date:	X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	N/A  Classrooms  Podium - Knee Clearance  2010 ADAS 504.2  Indard: No Quantity: EACH As-built: 1  Podium knee clearance not min. 27" high, 19" deep or 30" wide
Implementation Priority: 2 Implementation Phase: Implementation Date:	X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	N/A  Classrooms  Podium - Knee Clearance  2010 ADAS 504.2  Indard: No Quantity: EACH As-built: 1  Podium knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided
Notes:	X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	N/A  Classrooms  Podium - Knee Clearance  2010 ADAS 504.2  Indard: No Quantity: EACH As-built: 1  Podium knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided  Provide min. 1 accessible podium
	X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution: Barrier Severity:	N/A  Classrooms  Podium - Knee Clearance  2010 ADAS 504.2  Indard: No Quantity: EACH As-built: 1  Podium knee clearance not min. 27" high, 19" deep or 30" wide  No knee clearance provided  Provide min. 1 accessible podium  4 Low Severity Cost Est \$1,275.00 Facility Function: Public Status: Open



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49V				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Classrooms				
Barrier Type:	Alarm - No Horn/Strobe				
Code References:	2010 ADAS 702.1				
Performance Sta	ndard: No Quantity: EACH As-built : 1				
Barrier Description:	Where a fire alarm is installed, no horn/strobe provided				
Findings:	No device provided				
Rec. Solution:	Provide horn/strobe				
Barrier Severity:	1 Necessary Cost Est \$5,500.00 Facility Function: Public Status: Open				
Implementation	Priority: 1 Implementation Phase: Implementation Date:				
Notes:					
-					
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49W				
Field Date: Bldg Name:	6/26/2019 Report Date 9/13/2019 Barrier #: 49W Hovland Hall Reference Dwg: 4 of 4				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Bldg Name: Location:	Hovland Hall Reference Dwg: 4 of 4 Floor 2 - Classroom 202				
Bldg Name: Location: X Coordinate:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A				
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Door leading directly into an exit stairway lacks tactile exit sign				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Door leading directly into an exit stairway lacks tactile exit sign  Door to exit stair with low level illuminated sign lacks tactile exit sign  Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Signage  Tactile Exit Signs - Stairway  Performance Standard  ndard: Yes Quantity: EACH As-built: 1  Door leading directly into an exit stairway lacks tactile exit sign  Door to exit stair with low level illuminated sign lacks tactile exit sign  Provide sign stating "EXIT STAIR DOWN (or UP)" at latch side of door  2 Recommended Cost Est \$250.00 Facility Function: Public Status: Open				



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49X				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Stairways				
Barrier Type:	Handrail - Opening Limitations				
Code References:	Performance Standard				
Performance Sta	ndard: No Quantity: LF As-built : 20				
Barrier Description:	Guard or handrail have openings that allow passage of a 4" sphere				
Findings:	Guardrail height and openings at landing not accessible				
Rec. Solution:	Replace handrails				
Barrier Severity:	1 Necessary Cost Est \$4,500.00 Facility Function: Public Status: Open				
Implementation	Priority: 3 Implementation Phase: Implementation Date:				
Notes:					
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49Y				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Stairways				
Barrier Type:	Handrail Extension - Top				
Code References:	2010 ADAS 505.10.2				
Performance Sta	ndard: No Quantity: LF As-built : 0				
Barrier Description:	Extension does not extend horizontally above landing for min. 12" from first riser nosing				
Findings:	No top extensions provided				
Rec. Solution:	Provide handrails at both sides of stairway				
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open				
Implementation	Priority: 3 Implementation Phase: Implementation Date:				
Notes:					



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49Z				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Stairways				
Barrier Type:	Handrail Extension - Bottom				
Code References:	2010 ADAS 505.10.3				
Performance Sta	ndard: No Quantity: LF As-built : 0				
Barrier Description:	Extension not sloped for length of one tread beyond the last riser nosing				
Findings:	Extension not sloped for the length of one tread long				
Rec. Solution:	Provide handrails at both sides of stairway				
Barrier Severity:	2 Recommended Cost Est \$0.00 Facility Function: Public Status: Open				
Implementation	Priority: 3 Implementation Phase: Implementation Date:				
Notes:					
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49AA				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Stairways				
Barrier Type:	Handrail Height				
Code References:	2010 ADAS 505.10.2				
Performance Sta	andard: No Quantity: LF As-built: 20				
Performance Sta Barrier Description:	ndard: No Quantity: LF As-built : 20 Handrail grip measured at center not 34"- 38" high				
Barrier					
Barrier Description:	Handrail grip measured at center not 34"- 38" high				
Barrier Description: Findings:	Handrail grip measured at center not 34"- 38" high  Handrails not accessible  Provide handrails at both sides of stairway				
Barrier Description: Findings: Rec. Solution: Barrier Severity:	Handrail grip measured at center not 34"- 38" high  Handrails not accessible  Provide handrails at both sides of stairway  2 Recommended Cost Est \$4,500.00 Facility Function: Public Status: Open				
Barrier Description: Findings: Rec. Solution:	Handrail grip measured at center not 34"- 38" high  Handrails not accessible  Provide handrails at both sides of stairway  2 Recommended Cost Est \$4,500.00 Facility Function: Public Status: Open				



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49AB				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Stairways				
Barrier Type:	Riser Height - Existing				
Code References:	2010 ADAS 504.2				
Performance Sta	ndard: No Quantity: SF As-built : 0				
Barrier Description:	Stair riser height is not between 4" and 7"				
Findings:	Riser height not accessible				
Rec. Solution:	Demolish and construct new stairway				
Barrier Severity:	4 Low Severity Cost Est \$0.00 Facility Function: Public Status: Open				
Implementation	Priority: 3 Implementation Phase: Implementation Date:				
Notes:					
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49AC				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Stairways				
Barrier Type:	Tread Depth - Existing				
Code References:	2010 ADAS 504.2				
Performance Sta	ndard: No Quantity: SF As-built: 0				
Barrier Description:	Stair treads are not at least 11" in depth				
Findings:	Stair treads not accessible				
Rec. Solution:	Demolish and construct new stairway				
Barrier Severity:	3 Hindrance Cost Est \$0.00 Facility Function: Public Status: Open				
Implementation	Priority: 3 Implementation Phase: Implementation Date:				
Notes:					



Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49AD				
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Location:	Floor 2 - Classroom 202				
X Coordinate:	N/A Y Coordinate: N/A				
Barrier Area:	Stairways				
Barrier Type:	Contrasting Color - ADA				
Code References:	2010 ADAS Advisory 504.4				
Performance Sta	ndard: Yes Quantity: LF or TR As-built: 26				
Barrier Description:	No contrasting color on each tread of exterior stairway				
Findings:	Treads lack contrasting color defined as 70% contrast				
Rec. Solution:	Recommended: Consider providing contrasting color on each tread				
Barrier Severity:	2 Recommended Cost Est \$910.00 Facility Function: Public Status: Open				
Implementation	Priority: 3 Implementation Phase: Implementation Date:				
Notes:					
Field Date:	6/26/2019 Report Date 9/13/2019 Barrier #: 49AE				
	6/26/2019   Report Date   9/13/2019   Barrier #:   49AE   Hovland Hall   Reference Dwg:   4 of 4				
Field Date: Bldg Name: Location:					
Bldg Name:	Hovland Hall Reference Dwg: 4 of 4				
Bldg Name: Location: X Coordinate:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202				
Bldg Name: Location: X Coordinate: Barrier Area:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Stairways				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Stairways  Open Riser - Existing  2010 ADAS 504.3				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Stairways  Open Riser - Existing  2010 ADAS 504.3				
Bldg Name: Location:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Stairways  Open Riser - Existing  2010 ADAS 504.3  ndard: No Quantity: SF As-built: 40				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Stairways  Open Riser - Existing  2010 ADAS 504.3  Indard: No Quantity: SF As-built: 40  Stair has open risers				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings:	Hovland Hall  Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A  Y Coordinate: N/A  Stairways  Open Riser - Existing  2010 ADAS 504.3  ndard: No Quantity: SF As-built: 40  Stair has open risers  Stair has open risers  Demolish and construct new stairway				
Bldg Name: Location: X Coordinate: Barrier Area: Barrier Type: Code References: Performance Sta Barrier Description: Findings: Rec. Solution:	Hovland Hall Reference Dwg: 4 of 4  Floor 2 - Classroom 202  N/A Y Coordinate: N/A  Stairways  Open Riser - Existing  2010 ADAS 504.3  Indard: No Quantity: SF As-built: 40  Stair has open risers  Stair has open risers  Demolish and construct new stairway  I Necessary Cost Est \$10,000.00 Facility Function: Public Status: Open				





## SUMMARY REPORT

Cost Estimate Total	\$1,450,747.00		
Cost Estimate - Priority 1:	\$25,600.00	% of Total Cost Estimate:	1.76%
Cost Estimate - Priority 2:	\$757,012.00	% of Total Cost Estimate:	52.18%
Cost Estimate - Priority 3:	\$668,135.00	% of Total Cost Estimate:	46.05%